

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0004	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	424 East 34th Street New York NY	Administrative Closure	\$650.00
Short circuit study one Line too small to read. 12/21/16 1) Confirm the FP requirement and show it on the one line diagram. 2) Include the main MV switchgear in the coordination study. 2/7/17 This job is void in lieu of Submittal. #17A0154						
54240	16A0105	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Essex House 160 Central Park South New York NY	Approved	\$650.00
OR 1) Verify 7' clearance in front of service switch #4. 2) Show length of transformer secondary taps. 12/5/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0196CO3	Verde Electric Corp. 811 Whittier Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	500 West 33rd Street New York NY	On Hold	\$0.00
Carry over from August 17, 2016 meeting. 1) How and where is the feeders between the generator and the 13KV secondary switchgear protected.? Are the feeders concrete encased? Medium voltage conductor cut sheet not provided. Is it shielded? 2) Cogen system to be field evaluated by a OSHA recognized NRTL as a complete system. 3) Show by not on drawing indicating fire rated stacked rooms.						
54376	16A0253CO	Walsh Electrical Contracting Inc. 76 Midland Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	55B Richmond Terrace Staten Island NY	Approved	\$0.00
Carry over from August 17, 2016 meeting. 1) F.A. systems #8 fused at 60 amps, FACP transform voltage reversed emergency side F.A. #10s fused at 60 amps. 2) #10 conductors feeding 75 KVA transformer overfused and can't take transformers in rush current with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/8/17 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54158	16A0543CO3	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	25-70 Whitestone Expressway Queens NY	Approved	\$0.00
Carry over from the September 21, 2016 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54306	16A0585CO	Centrifugal Electric, LLC 7 West 36th Street, 6th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	161 Maiden Lane New York NY	Approved	\$0.00
Carry over from September 21, 2016 meeting. 1) Manufacturer's cut sheets of switchgear not provided. 2) ATS connected thru TRX shall be 4 poles. 1/9/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0590	FSM Electrical Corp. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	461 West 34th Street New York NY	On Hold	\$650.00
<p>1) Verify where tap was taken for jockey pump, tap conductors to be #6 and #6 ground. 2) Tap conductors from tap boxes are undersized. DWG 1. 3) Provide coordination study. 4) Drawing 2, bonding and grounding to be made on Line side of neutral link in "Switchgear 1". 5) Elev. panel must coordinate with upstream OCPD with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code</p>						
54291	16A0593	Dooley Electric Co., Inc. 4014 Third Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	787 11th Avenue New York NY	Approved	\$650.00
Verify size of fire alarm feeders. 12/22/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
	16A0596CO	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	222-11 56th Avenue New York NY	Pending	\$0.00
Carry over from August 17, 2016 meeting. 1 Line doesn't match coordination study 4500 amp main breaker to be installed.						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0597CO	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	222-25 56th Avenue Queens NY	Pending	\$0.00
Carry over from August 17, 2016 meeting. 1) Is fire alarm existing or new? New work to be bubbled on drawing. 2) Where is F.A. ATS and panel located? Not fire rated.						
54176	16A0598CO	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	222-05 56th Avenue Queens NY	Approved	\$0.00
Carry over from August 17, 2016 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54168	16A0607	JW Electric Corp. 1106 East 43rd Street Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	91 Junius Street Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0649	PowerOne Electrical Contracting, Inc. 9202 Avenue M Brooklyn NY 11236	Requested approval for the electric service equipment proposed to be installed	22-44 Jackson Avenue Queens NY	Pending	\$650.00
1) Where are the Con Edison boxes located? Show room layout and routing of service entrance conductors. 2) Coordination study not provided. 3) Comply with tap rule for Jockey Pump.						
54140	16A0650	Robert B. Samuels, Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	85 Broad Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0654	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	28-30 Jackson Avenue Long Island City NY	On Hold	\$650.00
<p>1) Line doesn't match equipment on room layout drawing. 2) Where are the Jockey pumps located? Fire pump feeders in the fire pump room are concrete encased. 3) Are feeders to B1-service entrance switchboard installed in EMT or conduit? 4) Show length of transformer secondary taps. 5) Secondary of transformers to be bonded and grounded in one location not two, verify 600 KCM AL equipment grounding conductors on transformer secondary feeders. 6) Fire alarm switch feed to be taken ahead of service switch. 7) Verify compliance with Section 225.32. 8) Provide transformer cut sheets showing listing with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
	16A0660	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Manhattan West North E. Tower 401 Ninth Avenue New York NY	Denied	\$650.00
<p>1) Drawing AB-1 verify amount of feeder conductors off of 2000 and 4000 amp service switches in SS-1. 2) Dwg AB-1 retail bus-tapped conductor to 400 amp switch undersized. 3) Drawing AB-2 verify amount of feeder conductors in conduit. 4) Drawing AB-1, AB-2 verify amount of conductors between split panels. 5) AB-3-verify amount of conductors in conduits and between split panels. 6) Provide derating calculations for conductors in conduits. 7) AB-3 retail trough tapped conductor undersized. 8) AB-4 THHN transition conductors undersized to ATS-2. 9) AB-3 exhaust fan overfused. 10) AB-6 DP-04-ME-3 section bus undersized. 11) AB-6 show amount of conductors in split panel. 12) AB-7 verify amount of conductors in conduits. 13) Generator room doors to open outwards. Explain reactor tank. 14) Wire fill charts exceeded, conductor types not shown. 15) Designer to appear to explain coordination study.</p>						
	16A0666	Interphase Electric Corp. 230 Park Avenue New York NY 10169	Requested approval for the electric service equipment proposed to be installed	58-26 47th Street Maspeth NY	On Hold	\$650.00
<p>1) Equipment grounding conductors and SEC's to transformer to service switchboard undersized. 2) Transformer overfused? Con-ED supplied. 3) Correct notes under bus sizing to correct bus densities. 4) Verify that TRX is corner ground Delta. 5) Coordination study indicates delta Y transformer. 6) Provide summary for coordination study .</p>						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54169	16A0676	Arcadia Electrical Contracting. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	60-30 80th Street Middle Village NY	Approved	\$650.00
<p>Services below 1000 KVA shall not be submitted to the Electrical Advisory Board. Notes: Transition boxes conductors not shown on 1 Line. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	16A0677CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	28 Liberty Street New York NY	Denied	\$0.00
<p>Carry over from September 21, 2016 meeting. 1) 5' rear clearance required on 4160 volt switch. 2) Manufacturer's cut sheet of 480 volt equipment not provided, GFP?</p>						
54162	16A0686	Emanon Electric 114-49 Lefferts Blvd. South Ozone Park NY 11420	Requested approval for the electric service equipment proposed to be installed	1293 Broadway New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
54151	16A0710	Maximum Electrical Corp. 65-19 Metropolitan Avenue Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	24 5th Avenue New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54163	16A0735	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	55 Water Street New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54149	16A0737	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	450 West 33rd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54164	16A0739	Didonato & Sons Elecl Cont. 85 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	2211 3rd Avenue New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54165	16A0740	Walsh Electrical Contracting Inc. 15 Newark Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	319 Beach 98th Street Queens NY	Approved	\$650.00
<p>1st & 2nd fusing existng, not Advisory Board installation. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54152	16A0741	Patriot Electric Corp. 58-71 57th Road Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	125 West 55th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0742	Metropolis Electric Corp. 11-36 31st Avenue Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	30 East 62nd Street New York NY	Denied	\$650.00
Verify service room to comply with 110.26(c) (2) (a) & (b) room to be re-arranged or provide an exit.						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0746	Martin Dorkin, Licensed Electrician 547 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	1535 Bedford Avenue Brooklyn NY	Pending	\$650.00
1) Coordination study signed, sealed and performed by a PE not provided. 2) Tapped conductor to 600 amp disconnect switch undersized.						
54157	16A0747	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	12266 Flatlands Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54138	16A0753	Charles M. Dwyer Inc. Elecl Contg. 2615 Nostrand Avenue Brooklyn NY 11240	Requested approval for the electric service equipment proposed to be installed	505 West 218th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54150	16a0756	Aurora Electrical Contracting, Inc. 155 Water Street Brooklyn NY 11201	Requested approval for the electric service equipment proposed to be installed	523 Fulton Street Brooklyn NY	Approved	\$650.00
OR This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54293	16A0757	Primiano Electric Co. 600 Third Avenue, 2nd Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	1230 York Avenue New York NY	Approved	\$650.00
1) F.A. S.S. to be 600V rated. 2) How end bus is accessible from the front? 12/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54139	16A0758	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	100 Centre Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0759	Primiano Electric Co. 600 Third Avenue, 2nd Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	1230 York Avenue New York NY	On Hold	\$650.00
1) Feeder is overfused. 2) Verify trip setting for D5 section. 3) Coordinate study with actual devices.						
54161	16A0761	Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	60 Hudson Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
	16A0762	Top Shelf Electric Corporation 4386 Victory Blvd Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	122 East 23rd Street New York NY	Denied	\$650.00
OR 1) Provide neutral disconnect links for service switches 4 and 5. 2) Parallel conductors to comply with 310.4(B). 3) Coordination study not provided. 4) Meter bank and circuit breaker cut sheets not provided. 5) Secondary of transformer to GAR-C overfused and length of tap not shown. 6) Secondary of 1000 KVA transformer overfused 120/208. 7) Show size of bonding jumpers on load side of transformers. 8) Transformer cut sheets not provided. 9) Genset cut sheet not provided. 10) Emergency fire alarm disconnect switch bonded and grounded on a separately derived system. 11) 1 Line doesn't match physical.						
54170	16A0763	Team Electric, Inc. 20 West 36th Street, 10th Fl. New York NY 10001	Requested approval for the electric service equipment proposed to be installed	81 Propect Street Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54308	16A0774	A.L. Electrical Corp. 307 7th Avenue, Suite 404 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	2230 Broadway New York NY	Approved	\$650.00
<p>1) Service entrance and feeders to fire pump undersized. 2) Show bus size feeding Switch #3. 3) Tap conductor to 400A trans device is undersized. 4) Show feeder sizes on emergency sides of ATSS with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/10/17 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54144	16A0777	Circle D Electrical Contracting Inc. 3525 Rombouts Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	99 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54147	16A0778	GC Eng & Associates, P.C. 141 West 28th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	181 Bay Street Staten Island NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54145	16A0779	K & R Electric Co. 4347 Hylan Boulevard Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	21 West End Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54239	16A0780	RGF Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	491 Gerard Avenue New York NY	Approved	\$650.00
1)SS MDP mislabeled. 2) Main bonding jumper for 4000 amp switch is undersized. 12/5/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54143	16A0781	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	235 West 76th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54232	16A0782	A.S.M. Electric & Machine Corp. 333 West 39th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	1501 Broadway New York NY	Approved	\$650.00
OR Equipment grounding conductor undersized. 11/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/29/16 Job finalized..Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54142	16A0783	Hi-Tech Wiring Electrical Services 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	23 East 22nd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54378	16A0784	Citywide Electrical Wiring Inc. 30-73 Crescent Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	29-10 Broadway Astoria NY	Approved	\$650.00
1) One line does not match physical (cut sheets) for main distribution board house. 2) Show number of sets of conductors in split panel. 2/2/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54141	16A0785	Safetech Electrical Contracting Corp. 102-29 Jamaica Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	255 West 84th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54179	16A0787	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	110 East 42nd Street New York NY	Approved	\$650.00
OR Verify jockey pump tap on line side of ATS.. 10/27/16 Jockey pump ok. Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54155	16A0788	Techno-Volt Electric, Inc. 28-29 119th Street Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	1399 Park Avenue New York NY	Approved	\$650.00
OR With the stipulation: Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54154	16A0789	HV Electric Corp. 36-17 Bud Place Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	1407 Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54153	16A0790	Reliant Electrical Contracting Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	487 Livonia Avenue Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54160	16A0791	CRM Electric Corporation 461 West 261st Street Bronx NY 10471	Requested approval for the electric service equipment proposed to be installed	1939 West Farms Road Bronx NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54159	16A0792	NYCOM Electric Corp. 36-09 20th Avenue Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	122 West 146th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 2/13/17 swap dwg # 1 Rev 1						
54166	16A0793	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	1875 Atlantic Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54167	16A0794	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	25 Bruckner Blvd. Bronx NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54295	16A0795	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	150-01 89th Avenue Jamaica NY	Approved	\$650.00
Fire pump feeder not fire rated. 1/3/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

October 19, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54156	16A0798	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	115 Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54230	16A0799	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	28 Liberty Street New York NY	Approved	\$650.00
1) Identify switchboards on 1 Lines and physicals. 2) 16A00A, 480V disc switch to be ground fault protected. 11/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54146	16A0800	Allstate Electric Corp. 555 Eighth Avenue, Suite 809 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	30 East 40th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/4/16 Swapped Drawing #A091609-Revision #1						
54171	16A0801	Reliant Electrical Contracting Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	500 Livonia Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						