

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
	16A0004	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
Short circuit study one Line too small to read. 12/21/16 1) Confirm the FP requirement and show it on the one line diagram. 2) Include the main MV switchgear in the coordination study. 2/7/17 This job is void in lieu of Submittal. #17A0154				
54240	16A0105	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Verify 7' clearance in front of service switch #4. 2) Show length of transformer secondary taps. 12/5/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0196CO3	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carry over from August 17, 2016 meeting. 1) How and where is the feeders between the generator and the 13KV secondary switchgear protected.? Are the feeders concrete encased? Medium voltage conductor cut sheet not provided. Is it shielded? 2) Cogen system to be field evaluated by a OSHA recognized NRTL as a complete system. 3) Show by not on drawing indicating fire rated stacked rooms.				
54376	16A0253CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from August 17, 2016 meeting. 1) F.A. systems #8 fused at 60 amps, FACP transform voltage reversed emergency side F.A. #10s fused at 60 amps. 2) #10 conductors feeding 75 KVA transformer overfused and can't take transformers in rush current with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/8/17 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54158	16A0543CO3	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from the September 21, 2016 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/5/18 Swap dwgs dwg 1-Revision 2, dwg 2-Revision 3 and dwg 3-Revision O.				
54306	16A0585CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from September 21, 2016 meeting. 1) Manufacturer's cut sheets of switchgear not provided. 2) ATS connected thru TRX shall be 4 poles. 1/9/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54789	16A0590	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify where tap was taken for jockey pump, tap conductors to be #6 and #6 ground. 2) Tap conductors from tap boxes are undersized. DWG 1. 3) Provide coordination study. 4) Drawing 2, bonding and grounding to be made on Line side of neutral link in "Switchgear 1". 5) Elev. panel must coordinate with upstream OCPD with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 9/28/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/23/19 - Swap dwg 1&amp;2 rev 1</p>				
54291	16A0593	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Verify size of fire alarm feeders. 12/22/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 4/21/2020 Amended Drawings Dwgs A-Revision 5; B-Revision 2; C-Revision 2; D-Revision 2 and E-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. to clearly mark and note all changes to original approved DWGs. 12/21/2020 Amended dwg# A Rev 6 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/9/2021 Amended dwgs # C &amp; D Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 3/25/2021 Amended dwgs# A Rev 7, D Rev 4 and E Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54469	16A0596CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from August 17, 2016 meeting. 1 Line doesn't match coordination study 4500 amp main breaker to be installed. 3/28/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/26/18 - swap dwg Rev 3. 11/1/19 Swap Dwg rev 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
54468	16A0597CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from August 17, 2016 meeting. 1) Is fire alarm existing or new? New work to be bubbled on drawing. 2) Where is F.A. ATS and panel located? Not fire rated. 3/28/2017 - job finalized. 7/2/18 1) Comply with 230.64(B)(4)-Provide seal at the other end of main 4000A switchboard and verify equipment in the back of the switchboard.5/7/19 - Swap dwg #A061603 Rev-4. 9/19/19 Swap Dwg # A061603 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
54176	16A0598CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from August 17, 2016 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/2/18 Comply with 230.64(B) at main 4000A switchboard distribution sections. 5/13/19 Swap Dwg #A061604 Rev-4. 9/19/19 Swap Dwg # A061604 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
54168	16A0607	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/20/17 - 1) Service bus feeds S.SW # 2,3,4 & 5 is undersized. 2) F.A. tap to be before N.D.L. 3) F.P. bonding is undersized. 11/21/17 - swap dwg 1 of 2 & 2 of 2 Rev 1				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54427	16A0649	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Where are the Con Edison boxes located? Show room layout and routing of service entrance conductors. 2) Coordination study not provided. 3) Comply with tap rule for Jockey Pump. 2/8/2017 - 1. Provide a larger and clear dwg for the coordination study 3/6/2017 - Job Finalized .Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54140	16A0650	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	16A0654	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) ILine doesn't match equipment on room layout drawing. 2) Where are the Jockey pumps located? Fire pump feeders in the fire pump room are concrete encased. 3) Are feeders to B1-service entrance switchboard installed in EMT or conduit? 4) Show length of transformer secondary taps. 5) Secondary of transformers to be bonded and grounded in one location not two, verify 600 KCM AL equipment grounding conductors on transformer secondary feeders. 6) Fire alarm switch feed to be taken ahead of service switch. 7) Verify compliance with Section 225.32. 8) Provide transformer cut sheets showing listing with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
	16A0660	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Drawing AB-1 verify amount of feeder conductors off of 2000 and 4000 amp service switches in SS-1. 2) Dwg AB-1 retail bus-tapped conductor to 400 amp switch undersized. 3) Drawing AB-2 verify amount of feeder conductors in conduit. 4) Drawing AB-1, AB-2 verify amount of conductors between split panels. 5) AB-3-verify amount of conductors in conduits and between split panels. 6) Provide derating calculations for conductors in conduits. 7) AB-3 retail trough tapped conductor undersized. 8) AB-4 THHN transition conductors undersized to ATS-2. 9) AB-5 exhaust fan overfused. 10) AB-6 DP-04-ME-3 section bus undersized. 11) AB-6 show amount of conductors in split panel. 12) AB-7 verify amount of conductors in conduits. 13) Generator room doors to open outwards. Explain reactor tank. 14) Wire fill charts exceeded, conductor types not shown. 15) Designer to appear to explain coordination study.</p>				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54566	16A0666	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Equipment grounding conductors and SEC's to transformer to service switchboard undersized. 2) Transformer overfused? Con-ED supplied. 3)Correct notes under bus sizing to correct bus densities. 4) Verify that TRX is corner ground Delta. 5)Coordination study indicates delta Y transformer. 6) Provide summary for coordination study .3/29/17 - item 1 not addressed. 2) Conductors feeding 2000 amp service switch undersized. 5/16/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/5/18 - swap dwg with Rev 3</p>				
54169	16A0676	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Services below 1000 KVA shall not be submitted to the Electrical Advisory Board. Notes: Transition boxes conductors not shown on 1 Line. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.                      Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/2/18 - swap dwg 1 Rev 2</p>				
	16A0677CO	Requested approval for the electric service equipment proposed to be installed	Denied	\$0.00
<p>Carry over from September 21, 2016 meeting. 1) 5' rear clearance required on 4160 volt switch. 2) Manufacturer's cut sheet of 480 volt equipment not provided, GFP?</p>				
54162	16A0686	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
54151	16A0710	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/22/17 - dwg - 12561 rev 1</p>				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54163	16A0735	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/7/19 - Swap dwg #AB20 - 1 of 3, 2 of 3, 3 of 3 Rev-1. SB40 - 1 of 6 (Rev-3), 2 of 6, 3 of 6, 4 of 6, 5 of 6, 6 of 6 Rev-2. FP20 - 1 of 2 Rev-1.				
54149	16A0737	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54164	16A0739	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/28/17 - swap dwg with Rev 1				
54165	16A0740	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1st &amp; 2nd fusing existng, not Advisory Board installation. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54152	16A0741	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/23/17 Swapped drawing #1-Revision 1.				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
	16A0742	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
Verify service room to comply with 110.26(c) (2) (a) & (b) room to be re-arranged or provide an exit. 10/24/17 Although this submittal was Denied, it will be void in lieu of submittal number 17A0155.				
54441	16A0746	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Coordination study signed, sealed and performed by a PE not provided. 2) Tapped conductor to 600 amp disconnect switch undersized. 3/15/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/22/18 - Contractor name changed. 3/27/2020 Dwg swap Dwg 1 and 2-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
54157	16A0747	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54138	16A0753	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54150	16a0756	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the board. Contact Con-Edison regarding Blue Book requirements. 5/12/17 - 1) tapped conductors off 5000A SW is undersized 2) Provide physicals of switchboard. 3) Provide tap length. 8/29/17 - comments 1 & 2 not addressed. 11/22/17 - swap dwg 1 rev 2				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54293	16A0757	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) F.A. S.S. to be 600V rated. 2) How end bus is accessible from the front? 12/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 8/25/17 - swap dwg # 2 of 4 rev 2, # 3 of 4 rev 2 11/8/19 Swap Dwg # 1 of 4 Rev. 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
54139	16A0758	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0759	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Feeder is overfused. 2) Verify trip setting for D5 section. 3) Coordinate study with actual devices.				
54161	16A0761	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
	16A0762	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
OR 1) Provide neutral disconnect links for service switches 4 and 5. 2) Parallel conductors to comply with 310.4(B). 3) Coordination study not provided. 4) Meter bank and circuit breaker cut sheets not provided. 5) Secondary of transformer to GAR-C overfused and length of tap not shown. 6) Secondary of 1000 KVA transformer overfused 120/208. 7) Show size of bonding jumpers on load side of transformers. 8) Transformer cut sheets not provided. 9) Genset cut sheet not provided. 10) Emergency fire alarm disconnect switch bonded and grounded on a separately derived system. 11) 1 Line doesn't match physical.				
54170	16A0763	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				



# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54308	16A0774	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Service entrance and feeders to fire pump undersized. 2) Show bus size feeding Switch #3. 3) Tap conductor to 400A trans device is undersized. 4) Show feeder sizes on emergency sides of ATSS with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/10/17 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54144	16A0777	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54147	16A0778	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54145	16A0779	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54239	16A0780	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1)SS MDP mislabeled. 2) Main bonding jumper for 4000 amp switch is undersized. 12/5/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/2/18 - swap dwg with Rev 3				
54143	16A0781	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54232	16A0782	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Equipment grounding conductor undersized. 11/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/29/16 Job finalized..Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/16/2017 -swap dwg rev 2				
54142	16A0783	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54378	16A0784	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) One line does not match physical (cut sheets) for main distribution board house. 2) Show number of sets of conductors in split panel. 2/2/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
54141	16A0785	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54179	16A0787	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Verify jockey pump tap on line side of ATS.. 10/27/16 Jockey pump ok. Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54155	16A0788	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR With the stipulation:  Fire Rated Enclosure's must comply with the following:  1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/20/19 Swap Dwg 1-Revision 4.				
54154	16A0789	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54153	16A0790	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/6/19 Swap Dwgs 1&2 rev1				
54160	16A0791	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54159	16A0792	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 2/13/17 swap dwg # 1 Rev 1 6/7/19 Swap dwg #1-Revision 2. 8/15/19 Swap Dwg #ACS-D-12610-1 Rev.3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. No more Swaps.				
54166	16A0793	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/15/17 - swap dwgs 1 & 2 rev 1				
54167	16A0794	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/24/17 Swapped drawing #1-Revision 2 and Drawing #2-Revision 2. 2/26/18 - swap dwg with Rev 3 Now Short Circuit Study Submitted				
	16A0795	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
Fire pump feeder not fire rated. 1/3/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/12/17 - void in lieu of 17A0498				
54156	16A0798	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				

# ADVISORY BOARD CALENDAR

**October 19, 2016**

Approval #	Submission #	Type of Request	Status	Fee
54230	16A0799	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Identify switchboards on 1 Lines and physicals. 2) 16A00A, 480V disc switch to be ground fault protected. 11/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/26/18 - Swap dwg 1,2 & 3 Rev 2. 12/14/18 Swap dwg # 1,2, and 3-Revision 2. 2/12/19 Swap dwg 2 of 3 and 1 of 3-Revision 3. 5/10/19 Swap dwg 1 of 3 and 3 of 3-Revision 3				
54146	16A0800	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/4/17 Swapped Drawing #A091609-Revision #1 1/25/18 - Swap dwg # A091609 - Rev # 2				
54171	16A0801	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/8/19 Swap dwg # 1&2 Rev-1				