

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| 53605 | 15A0283CO2 | Requested approval for the electric service equipment proposed to be installed | Approved | \$0.00 |
| <p>1) Main bonding jumpers undersized in switchboards. 2) Equipment grounding conductors undersized for service entrance conductors CUP-E. 3) FA transformer 115KVA fed by 60A fuse and tap length to FA cutout feeder? 4) Emergency side not fully coordinated. 1/27/16 Rejected 1) Genset changed to separately derived system put note under emergency panel indication whether 3 or 4 pole ATS' are being used. Is F.A. system 3 or 4 wire? 2) Show size of FA secondary conductors. 3/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/22/16 Swapped drawing FP-Revision 3. 1/30/17 Remove the fuse between fire alarm ATS & fire alarm transformer. 8/31/17 - swap dwg AB20-01, 02, 03 dwg SB80-01, 03, 05 9/21/17 - swap dwg AB20-02 of 3 No More Swaps</p> | | | | |
| 53272 | 15A0310CO | Requested approval for the electric service equipment proposed to be installed | Approved | \$0.00 |
| <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| | 15A0341 | Requested approval for the electric service equipment proposed to be installed | Pending | \$650.00 |
| <p>1) Normal side fire pump conductors undersized. 2) Feeders to panel EDP-Roof overfused on emergency side. 3) Provide manufacturers installation instructions for MI cable showing MI directly connected to equipment lugs with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| 53836 | 15A0352 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) 2nd set of Genset cut sheets. 2) Service entrance conductors are undersized. 3) Fire pump emergency feeder not fire rated, verify neutral conductors. 4) Fire alarm service switch not bonded and grounded. 5) Verify rear access of service switch B. 6) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7) Verify adequate clearance under existing pullbox. 8) Verify if Gen is emergency or optional stand by. 5/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/5/18 - swap dwg 1 Rev 2. 12/27/18 Swap dwg. #1-Revision 3. 4/23/19 1) Fire pump conductor-normal side-is undersized. 2) Provide coordination between new 1200A breaker and downstream fuses in "EDP-LS". 6/7/19 Swap dwg #1 of 1-Revision 5. 8/22/19 1) Provide coordination between 3000A LCL and downstream fuses. 1/27/2020 Swap Dwg # 35424479 Rev-6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |
| 54054 | 15A0454 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Verify feeder sizes and wiring methods to meter banks. 2) Service entrance conductors to 1200 amp service switches undersized, if it one set or sets. 3) How are the 2-1200 amp services switch being fed? Are line and load in same enclosure? 4) Show sections sizes from end box to c.t. 8/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p> | | | | |
| 53549 | 15A0475CO | Requested approval for the electric service equipment proposed to be installed | Approved | \$0.00 |
| <p>Carry over from August 12, 2015 meeting. 3 setsif 4/0 fused at 1200 amps and conduit size. Cut sheet not provided.(two locations)... 2/16/16 Rejected 4/0 rated at 305 x 3=915 fused at 1200 amps. 2/19/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.8/23/17 - swap DWG # 36444271 rev -3 7/31/18 - swap dwg 1 of 3 Rev 3</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| 53459 | 15A0495 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Provide separation between thru(service) bus and distribution. 1/26/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 54052 | 15A0500 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Verify that this building is one lot. 2) Fire alarm load side ATS' #10 fused at 60 amps. 3) Verify transformer sizes 1.2. KVA. 4) Cut sheets showing cogen listing not provided. 5) 75 KVA transformers overfused. 6) Provide separation between service bus and distribution. 7) Remove equipment ground from second building service conductor. 2/18/16 Each lot needs a separate P.O.E. 5/23/16 "Rejected" Letter from the borough president is still needed with "no objection". 8/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/24/2017 - Comply 110.26 (A) (3) for beckwith control & 60A ARC disc. Switch in service room 2A & 2B. 2) Comply section 230.64(B) for FA disc switch in service room 2A 3) Comply section 230.42 (A) for SS # 2, FA & ARC Service disc. Bus bar rating in service switchboard 2A. And SS#4, FA & ARC in service switchboard 2B 4) Show tap length for retail tenant meter & from junction box to 1S Tr Fuse. 5) Show ground conductor size on building 2A & 2B grounding details. 6/19/2017 - swap dwg with rev 5 & rev 6 9/26/17 - 1) Verify clearance in front of 75KVA xfmr in ATS room 2A. Table 110.269A)(1 10/2/17 Drawing swapped P-2871-D-1 with Revision 7.</p> | | | | |
| 53620 | 15A0508 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Verify that utility is bringing in service conductors to service room. 2) Service entrance conductors to fire pump service switchboard to comply with 430.24. 3) Verify conductors on secondary of 1000 KVA transformers to 1200 amp disconnect switch and load side of switches. 4) Will panel OHDP3 be fed with 3 or 4 conductors with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/25/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/26/2020. 1) Provide signed and sealed coordination study. 6/4/2020 Swap drawings # A REV 2, B REV 6, C REV 3 and D REV 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/23/2020 Amended Plan # A Rev- 3 & B Rev-10. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/21/2020 Amended Plan # B Rev- 11 & # D Rev- 8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 53437 | 15A0516 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Section bus feeding service switches 4 and 5 undersized. 1/19/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/25/18 - swap dwg 1 of 2, 2 of 2 Rev 1 | | | | |
| 53816 | 15A0538 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Service entrance conductor trough to comply with 376.22, not clear on drawing, shows 2 incoming utility points on room lay 1 vault has no doors. 2) Verify size of fire alarm transformer, primary fuse with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/11/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| | 15A0540 | Requested approval for the electric service equipment proposed to be installed | Rejected | \$650.00 |
| <p>OR This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/22/17 - 1) Equipment Gnd conductor undersize from FP SS# to FP controller 2) Normal side of "EXT'g ATS-FA2" is overfused</p> | | | | |
| 53273 | 15A0541 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 53302 | 15A0556 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| | 15A0559 | Requested approval for the electric service equipment proposed to be installed | On Hold | \$650.00 |
| <p>1) Indicate on site plan drawing where co-location (the Bridge) is located. 2) AB20-1 of 3, indicate which feeders are existing, "new". switches are being installed, must be clearly noted for inspection purposes. Where will fire alarm and fire pump switches be located in "the Bridge" building? 4) Provide signage in "Bridge" building electrical distribution room indicating where equipment listed under 225.30(A) are located as per 225.37. 5) Add note under panel board EDP indicating whether 3 or 4 pole ATS' will be installed or 3 phase-3 wire a 3 phase-4 wire systems will be used. 6) Gen system to be re-coordinated. 7) Service switchboard SB-cup-C says new but its on another submittal. 8) Provide grounding scheme drawing for separate buildings. 9) Clarify 2 switches for fire pump instead of feeding controller that's service rated. 10) Clarify grounding in EDP panel with no EGC's. 11) Verify amount of conductors from generator to fire alarm ATS. 3 pole used with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> | | | | |
| 53274 | 15A0563 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53275 | 15A0565 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 53303 | 15A0572 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements | | | | |
| 53956 | 15A0585 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Show clearances in service room. 6/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/20/16 Swapped dwg 1-Rev 2. | | | | |
| | 15A0586 | Requested approval for the electric service equipment proposed to be installed | Denied | \$650.00 |
| 1) Drawing is not clear on new work. 2) All new work to be bubbled, explain the scope of work for this submittal. | | | | |
| 53667 | 15A0587 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Verify that western EMT is listed to be used with fire rated conductors, is the RHW-2 fire rated conductors. If so, indicate it on the drawing and provide installation instructions. 2) Generator, verify compliance with 445.18, show length of generator feeders. 3) Verify whether generator is separately derived system or not, 3 and 4 wire loads connected to generator, 4 wire load to 3 pole ATS'. 4) Verify that line and load is not mixed in vertical section of switchboard for fire pump service entrance conductors. 5) Size of EGC's not shown to ATS #2 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6) Provide coordination curves for "SB-MER". 10/30/15 Sub #15A0266 is void in lieu of this Sub. #15A0587. 4/19/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/14/16 Swapped Drawing B-Revision 6.</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| | 15A0588 | Requested approval for the electric service equipment proposed to be installed | On Hold | \$650.00 |
| <p>1) Submissions to be submitted as 2 independent sets of drawings and cut sheets. 2) Show clearances in switchgear rooms. 3) Drawings-3,4 and 5. Show feeders to drawing-2. 4) Show bus sizes on drawing Drawing-2. 5) Show size of MI cable on Drawing-3. 6) Show where normal feeders connects to switchboard ssc. 7) Transformer secondary to be bonded and grounded in 1 location fire alarm, line and load sides of transformers. 8) Fire alarm ATS verify 4 pole ATS on 3 wire system. 9) Show all bus sizes on 1 Line drawing. 10) Bus on load side of transformer undersized on drawings 3,4 and 5. 11) Bus sizes to comply with 408.60(E)(3)(A). 15) Increase interrupting rating on lighting and power panel as per coordination /s.c. study.</p> | | | | |
| 53623 | 15A0589 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Verify ground fault indication on generator. 2) F.A. system overfused. 3) ATS #10 verify feeders and neutral (4P ATS). 4) 1-Line emergency board notation indicates fuses correct to cb. 5) Fire alarm and fire pump taps must be before all OCPD. 6) Indicate GFI for all optional standby over 1000A. 7) Correct location of Jockey Pump tap location. 3/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/10/19 1) Terminate neutral at 200A fire alarm switch and confirm bonding as per 250.28(D)(1)-Dwg B. 2) Confirm using 4 pole ATS for future fire alarm for using 4 wires. 3) Clarify reason to change kirk key locations in "TDP-209-G3-SB-14A1" and "TDP-210-G3-SB-14 B L" 11/18/19 Swap Dwg # A & B Rev-3 and Dwg # C, F & D Rev- 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/5/2020 Amended Plan #B Rev-4, #C Rev-3, and #D,E & F Rev-2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |
| | 15A0597 | Requested approval for the electric service equipment proposed to be installed | Pending | \$650.00 |
| <p>1) Provided manufacturer's cut sheets of equipment and physicals of service equipment, end box showing extension. 2) Transformer secondary to be bonded and grounded, show length of secondary tap. 3) Show supplemental grounds on 1 Line. 4) Add stipulation to indicate approval is for temp service only. 5) Provide mechanical ventilation for room.</p> | | | | |
| 53276 | 15A0612 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/20/18 - swap dwg A,B, & C Rev 3 8/3/18 - 1) Provide coordination between 1200A KRPC & 400A FRN fuse 2) GEC of SS# 5 is undersized T250.66. 9/28/18 Swap dwg #B-Revision 4 and C-Revision 5. 12/31/18 1) Update changes to ss#5 in floor plan and provide 5' clearance. 2/1/19 Swap dwg# A & B-Revision 5 and dwg C-Revision 6.</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| | 15A0613 | Requested approval for the electric service equipment proposed to be installed | Denied | \$650.00 |
| <p>1) Switchboard #1 section bus feeding ss, 1A, 2A, 3A and 4A undersized. 2) Show size of transformer secondary conductors off of MDP-78. 3) Switchboard #2 section bus feeding ss 3B, 4B, and 5B undersized. 4) Substation #4 provide ground fault protection on 2000 amp main switch. 5) Drawing D, fire pump feeders not fire rated. 6) Drawing D correct voltage on 750 KVA transformer to 480/277V. 7) Switchboard 1 and 2 1Line doesn't match physical. 8) Verify switchboard 1 and 2 1 Line doesn't match physical. 8) Verify switchboard complies with 408.60(F). 9) Provide room layout drawings for substations. 10) Fire pump service switches not to be ground fault protected. 11) Provide coordination study.</p> | | | | |
| 53402 | 15A0619 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Advisory Board approval is limited to connection to 1000 KVA switchboard only. 2) Drawing not in Advisory Board format. 3) Contractors name not in title block. 4) Explain generator disconnect switch and where it is located, not shown in service room, clearances not shown in service room. 5) Show compliance with Section 690.17. 6) Wiring methods not shown. 7) Transformer sizes not shown on 1Line, TR1 and TR2 not shown on 1 Line, fuse sizes and switch sizes not shown and equipment grounding conductors can't be reviewed. 8) Do not use charts. 9) Bonding and grounding of service not shown. 1/5/16 OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/14/16 Swapped Drawing D-Revision 1.</p> | | | | |
| | 15A0620 | Requested approval for the electric service equipment proposed to be installed | Pending | \$650.00 |
| <p>Length of tap not shown, tap conductor undersized.</p> | | | | |
| 53304 | 15A0622 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/16/16 Rejected AB50-2 of 2 Aluminum equipment grounding conductors undersized in two locations. 3/22/16 Swapped Drawing FP60-01-Revision 1; AB50-01 and 2-Revision 2s. 3/25/16 Received letter to change address from 2566 Richmond Avenue to 2655 Richmond Avenue-Staten Island.</p> | | | | |
| 53253 | 15A0625 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>OR Expedited Review Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| | 15A0628 | Requested approval for the electric service equipment proposed to be installed | On Hold | \$650.00 |
| <p>1) How will medium voltage cable installed, supported, concealed, exposed, concrete encased from basement to 49th floor. 2) See 328.12. 3) Show how medium voltage cable will connect to transformer (wire bending radius, stress cones). 4) Coordination study not provided, just short circuit calculations.</p> | | | | |
| 53921 | 15A0631 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Verify that rear of 4000 amp service switch complies with 408.60(F). 2) Existing end box not shown on 1 Line, drawing from Eaton shows sec's coming off of switchboard not end box.. End box not shown in service room. 3) Explain 1200 amp ss feeding 3-800 amp disconnect switches in panel MS-house. 4) EGC on load side of fire pump service switch undersized. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/21/16 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/18/16 Swapped Drawing 2-Revision 2; Drawing 3-Revision 2 and Drawing 4-Revision 1.</p> | | | | |
| 53839 | 15A0632 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Verify size of 6"x6" trough containing polaris connectors and conductors bonding radius provide calculations. 2) HDP panel to have main does not comply with 10' tap rule. 3) Provide note under EDP panel indicating whether 3 or 4 pole ATS' will be used. 4) Verify 5' clearance in front of ss #5. 5) Change CB as per s.c. study with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/25/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/12/17 Neutral in PV switch to be bonded and grounded.3/27/2017 - swap dwg 1 Rev 3 , dwg 2, Rev 2</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 53277 | 15A0634 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.. 8/23/19 Swap dwg #-Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.. | | | | |
| 53455 | 15A0635 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Provide coordination study for elevators. 1/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53622 | 15A0636 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Bus ducts shall not have joints with the plenum 368.10. 2) Fire alarm and fire pump emergency feed to be taken from line side of generator switches. 3) Fire pump feeder to be 125% of motor FLA. 4) Clarify type of fire pump emergency feeder between transition boxes. 5) 4 and 3 pole ATS used, neutral in generator bonded and grounded, clarify number of conductors in conduits. 3/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53299 | 15A0638 | Requested approval for use in New York City of your LED Lighting System. | Approved | \$200.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53298 | 15A0641 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53296 | 15A0642 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 53507 | 15A0645 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Section bus in DP-8-1 undersized. 2) Feeder to new 9th floor transformer undersized. 3) Show length of secondary tap conductors. 2/11/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| 53443 | 15A0646 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>Physical does not match 1 Line for temp distribution board 2. 1/20/16 Job finalized. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| 53278 | 15A0649 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| | 15A0651 | Requested approval for the electric service equipment proposed to be installed | Rejected | \$0.00 |
| <p>SANDY 1) Signs to be attached to the back of med--voltage compartment to indicate "medium voltage loop compartment shall not be accessed energized." 2) Provide clean set of drawing (drafting error). 3) Verify clearance in front of mid voltage section. 4) Letter to be amended to indicate "shall not" as EAB comment and to be signed and stamped by P.E. 5) Address coordination 2 issues "recommendation" on the short/coordination study. 1/28/16 Rejected Letter to address Item 5 from JB & B waiting for revised drawings.</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| 54457 | 15A0652 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Verify that service switchboard switchboard complies with 408.60(F). 2) Is A-MCC-02 rear accessible? 3) Verify that service room is mechanically ventilated and b was room. 4) Are ATS' in service room feeding life safety systems. 5) Relocated A-PLC-01. 6) Verify note B on load side 11B main, main 52-M2 and line side of 7B tie 52 T. 7) Is fire pump listed as service equipment for direct connect. Is ATS for fire pump service rated, no fire pump service switch shown on drawing. 8) Verify that Jockey Pump ATS is service rated. 9) Fire pump emergency feeder not fire rated. Review stopped. 9/7/16 Rejected. 1 Item 1 not addressed. 2) Item 7 partially addressed, fire pump cut sheets showing listing not provided. 3 Verify size of emergency generator. 4) Verifiy 3 pole ATS' used on 4 wire system. 5) Transformer 03 feeds more than 6 disocnnect switches with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/24/17 - job finalized -Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/9/18 Swap dwg 1, 2, 3, 4 and 5-Revision 3 8/8/19 Swap Dwg 1.2 & 3 rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |
| 53448 | 15A0654 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>Service entrance conductors to be increased.. 1/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| 53446 | 15A0655 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) General notes not shown on drawing. 2) Manufacturer's equipment cut sheets not provided. 3) Show switch sizes on room layout drawing. 4) Confirm that pull boxes located in buildings B-1 and B-2 are properly located as per 225.32. 1/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| 53395 | 15A0657 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>Show sizes of equipment grounding conductors in new MC cables. 12/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|------------------------|----------|
| 53292 | 15A0660 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/11/16 Swapped drawings 1 and 2, Revision 2. | | | | |
| 53611 | 15A0661 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Show coordination on emergency side. 3/21/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements | | | | |
| 53439 | 15A0662 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Service room door to open outwards. 1/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| | 15A0663 | Requested approval for the electric service equipment proposed to be installed | Administrative Closure | \$650.00 |
| 1) General notes not on drawing. 2) Manufacturer's equipment cut sheets not provided. 3) Switch sizes not shown on room layout drawing. 4) Verify bus size in 1600 amp HDP panel. 5) Fused disconnect switch required for roll up generator. 1/21/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/7/17 - Void in lieu of 17A0324 | | | | |
| 53449 | 15A0664 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Explain new service end box mounted in ceiling, and verify that this is allowed by the utility, show elevation drawing. 2) Service room door to open outwards. 1/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 53516 | 15A0665 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Who will performing the replacement of link fuses with fuses bus work, verify listing. 2) Existing service entrance undersized service entrance conductors to be taken from the service entrance end box for the fire pump. 3) Tap conductor to 400 amp disconnect switch undersized. 2/12/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/28/16 Swapped drawing 1-Revision 2 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53290 | 15A0667 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/5/17 - swap dwg A & B rev 1 | | | | |
| 53284 | 15A0668 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53556 | 15A0669 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Service room doors to open outwards. 2/25/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53285 | 15A0672 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53293 | 15A0673 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 53351 | 15A0678 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>Manufacturer's cut sheets showing listing not provided for co-gen units. 12/3/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| | 15A0679 | Requested approval for the electric service equipment proposed to be installed | Pending | \$650.00 |
| <p>1) Where is the generator and EMBI switchboard located show compliance with 445.18, show lengths of generator feeders. 2) Show service entrance conductor sizes to 2500 amp service switch with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> | | | | |
| 53618 | 15A0680 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Service room doors to open outwards. 2) 1 Line doesn't match physicals. 3) Service bus undersized. 4) Verify meter bank type fuses. 5) Meter bank cut sheets and fusing cut sheets not provided with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/1/16 Rejected. 1 Line doesn't match physicals. 3/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/12/2017 - 1) Conductor feeding DP-Elev normal side is undersized. 2) Physical doesn't match one line (Dist. Section # 1) 3/24/17 - swap Dwg 1 Rev 3, Dwg 2 Rev 4 3/16/18 - 1) Comply with 408.60 (A) - NDL to be downstream of the main bonding jumper 4/26/18 - swap dwg 1 of 2 Rev 4</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 53294 | 15A0681 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53390 | 15A0682 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| EGC is undersized for ss #1 & 2. 12/18/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53452 | 15A0683 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) More than 40 service entrance conductors in wireway. 2) Supplemental grounds not shown on 1Line. 1/22/16 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53616 | 15A0685 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Pad not to extend more than 6". 2) Indicate mechanical ventilation from the room. 3/23/16. Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.5/28/2020 Swap drawings # 1 REV-3, 2 REV-3, 3 REV-2 and4&5 REV-0 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| | 15A0686 | Requested approval for the electric service equipment proposed to be installed | On Hold | \$650.00 |
| Not Reviewed. | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 53438 | 15A0687 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Verify that existing service equipment is bonded and grounded. 2) 4/0 equipment grounding conductor undersized to new 1600 amp disconnect switch. 1/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53300 | 15A0689 | Requesting permission to install medium voltage cable direct buried underground outside and indoors in cable tray, and to all the medium voltage cable to be installed outdoors from the building supply down the side of the building to underground protected by a PV mold schedule 40 non-metallic pole riser system to protect the cable of the entire length, the scheduled removal date for this temporary installation will be the 3rd quarter of 2017. | Approved | \$0.00 |
| Code: 328.12(1), (2), and (3) temporary installation. With stipulation that the medium voltage cable installed outside on the surface of the building is concrete, brick, or cement block encased for physical protection, with Bollards installed around the cable where it enters the earache. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53289 | 15A0690 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| This job is approved in lieu of submission number 14A0689. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/24/16 Swapped Drawings FP50-01, Revision 1; AB50-01, Revision 3 and SB80-01, Revision 2. 8/5/16 Swapped drawing AB50-01-Revision 5. | | | | |
| 53291 | 15A0692 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53279 | 15A0693 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53280 | 15A0694 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| a.k.a 66 Boerum Place-Brooklyn. This submittal voids out Cal. #52128, Submittal #13A0700. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 53281 | 15A0695 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53282 | 15A0696 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53283 | 15A0697 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53297 | 15A0698 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53286 | 15A0699 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 53287 | 15A0700 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/15/16 Swapped D-Revision 1 | | | | |
| 53288 | 15A0701 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 54988 | 15A0702 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Verify that the 10 point meter pan complies with 110.26(A)(3). 2) All new work to be bubbled. 3) Drawing not reviewed, triangles should not be used for new submittals. 12/7/15 Rejected 1) Items 2 and 3 not addressed. 2) More triangles. 6/24/16 Rejected No good for 7/13/16 carryover. 1) No fusing of fire pump emergency feeder and fire rating on emergency side. 2) Fire alarm ATS to be 3 pole. 3) New revised set of drawings to show revision 4. 4) Show frame ratings of emergency breakers with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 12/27/17 - 1) Comment 1 not addressed. Provide 2 HR FR for FP emergency feeder. 2) Comment 4 not addressed. Show frame rating. 1/19/18 - Job Finalized</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/22/18 - swap dwg # 2 Rev 5, Dwg 1 Rev 6</p> | | | | |
| 53295 | 15A0703 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/20/2020 Swap drawings # 1 & 2 Rev 2</p> <p>Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |
| 53453 | 15A0705 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Gen 1 and 2 are mislabeled. 2) Gens and switchboard to indicate optional standby. 3) Indicate GFI on GEN CB and switchboard CB. 1/22/16.. Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/7/16 Swapped Drawing 1 of 3-Revision 2.</p> | | | | |
| 53301 | 15A0706 | Requesting permission due to space limitations and vandalism to allow fire rated elevator feeders to be installed as per Section 620.37© in the elevator shaftways for replacement elevators | Approved | \$0.00 |
| <p>Code: 620.37©. Addresses: 14-60, 14-64, 14-68, 14-72, 14-74, 14-76, 14-78 and 14-80 Beach Channel Drive; 15-30 and 15-40 Hassock Street, Queens. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |

ADVISORY BOARD CALENDAR

October 21, 2015

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| | 15A0708 | Requested approval for the electric service equipment proposed to be installed | Denied | \$650.00 |
| Drawing not in Advisory Board format existing switchboard not shown on 1 Line drawing. | | | | |
| | 15A0711 | Requested approval for the electric service equipment proposed to be installed | Denied | \$650.00 |
| 1) All new work to be bubbled on 1Line, not clear on drawing. 2) Physicals of new end cable tap box not provided. 3) Verify that bus tap to panel E5 is existing review not complete. 5/26/16 1) Verify 5' clearance in front of service switches, equipment added in front of service switches not indicated as a change. 2) New 1000 KVA transformer and equipment it supplies not submitted. 3) Revised drawings don't show revision numbers. | | | | |
| | 15A0737 | Requested approval for the electric service equipment proposed to be installed | Rejected | \$650.00 |
| 1) Bond neutral to enclosure in fire pump service switch. 2) 3/0 conductors undersized for fire pump. 1/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/29/16 Rejected new work need to be submitted separately(1000 KVA and above. | | | | |