

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52587	14A0161	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/30/18 Swapped dwg A-Revision 1</p>				
52720	14A0293CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Carry over from July 16, 2014 meeting. 1) Add note to 1-Line stating whether 3 or 4 pole ATS are being used. 2) With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/6/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/28/17 Swapped Drawing A-Revision 8, drawing C-Revision 4 and drawing D-Revision 9. 11/30/17 - swap dwg A Rev 9, B Rev 3, C Rev 5, D Rev 10 Address change.</p>				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52960	14A0318CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from July 16, 2014 meeting. 1) Verify that transformer's can be mounted trapeze style and show clearances between them, show elevations drawing and documentation from an engineer that transformers can be stacked. 2) Item #4 not completely removed, FA, transformer secondary tap lengths not shown. 3 Drawing 1 of 2 not marked Revision 1. 4) Show lengths of transformer secondary conductors. 12/1/14 Item #1 not addressed. Rejected for 12/17/14 meeting. 4/3/15 1) Verify that transformers can be mounted trapeze style and show clearances between them. 4/13/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/30/19 Swap dwg #1 of 2 and 2G of 2-Revision 4. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/23/19 1) Fire alarm ATS shall be 4 pole with switched neutral to void the double bonding when use emergency side. 9/18/19 1) Fire alarm ATS shall be 4 pole with switched neutral to void the double bonding when use emergency side. 8/3/2021 Amended Plan # 2 of 2 Rev- 4 and # 2G of 2 Rev-5.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 1/18/2022 Amended Plan# 1 of 2 Rev 6 , 2G of 2 Rev 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
52585	14A0358CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Carry over from July 16, 2014 meeting. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52956	14A0379CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Carry over from July 16, 2014 meeting. 1) Provide cut sheet of outdoor bus duct and show how bus duct will be installed on the roof. 2) Provide ambient temperature adjustment calculations for bus duct by a P.E. 3) Vertical bus in distribution panels undersized. 4) Short circuit calculations not clear or complete. 5) Verify that ground fault sensor is connected to load side of main bonding jumper. 4/7/15 Job finalized. With the stipulation: Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52675	14A0401	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide inverter and transformer layout. 2) Provide required cuts for the inverter. 3) Sign/Seal the coordination study. 12/15/14 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	14A0407CO	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
<p>Carry over from September 10, 2014 meeting. 1) Verify that ATS switches are 4 pole that connect to emergency board. 2) Remove 2 neutral bonds to enclosure if separately derived system is being used, only one neutral bond to enclosure is allowed. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/29/15 Rejected 1) New revised drawing to be Revision 3s. 2) Verify main electrical service room containing generators, not on approved drawing; 3) How many stories does the building have; how will roll up generator feeder conductors be routed to the cmlock disconnect switch? 4) Roll up generator to comply with Section 700.6(G). 5) Changes to this drawing requires new filing.</p>				
	14A0422	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52868	14A0426	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Will transition boxes be used for MI cables. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/20/17 - swap dwg B rev 2</p>				
52588	14A0427	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 9/27/17 - swap dwg B rev 1 & dwg C rev 1</p>				
	14A0428	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed				
	14A0430	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52584	14A0451CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Carry over from September 10, 2014 meeting. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
52676	14A0455CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from August 13, 2014 meeting.. 1) Modifications to the lugs of the switchboard must be installed by a UL listed switchboard company or be field evaluated by a NRTL. This information shall be included in this submittal. 2) Size of equipment grounding conductor not shown. 3) Line and load are mixed together in the 4000 amp service switch. 4) Provide backfeed signage on service equipment. 12/15/14 With the stipulation that modifications to the bus bars in the switchboard are field evaluated by an NRTL. The field evaluation listing report is to be kept on site and be available for inspection.</p>				
52872	14A0462CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from August 13, 2014 meeting. 1) Length of tapped conductor not shown to existing 400 amp disconnect switch. 2) Verify that rear doors can open behind switchboard #4. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52586	14A0463CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from August 13, 2014 meeting.</p>				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52589	14A0468	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Gen set not listed. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/27/15 Swapped drawings. 1 and 2, Revision 1s.</p>				
52717	14A0470	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Tap conductor to 800 amp trans s and switch undersized-cure housing. 2) Verify conductors and wiring method to fire pump-town houses. With the stipulation: that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/6/15 With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	14A0474	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
53245	14A0485	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Tap conductor undersized and new 400 amp disconnect switch overfused. 9/14/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	14A0492CO	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
Carry over from September 10, 2014 meeting. 10/8/15 Rejected. 1) Verify that panels in the service room supplied from the generator do not feed life safety. 2) Provide new physicals indicating the changes.				
52869	14A0511	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) D drawing 150 amp ATS-SC1-FA fused at 250 amps note incorrect. 2) D drawing transformer secondary tap length not shown. 3) Verify if M1 cable tap boxes will be installed. With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/23/15 Job finalized. With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Co. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52590	14A0514	Requesting permission to leave as installed on a twin panelboard interior replacement a front clearance of 25 inches Table 110.26(A)(1) Condition 2 installation.	Approved	\$350.00
Code: Table 110.26(A)(1).				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0518	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
OR Lower main fuse to 3500 amps and show 2nd fuse type. 10/6/15 Rejected. Lower main fuse to 3500 amps and show 2nd fuse types. 9/6/16 Lower main fuse to 3500 amps and show 2nd fuse types. 6/28/17 - swap dwg with rev 3 (D-1408=25848-A)				
52726	14A0519	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify if neutral is present at existing s.s.(new work indicates neutral). 1/8/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52728	14A0520	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify that the service room is two hour fire rated. 2) Section bus 2nd section of MSB-1 undersized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> <p>3/15/2017 - swap dwg-C rev-2 5/1/2017 - the swap dwg same as Rev '0'</p>				
52591	14A0521	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52729	14A0522	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Short circuit study to be performed by a PE bearing signature and stamp, emergency does not coordinate. 1/8/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/23/2021</p> <p>With the stipulation: Fire Rated Enclosure’s must comply with the following: 1. A P.E. or R.A. must file a PW1 as an ALT 3. 2. A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/14/2017 - 1) F.P. disconnect switch is over fused at normal and emergency side. Section 695.4 (B) 4-27-16-V-ECH. 6/22/18 Swapped dwg #B-Revision 4. 1/6/2020 Swap #B-Revision 5; dwg C-Revision 1; dwg D-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant’s responsibility to clearly mark and note all changes to original approved DWGs. Amended Plan # B Rev- 8 and # C rev- 3.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant’s responsibility to clearly mark and note all changes to original approved DWGs. 9/30/2021 Amended plans# B Rev 9, C Rev 3 and D Rev 2 . Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant’s responsibility to clearly mark and note all changes to original approved DWGs</p>				
52732	14A0523	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify that service room is mechanically ventilated. 2) Provide listing documentation from an NRTL for the cogen unit. 3) Show sizes of equipment grounding conductors, conduit sizes. 4) Equipment grounding conductor to new 400 disconnect switch undersized. 5) Provide sequence of operation of cogens. 6) Provide cut sheet of new panelboard. 7) Drafting of trx must be consistent with note #6 about grounding. 1/9/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52740	14A0524	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify 2600 amp ATS, does it have rear doors. 2) Explain doorway behind 2600 ATS. 2/29/16 Swapped drawings A-Revision 3, with the stipulation that the equipment installed under the vent complies with Section 110.26(A)(3). B-Revision 3 and C-Revision 2. 5/4/2017 - swap dwg c rev 5</p>				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52873	14A0525	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Tapped conductor to SB-C panel undersized, verify size of tapped conductor. 2) Clarify panel size(400A) with fuse 600A and feeder conductor. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52725	14A0526	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Provide grounded conductor to fire pump service switch. 1/8/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52731	14A0527	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify that generator and feeders to 1600 amp disconnect switch are not included on the drawing. 2) Project address to be corrected on agenda 1/9/14 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	14A0530	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed				
52721	14A0531	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify that vita link mc cable will be installed in conduit, provide manufacturers' instructions for this product installed in conduit. 1/6/15 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0532	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Provide listing documentation from an NRTL for the new panelboard and transformer. 2) Full coordination study to be performed by a P.E. and stamped, study show lack of coordination. 3) Sequence of operation not provided. 4) Roll up generator to comply with 700,6(G) 5) Is generator a separately derived system? 6) Is 2000 amp switch with 1400 amp trip 3 or 4 pole type?				
	14A0534	Requesting permission to allow the elevator main feeders installed in the elevator shaftways not to be fire rated and allow the elevator main feeders to supply power to roof fans as originally installed when the buildings were built.	Denied	\$0.00
45 Addresses in Queens.				
52611	14A0535	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Tap conductors undersized (3 location). 2) Existing 2000 buses are not protected(tapped). 11/12/14 Job finalized.				
52722	14A0536	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Equipment grounding conductor undersized for new feeders. 1/6/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/6/15 Swapped drawing 1, Revision 2. 2/28/2017 - swapped dwg 1 revision 3				
	14A0538	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Show location of QCS-1 quick connect and reidentify-2 DSC's. 2 All new work to be bubbled. 3) Verify feeder sizes off of service switch #4. 4)Existing feeders to service switch 6 not shown. 5) Verify bus sizes on equipment cut and 1-Line and physical (4)6x1/4 or 1000A square inch?				
	14A0539	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0540	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
	14A0541	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
52592	14A0544	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
52593	14A0547	Requesting permission to leave as installed foreign systems installed above 30 laboratory panelboards	Approved	\$0.00
Code: 110.26(F)(1)(a) and 110.26(A)(3). Stipulation with drip pans.				
52594	14A0549	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
10/3/16 Verify that service room is 2 hour fire rated. 12/6/16 Swapped dwg 1 of 2-Sheet 3.				
	14A0550	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
	14A0551	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Show the new work only, remove unrelated items. 2) Show distribution panels as existing. 3) Show transformer and selector switch on 1 line. 4) Show grounding of the transformer.				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0553	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Generator bus to be sized at 800 square inch add gen set stip. 2) Show wiring methods and overcurrent protection sizes to existing equipment ATS T12. 3) Where is the generator room located and how will conductors connect to the cam locks? 4) Indicate wiring method from 6 sets to 7 sets to connect to existing conductors. 5) One FCO is allowed on TRX primary. 6) Provide coordination study and coordinate gen w/downstream 2000A cb. 7) Verify gen bonding size to steel(250,102). 8) Verify if GF1 alarm or trip is required for the gen cb, 9) With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
	14A0554	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
	14A0555	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed				
52606	14A0558	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				
53055	14A0559	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Provide reduced neutral calculations. 5/28/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52719	14A0560	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify 3' front clearance in front of F.A. panel. 1/6/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52867	14A0561	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Equipment grounding conductors undersized. 2) Coordination study not provided. 3) Verify that the back of new Board #1 can be open 90 degree swing. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/27/15 Rejected 1) Explain how you bond and ground a switchboard without grounded conductors. 2) Verify 32 conductors in 12"x12" trough. 6/5/15 Swapped drawings 1-Rev 3, 2-Rev.2 and 3-Rev 2. 3/16/16 Swapped Drawings 1, Revision 3; 2 and 3, Revision 2; 4 and 5, Revision 2 and 6 Revision, 1.				
52919	14A0562	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Equipment grounding conductors undersized. 2) Coordination study not provided. 3) Show clearance behind distribution board #1. 3/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/16/15 Swapped drawings 1, Revision 3. Drawings 2 and 3, Revision 2s.				
	14A0565	Requested approval for use in New York City of your LED Panel. Model/Series Numbers: Art no. DKI P595595.		\$200.00
52575	14A0571	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				
52576	14A0572	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52597	14A0573	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>7/22/19 Swap Dwg # ACS-D-11681-1 Rev 2 and Dwg # ACS-D-11681-2 Rev 2.. 5/29/2020 1) Clearly list all the changes from the approved plans and mark it with a revision triangle. 2) Provide notarized letter from the owner for the change of the contractor name , also provide all information (address, phone...etc.) of new contractor on the plan. 3) Provide coordination study/ curve signed and sealed by P.E. 8/6/2020 Amended Plans # 1&2 Rev- 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/10/2020 Client sent change of company name letter. Amended Plans # 1 of 2 & 2 of 2 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 1/25/2021 Amended dwgs# 1 Rev 3 and 2 Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 2/8/2021 Amended dwgs# 1 & 2 Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
52596	14A0574	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
52598	14A0575	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
52986	14A0576	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Verify who is installing the service entrance conductors. 1/8/15 Rejected Service entrance conductors undersized. 4/21/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52599	14A0577	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52600	14A0578	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/5/19 Swap dwgs 1 and 2-Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
	14A0579	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
52577	14A0580	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 7/21/15 Swapped drawing 1, Revision 1.				
52578	14A0581	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 9/10/15 Swapped Drawing 2-Revision 1.				
52579	14A0582	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				
52580	14A0583	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0584	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
	14A0586	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
	14A0587	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
	14A0588	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
52581	14A0589	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				
52582	14A0590	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 7/1/15 Swapped Drawing 1, Revision 1.				
	14A0591	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
52723	14A0592	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Verify that existing service is grounded and bonded. 1/6/15 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	14A0593	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed				
	14A0595	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
52601	14A0596	Requesting permission to use PVC as a wiring method in the NY Aquarium basement of each building containing severe corrosive influences that destroy metallic conduits where the buildings are located on the ocean front and the basements contain all mechanical and life support systems for the animals and the basements are not normally occupied.	Approved	\$0.00
Code: 300.6.				
	14A0597	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
	14A0598	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0599	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
	14A0604	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
	14A0605	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed				
	14A0607	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
52791	14A0613	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Bus to 3000 amp disconnect switch undersized. 2) Verify if the system is ungrounded. 3/4/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/17/15 Swapped drawings. E-6.0AB, E-1.0AB, E-6.1AB-Revision 2s.				
	14A0622	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				

ADVISORY BOARD CALENDAR

October 22, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0623	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed.				
52607	14A0624	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				