

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47171CO3	06A0257CO3	Broadway Electric, LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	6 West 48th Street New York NY	Approved	\$0.00
Carry over from July 12, 2006 meeting.						
47354CO	06A0407CO	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	The Plaza Hotel Fifth Avenue at Central Park South New York NY	Hold	\$0.00
Carry over from August 16, 2006 meeting. 1) Floor plan almost consistent with one-line. 2) Service room elevations drawings should be provided or photos. 3) Provide proof from a testing agency that the existing service equipment is safe to operate and reuse.						
47433	06A0519	GMA Electrical Corp. 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 355 Forest Avenue Staten Island NY	Hold	\$650.00
No drawings.						
47434	06A0520	GMA Electrical Corp. 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 117 East 167th Street New York NY	Approved	\$650.00
47435	06A0487	BLZ Electric, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	302 Second Street Brooklyn NY	Approved	\$650.00
Show wiring method from service end box to service switchboard. Job finalized 12/19/06.						

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47436	06A0488	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Kingswood Office & Retail 1630 East 15th Street Brooklyn NY	Approved	\$650.00
1) Increase feeder size to fire pump and fire alarm loads. 2) No coordination 4000 - 3000A fuse. 3) In Switchboard 'B' switches drawn backwards. 4) Provide 2nd means of egress. 5) Justify use of 1600A BPS for 750 KVA XFMR primary. Job finalized 12/18/06.						
47437	06A0511	Another NYCER Electric Corp. 652 Sackett Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	Capstone Turbine 10203 Avenue D Brooklyn NY	Hold	\$650.00
1) Provide catalog info on Capstone generators, shunt trip switch and transfer switches. 2) Indicate status of status of util/gen/Capstone under all operating modes. 3) Show all feeders including N & G. 4) Indicate available service current. 5) Indicate when "future" is to be installed.						
47438	06A0517	Allstate Electric Corp. 481 Eighth Avenue, Suite 920 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	150 Fifth Avenue New York NY	Approved	\$650.00
47439	06A0490	Knight Electrical Services Corp. 111 Eighth Avenue New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Citigroup 333 West 34th Street New York NY	Approved	\$650.00
47440	06A0492	Genegy Electric Service Co., LLC 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	505 Park Avenue New York NY	Approved	\$650.00
No coordination 1200-600A, 400A (fuse type). Job finalized 3/22/07.						

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47441	06A0505	L.T.C. Electric, Inc. 47-10 104th Street Corona NY 11368	Requested approval for the electric service equipment proposed to be installed	Waterside Restaurant 20 Waterside Plaza New York NY	Approved	\$650.00
47442	06A0509	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The Schermerhorn House 160 Schermerhorn Street Brooklyn NY	Ok, but	\$650.00
1) Show bonded neutral in FCO. 2) Provide site plan showing service manhole. Indicate jurisdiction Con-Ed/owner. Service conductors from manhole undersized if owners cables.						
47443	06A0516	AL-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Macy's West 38 Fulton St. a.k.a 177 Livingston St Brooklyn NY	Approved	\$650.00
1) Feeder to ATS 21 and panel 'EDP' undersized. 2) Emergency feeds to like safety loads must be ahead of generator main circuit breaker. 3) Indicate ["Life-Line" RHH] for fire pump feeder. Job finalized 12/29/06						
47444	06A0515	J.H. Electric of New York, Inc. 59-01 Grand Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	American Museum of Natural History 200 Central Park West New York NY	Approved	\$650.00
Egress doors should swing out. Job finalized 12/12/06.						
47445	06A0498	Pappas & Fodera Electric 15 Ingraham Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	80 Fifth Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47446	06A0497	Platinum Electrical Contracting Inc. 360 Industrial Loop Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Columbia University-Haven Twr 100 Haven Avenue New York NY	Approved	\$650.00
New fuse (2500A) to large for existing feeder. Job finalized 12/19/06.						
47447	06A0495	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	156 Beach 9th Avenue Far Rockaway NY	Approved	\$650.00
47448	06A0500	Star Electric 494 Greenwich Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Gateway Plaza 395 South End Avenue @ Plaza 600 New York NY	Denied	\$650.00
The submitted drawings do not comply with Sections 225.31 and 225.32 of the 2002 NEC..						
47449	06A0499	James F. Volpe Electl Contracting Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Verizon 221 East 37th Street New York NY	Approved	\$650.00
47450	06A0502	A.P.E. Electric Inc. of NY & NJ 6581 Amboy Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	515 East 72nd Street New York NY	Aprproved	\$650.00

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47451	06A0464	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	260 Beach 81st Street Far Rockaway NY	Hold	\$650.00
1) Jockey pump feed must be same as fire pump. 2) Drawing illegible-font size too small on service switches. 3) Bonding and configuration of neutral for service switches incorrect 4) Show available short circuit current at meter banks and short circuit rating of equipment. 5) Provide submittals on service switches.						
47452	06A0477	Innovative Electric of New York, Inc. 2056 Cross Bronx Expressway Bronx NY 10472	Requested approval for the electric service equipment proposed to be installed	Propect Avenue Apartments 890 Prospect Avenue Bronx NY	Approved	\$650.00
47453	06A0476	RNH Electric Company, Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	James Monroe H.S. 1300 Boynton Avenue Bronx NY	Approved	\$650.00
47454	06A0475	Cerrito Electric of New York, Inc. 85-45 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	164 Kent Avenue Brooklyn NY	Approved	\$650.00
47455	06A0474	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	240 Park Avenue South New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47456	06A0473	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	200 West End Avenue New York NY	Approved	\$650.00
47457	06A0472	Gessin Electrical Contractors, Inc. 791 East 139th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	67 Wall Street New York NY	Approved	\$650.00
Provide second means of egress. Job finalized 11/15/06.						
47458	06A0471	Jashar Engineering, PC 118 East 28th Street New York NY	Requested approval for the electric service equipment proposed to be installed	2 Prince Street Brooklyn NY	Approved	\$650.00
47459	06A0470	Prolight Electric 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	200 Park Avenue New York NY	Approved	\$650.00
47460	06A0468	Avalon Electric Corp. 3632 Kingsbridge Avenue Bronx NY 10463	Requested approval for the electric service equipment proposed to be installed	Apartment Building 55 East End Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47461	06A0469	Woodland Electrical Corp. 4601 White Plains Road Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	301 East 64th Street New York NY	Approved	\$650.00
47462	06A0467	High-Tech Electrical Services Corp. 36-33 23rd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Convenant House 460 West 41st Street New York NY	Approved	\$650.00
47463	06A0486	L.K. Comstock & Company, Inc. 5 Penn Plaza, 12th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	New York Life Insurance Co. 51 Madison Avenue New York NY	Approved	\$650.00
47464	06A0506	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Court Square Condominiums 45-31 Court Square Long Island City NY	Denied	\$650.00
<p>1) The amount of sets and sizes of service entrance conductors were not provided. 2) The feeders to the fire pump were not fire rated. 3) The full load amperage of the fire pump was not provided. 4) The bus sizes of the switchgear was not provided. 5) The fuse types were not provided, no coordination. 6) AIC was not provided. 7) The tap details off of the 2000 service switch 2-2 were not provided.</p>						
47465	06A0507	AK Electrical Contracting Inc. 512 68th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	560 Park Avenue New York NY	Hold	\$650.00
<p>The 1st four feet of bus off load side of 5000 amp service switch is undersized.</p>						

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47466	06A0503	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	38 East 57th Street New York NY	Approved	\$650.00
47467	06A0466	Compsec Electric Corporation 39-12 Crescent Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	133 Water Street Brooklyn NY	Approved	\$650.00
1) Manufacturer's cut sheets for distribution panel not provided for HDP1 and 2. 2) Tap of a tap not permitted. 3) Conductors are undersized feeding 9th and 10th floors. Job finalized 12/12/06.						
47468	06A0465	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	25 Fifth Avenue New York NY	Hold	\$650.00
1) Board can't determine new from old work, review taps. 2) Add 2nd door to service room.						
47469	06A0489	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	New York Stock Exchange New York NY	Hold	\$650.00
1) Explain feeder and fusing to ATS's 2,5,6, 11 and 13. 2) Feeders to transformer undersized. 3) Identify if 3 or 4 pole ATS's are being used. 4) Coordination between service switch and EDP-B2.						
47470	06A0491	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	TIAA-CREF 730 3rd Avenue, 6th Floor New York NY	Approved	\$650.00
Provide tap detail. Job finalized 12/19/06.						

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47471	06A0504	Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Home Depot 92-30 168th Street Jamaica NY	Approved	\$650.00
47472	06A0510	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Target @ The Junction 2201 Nostrand Avenue Brooklyn NY	Hold	\$650.00
1) Emergency side fire alarm switch to be on line side of generator and identified. 2) 480 volt Con-Ed ventilation switch to be rated at 100 amps. 3) Bus undersized in triangle equities detail box. 4) Provide us sizes in M 5-2. 5) Fire pump service switch undersized. 6) Provide ground fault indicator on 1000 amp feeder.						
47473	06A0514	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Midwood High School 2886 Bedford Avenue Brooklyn NY	Approved	\$650.00
Normal and emergency on ATS's reversed. Job finalized 12/12/06.						
47474	06A0513	Up Town Electric, Inc. 128-20 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Tuoro College 230 West 125th Street New York NY	Approved	\$650.00
1) Service room doors to open out. 2) Neutrals in disconnect switches 8 and 9 bonded after service switch. 3) Tap detail on load side of 1000A service switch not provided. 4) Feeder to disconnect switch #8 is undersized. 5) Provide tap detail. 6) Disconnect link not provided in service switch. Job finalized 12/12/06.						
47475	06A0493	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	IS/HS 362X 921 East 228th Street Bronx NY	Ok, but	\$650.00
1) Fire alarm switch to be rated 100 amp. 2) Correct notes on voltage. 3) Ground fault not provided. 4) Provide info on ATS's 3 or 4 pole.						

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47476	06A0494	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	Parsons New School For Design 2 W.13th St.,a.k.a.66-68-70 5th Ave. New York NY	Approved	\$650.00
47477	06A0484	Queens Electrical Contractors, Inc. 34-05 34th Street Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	37-01 31st St.,a.k.a. 31-02 37th Ave. Long Island City NY	Approved	\$650.00
47478	06A0518	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	59 Maiden Lane New York NY	Approved	\$650.00
1) Change 4 pole ATS to 3 pole. 2) Provide fused disconnect switch at load side of roll-up generator cable connector box.. Job finalized 12/12/06.						
47479	06A0485	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Taino Plaza 488 East 164th Street Bronx NY	Approved	\$650.00
47480	06A0483	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	204 West 55th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47481	06A0482	Dynamic Electric Service Inc. 14-17 110th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	1021 Park Avenue New York NY	Approved	\$650.00
47482	06A0481	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	111 E. 58th St., a.k.a. 110 E. 59th St. New York NY	Approved	\$650.00
47483	06A0480	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	941 Hoe Avenue Bronx NY	Approved	\$650.00
47484	06A0479	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	950 Wchst'r Ave. a.k.a. 967 Kelly St. Bronx NY	Approved	\$650.00
47485	06A0478	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	One Madison Avenue New York NY	Ok, but	\$650.00
1) Relocate service room door. 2) If ATS is new it should be in a fire rated room.						

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47486	06A0501	Judd Electric Inc. 41-41 38th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	67 Wall Street New York NY	Approved	\$650.00
47487	06A0512	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Time and Life Building 1271 Sixth Avenue New York NY	Approved	\$650.00
47488	06A0463	Elco Electrical Contracting Corp. 35-43 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Furman Residence 1060 Fifth Avenue, Apt. 11A New York NY	Approved	\$650.00
47489	06A0462	Hi-Rite Electric Corp. 1335 61st Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	199 Lafayette Street New York NY	Hold	\$650.00
47490	06A0496	Walter T. Gorman, P.E., P.C. 115-14 Beach Channel Drive Rockaway NY 11694	Requested approval for the electric service equipment proposed to be installed	Motiva Enterprises-Bklyn Term. 25 Paidge Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47491	06A0521	The Sound Beyond Electrical Corp. 134 West 29th Street-11th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	DOS S.I. Transfer Station 310 West Service Road Staten Island NY	Approved	\$650.00
47492	"	Walter T. Gorman, P.E., P.C. 115-14 Beach Channel Drive Rockaway NY 11694	Requesting permission to terminate a transformers secondary conductors to switchboard bus that feeds tow switches.	Motiva Enterprises 25 Paidge Avenue Brooklyn NY	Approved	\$0.00
47493	""	Cabin Electric Inc. 77 Commerce Street Brooklyn NY 11231	Requesting permission on drawing #47378 to leave the doors to the service room as submitted with 2 doors on one side of the service room, due to the building structure.	51 North 8th Street Brooklyn NY	Approved	\$0.00
With the stipulation that the doors in the service room open outwards and are equipped panic hardware.						
47494	""""	TEC Electric Co. 1751 Crosby Avenue Bronx NY 10461	Requesting permission to leave as installed a service switch mounted on the outside of a kiosk due to lack of space inside	Costco Gas Station 2975 Richmond Avenue Staten Island NY	Approved	\$0.00
47495	"""""	DiStefano & Marino's United Electric Co., Inc. 58-15 Fresh Pond Rd. Maspeth NY 11378	Requesting permission due to lack of space inside the 2 family building to install a 3rd service switch on the outside that will provide power to a detached garage.	53-14 74th Street Queens NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47496	*****	Contact Electric Corp. 1064 60th Street Brooklyn NY 11219	Requesting permission due to lack of space inside 4 two family buildings to install a 3rd service switch outdoors that will provide power for site lighting.	14, 58, 160 and 204 Dartmouth Loop Staten Island NY	Approved	\$350.00
47497	*****	Contact Electric Corp. 1064 60th Street Brooklyn NY 11219	Requesting permission due to a hardship to correct to leave as installed in 36 two family buildings a 20 amp small appliance branch circuit that serves one large room that contains a living room, dining room and one outlet in the foyer.	Dartmouth Loop Staten Island NY	Approved	\$350.00
47498	*****	WCK Electric Corp. 61 Utica Avenue Brooklyn NY 11213	Requesting permission to leave as installed AC cable without an insulated equipment grounding conductor as a wiring method inside a place of assembly.	724 Nostrand Avenue Brooklyn NY	Approved	\$350.00
With the stipulation that ground fault circuit breakers are installed on all of the branch circuits.						
47499	*****	A. Ceriello Electric, Inc. 15 Carroll Street Brooklyn NY 11231	Requesting permission to leave as installed AC cable without an insulated equipment grounding conductor as a wiring method inside a place of assembly	213-215 North 8th Street Brooklyn NY	Denied	\$0.00
47500	*****	TSF Engineering, PC 200 Park Avenue South, Suite 1020 New York NY 10003	Requesting permission to install a central battery back up system to provide emergency power in a ambulatory surgery facility as per 517.45B.	860 Fifth Avenue New York NY	Approved	\$0.00
With the stipulation that the installation corresponds with NFPA 99 4.4.1.2						

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47501	*****	M-E Engineers 417 Fifth Avenue, 5th Floor New York NY 10016	Requesting permission to install an automatic tap changing transformer to correct voltage drop on feeders that will run approximately 1600 feet.	Central Park Police @ 86th Street New York NY	Approved	\$0.00
47502	*****	Electric Light & Power, Inc. 463 Wild Avenue Staten Island NY 10314	Requesting permission due to limited space to utilize Section 695.(C) (2) of New York City's 2005 amendments to size the fire pump service switch that feeds the DC rectifier.	201 West 55th Street New York NY	Approved	\$0.00
47503	*****	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requesting permission to route replacement fire pump feeders through a common crown box mounted above the switchboard on a job that was installed under the old New York City Electrical Code.	350 West 42nd Street New York NY	Approved	\$0.00
47504	***** "	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requesting permission to install 480 volt panels that will face each other with a front clearance less than 4 feet	200 Chambers Street New York NY	Approved	\$0.00
47505	***** ****	Sambar Electric Corp. 314 Nelson Avenue Staten Island NY 10308	Requesting permission not to group together service switches on a one family building where the second service will be used to power condominium site lighting.	125 Clark Lane Staten Island NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47506	06A0522	Tyco Thermal Controls 11 Exeter Pass Colts Neck NJ 07722	Requested approval for use in New York City of your Raychem Brand S600 M.C. Power Cable		Approved	\$200.00
47507	***** *****	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requesting permission to install a generator to feed building temporarily.	Verizon 240 East 38th Street New York NY	Approved	\$0.00