



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 108-07-E

Manufacturer: Johnson Gas Appliance Co., 520 East Avenue NW.
Cedar Rapids, Iowa 52405

Trade Name(s): Piazzetta Powered by Johnson Gas

Product: Direct-vent gas fireplace

Pertinent Code Section(s): 27-800, 27-825, 27-886 RS14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z21.88)

Laboratory: Intertek

Test Report(s): 3095008 dated November 30, 2006.

Description: Direct-vent gas fireplace.

Model No.	Gas Input (Btu/hr)
JP2720	27,000
	Low Fire: 6,600

Terms and Conditions: The above-described direct-vent gas fireplace is accepted for supplemental heating and decorative purposes under the following conditions:

1. Installation shall be in accordance with manufacturer-supplied instructions.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.

3. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 11/29/07

Examined By Sayan M. Ghosh