

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 110-04-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, A Division of Pittway, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name – Notifier.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – Reference Standard 17-3, RS 4-6 (886-89-BCR).

Tests - UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S3705, Project 99NK6063, Vol. 7, Section 1, issued May 5, 1999, revised November 23, 2003.

Description – Fire Alarm Equipment.

Model No.	Description
FTM-1	Fire Phone Module

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated April 16, 2004, F.P. Index No. 0403063.

Recommendation - That the above equipment be accepted provided that all uses, configurations, arrangements and function, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard 17-3. The above referenced product shall be used only with MEA approved fire alarm control panels and accessories. The compatibility must be specified or determined by a UL test report or the Engineer of Record.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

November 22, 2004

Examined by

Donald J. [Signature]