

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47883CO	07A0257CO	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	148 Lafayette Street New York NY	Hold	\$0.00
Carry over from May 23, 2007 meeting. 1) Service room doors to open out with panic hardware. 2) Show details of end box. 3) Show 2nd fusing of 1200 amp service switch. 4) Explain purpose of fire pump ATS if no generator.						
48474CO	08A0060CO	B & G Electrical Contractors of New York 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Triangle Core & Shell/Triangle 2201 Nostrand Avenue Brooklyn NY	Approved	\$0.00
Carry over from February 13, 2008 meeting.						
49031CO	08A0500CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Vanderbilt Hall 40 Washington Square South New York NY	Approved	\$0.00
Carry over October 15, 2008 meeting Remove bonding jumpers form F.A. FCO and F.P> siwtch fed room substation. Job finalized 11/28/08.						
49032CO	08A0501CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Tisch Hall 40 West 4th Street New York NY	Approved	\$0.00
Carry over from October 15, 2008 meeting.						
49033CO	08A0502CO	Hugh O Kane Electric Company, Inc. 90 White Steet New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Furman Hall 245 Sullivan Street New York NY	Approved	\$0.00
Carry over from October 15, 2008 meeting.						

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49034CO	08A0503CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Kimmel Hall 60 Washington Square South New York NY	Approved	\$0.00
Carry over October 15, 2008 meeting. Relocate disconnect link in substation ahead of switches. Job finalized 11/28/08.						
49066CO	08A0535CO	Brandl Electric Inc. 1926 Mott Avenue Far Rockaway NY 11191	Requested approval for the electric service equipment proposed to be installed	4435 Victory Boulevard Staten Island NY	Denied	\$0.00
Carry over from October 15, 2008 meeting. 1) Manufacturers cut sheets of equipment not provided. 2) Coordination study not provided. 3) Drawings not submitted in Advisory Board format.						
49083	08A0538	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	1845-1849 Sedgwick Avenue Bronx NY	Approved	\$650.00
49084	08A0539	Integral Electrical Power & Control Corp. 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Southport, LLC 1150 South Avenue Staten Island NY	Approved	\$650.00
49085	08A0540	LTC Electrical Contracting LLC 47-10 104th Street Corona NY 11368	Requested approval for the electric service equipment proposed to be installed	Gateway II 2088 Lexington Avenue New York NY	Hold	\$650.00
1) Service room doors to open out with panic hardware. 2) Feeder from 4000A service switch undersized. 3) Feeder to "MB-HP" (1200A) undersized. 4) Fire pump tap must be in s.e.b. cabinet with separate Con-Ed mta. 5) Request special permission for lack of coordination.						

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49086	08A0541	JMC Electric Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	64-11 Beach Channel Drive Far Rockaway NY	Denied	\$650.00
1) The utility available short circuit current was not provided. 2) Documentation was not provided to verify that the new circuit breaker panel and devices are properly rated for the incoming AIC. 3) The Transector is not listed equipment.						
49087	08A0542	JMC Electric Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	1700 Bedford Avenue Brooklyn NY	Approved	\$650.00
49088	08A0543	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Lincoln Center 140 West 65th Street New York NY	Approved	\$650.00
49089	08A0544	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	444 Madison Avenue New York NY	Approved	\$650.00
49090	08A0545	Amcor Electrical Contractor 680 Sharrotts Road, Unit #1 Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Panera Bread 73-25 Woodhaven Boulevard Ridgewood NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49091	08A0546	Five Star Electric Corp 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	The Gansevoort Park Hotel 420 Park Avenue South New York NY	Approved	\$650.00
49092	08A0547	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	200 West End Avenue New York NY	Approved	\$650.00
49093	08A0548	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	Key Food Supermarket 626 Sutter Avenue Brooklyn NY	Approved	\$650.00
49094	08A0549	Selectric Electrical Contracting Co., Inc. 78-14 46th Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	NY School Construction Authority 120 West 231st Street New York NY	Approved	\$650.00
49095	08A0550	Horsepower Electric 4109 Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	2182 3rd Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49096	08A0551	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Mount Moriah AME Church 116-20 Francis Lewis Blvd. Cambria Heights NY	Approved	\$650.00
49097	08A0552	Quest Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	2 Northside Piers 164 Kent Ave. Tower 2 Williamsburg NY	Approved	\$650.00
1) Segregate service pull box into 3 sections, 10 set each. 2) Provide short circuit rating of panel 'HP-GYM' and short circuit calculations. 3) Provide details of property line box including connect. Job finalized 11/28/08.						
49098	08A0553	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	IS 259 7301 Fort Hamilton Parkway Brooklyn NY	Approved	\$650.00
49099	08A0554	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The New Family Intake Center 151 East 151st Street Bronx NY	Hold	\$650.00
Provide details of generator distribution breaker enclosure.						
49100	08A0555	Katco Electric, Inc. 44-15 Barnett Avenue Long Island City NY 11104	Requested approval for the electric service equipment proposed to be installed	A & E Television 235 East 45th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49101	08A0556	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	New York Law School 185 West Broadway New York NY	Approved	\$650.00
1) SS-A: Fire pump switch must be remote from switchboard tap at P.O.E. 2) Life safety ATS's cannot be locted in service room. 3) Provide f.a. fed per code norm emergency. Job finalized March 25, 2009.						
49102	08A0557	BGA Engineering, LLC 99 Bauer Drive Oakland NJ 07436	Requested approval for the electric service equipment proposed to be installed	4 Irving Place New York NY	Hold	\$650.00
1) Provide justification of MI cable sizing and termination in equipment . 2) Confirm primary transformer switches are sized correctly for transformer in rush. 3) ATS 2-5 should be 1200A based on generator mcb. 4) Provide secondary overcurrent protection for transformer's or comply with tap rules. 5) Feeds to F.A. and F.P> must be from generator bus and line side of utility service switch.						
49103	08A0558	Murray Diamond, Licensed Electrician 35-05 169th Street Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	Highland Care Center 91-31 175th Street Jamaica NY	Hold	\$650.00
1) Clarify voltage fo generators and KVA . 2) Verify selectivity between 2000 and fuse and circuit breakers. 3) Clarify # of sets of conductors feeding elevator ATS. 4) Clarify use of #10 neutral to fire pump ATS. 5) Verify if 3 or 4 pile ATS are used. 6) Show available short circuit current at breaker. 7) Provide field evaluation of existing verticle buss or nigh pot. test.						
49104	08A0559	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	383 Madison Avenue New York NY	Approved	\$650.00
1) Correct note on 3/0 panelboard. No neutral. 2) Include operation of interlocks on ASCO drawing. 11/28/08.						
49105	08A0560	Corporate Electric Group, Inc. 14-34 119th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Verizon Central Office 2101 West 12th Street Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49106	08A0561	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	NYU Langone Med. Ctr 333 East 38th Street New York NY	Ok, but	\$650.00
1) Bond neutral of transformer to buildings steel. 2) 1600 amp service entrance conductors fused at 2000 amps, 3) 600 MCM require l/O equipment grounding conductor. 4) Change 3 pole ATS to 4 pole.						
49107	08A0562	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Red Hook Water Pollution Plant 63 Flushing Avenue Brooklyn NY	Hold	\$650.00
1) Provide sequence of operation of inter-locking scheme. 2) Provide overcurrent protective device study.						
49108	08A0563	Indy Electric Corp. 125-05 Liberty Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	88-34 161st Street Jamaica NY	Approved	\$650.00
1) Change 400 amp fuses SS4 panel to coordinate. 2) Provide buss size in end box. 3) Fire pump branch circuit undersized. 4) Show length of the conductors to 600 amp switches. Job finalized 2/22/10.						
49109	08A0564	R.M.T. Electric Corp. 238-19 Braddock Avenue Bellerose NY 11426	Requested approval for the electric service equipment proposed to be installed	109-15 14th Avenue College Point NY	Approved	\$650.00
49110	08A0565	Mutual Electric 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hollister 600 Broadway New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49111	08A0566	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	UNFCU-Transfer Switch 24-01 44th Road Long Island City NY	Approved	\$650.00
49112	08A0567	Kleinknecht Electric Co., Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Telx Group 60 Hudson Street New York NY	Approved	\$650.00
49113	08A0568	Levis Electrical Contractors Corp. 28-17 31st Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	35-37 36th Street Astoria NY	Approved	\$650.00
49114	08A0569	Wank Adams Slavin Associates LLP 740 Broadway New York NY 10003	Requested approval for the electric service equipment proposed to be installed	Fordham Univ.-Lincoln Ctr. West 60th Street and Columbus Avenue New York NY	Approved	\$650.00
49115	08A0570	Sage Electrical Contracting, Inc. 651 Willowbrook Rd., Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Plaza West Associates 636 11th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49116	08A0571	Lakhani and Jordan Engineers, PC 50 East 42nd Street, Suite 1001 New York NY 10017	Requested approval for the electric service equipment proposed to be installed	350 Fifth Avenue New York NY	Approved	\$650.00
49117	08A0572	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	470 West 24th Street New York NY	Approved	\$650.00
49118	08A0573	A & R Electrical Maintenance, Inc. 85-44 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	133 Pitt Street New York NY	Approved	\$650.00
49119	08A0574	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	44-24 Vernon Blvd. Long Island City NY	Approved	\$650.00
Verify size of conductors from ATS to fire pumps. Job finalized 2/18/09.						
49120	08A0575	Power Tech Electric Corp. 245 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	270 West 124th Street New York NY	Approved	\$650.00
#3 tap conductors undersized. Job finalized 12/1/08.						

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49121	08A0576	Mar-Kam Electrical Contracting Inc. 153 32nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	32-00 Skillman Avenue Long Island City NY	Approved	\$650.00
Service bus undersized. Job finalized 12/12/08.						
49122	08A0577	A.L. Electrical Corp. 307 7th Avenue, Suite 404 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Visy Paper Plant 4435 Victory Blvd. Staten Island NY	Denied	\$650.00
) Manufacturers cut sheets of equipment not provided. 2) Coordination study not provided. 3) Drawings not submitted in Advisory Board format.						
49123	08A0578	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	456 West 19th Street New York NY	Approved	\$650.00
1) Show conductor size on load side of 1200 amp service switch. 2) Show length of taps off of 400 amp service switch and show short circuit calculations. Job finalized 9/21/10.						
49124	08A0579	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	41 Cooper Square New York NY	Approved	\$650.00
1) Explain why neutral is bonded in emergency board. 2) Service room doors to open out. Job finalized 3/25/09.						
49125	08A0580	Queens Hospital Center 82-62 164th Street Jamaica NY 11432	Requested approval for the electric service equipment proposed to be installed	Queens Hospital Center 82-70 164th Street Jamaica NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49126	08A0581	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	J.P. Morgan Chase 383 Madison Avenue New York NY	Approved	\$650.00
49127		Kleinknecht Electric Company, Inc. 252 West 37th Street New York NY 10018	Requesting permission to leave in place an existing 480 volt 2000 amp disconnect switch containing 601 amp fuses without ground fault protection in it or the existing service switch that feeds it.	Telx Group 60 Hudson Street New York NY	Approved	\$0.00
49128		Lakhani & Jordan Engineers, P.C. 50 East 42nd Street, Suite 1001 New York NY 10017	Requesting permission to replace existing motor disconnect switches one for one where the front clearance is less than 36 inches by insulating the chiller unit across from the switches or provide a motor lockout as per Section 430.102(B) exception.	AIG-Cooling Tower Replace 70 Pine Street New York NY	Approved	\$0.00
With the stipulation that the installation complies with Section 430.102(B).						
49129		Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requesting permission to leave as installed on a 1000 KVA service, a 2'6" front clearance in front of the Con-ED box and C.T. cabinet, and a 3'7" clearance in front of the 2000 and 800 amp service switch cabinet.	Adam Houses 745 East 152nd Street, Bldg. #3 Bronx NY	Approved	\$350.00
With the stipulation that the panel is relocated and two revised room layout drawings are submitted.						
49130		DiFazio Electric NY, Inc. 42-24 Douglaston Parkway Douglaston NY 11363	Requesting permission due to lack of space inside of the existing service room, to leave as installed service equipment in the adjacent room where signage will be provided at each room indicating where the other service is located.	1 East 14th Street New York NY	Approved	\$350.00

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49131		Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requesting permission due to lack of space inside of the existing service room, to leave as installed service equipment in the adjacent room where signage will be provided at each room indicating where the other service is located.	50 Orchard Street New York NY	Approved	\$350.00
49132		Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requesting permission to leave as installed a seventh service switch that powers a fire pump	180 Hester Street New York NY	Approved	\$350.00
49133		DVL Consulting Engineers Inc. 137 Fifth Avenue New York NY 10010	Requesting permission to install underground concrete encased service lateral conductors in rigid non-metallic conduits.	New PS 160 rt Hamilton Parkway and 11th Aven Brooklyn NY	Approved	\$0.00
With the stipulation that approval is granted from Con-Ed						
49134		Lerco Electric LLC 370 East 146th Street Bronx NY 10455	Requesting permission due to a hardship to replace to leave as installed in a place of assembly AC cable that does not contain an insulated grounding conductor.	El Valle Restaurant 2448 Jerome Avenue Bronx NY	Approved	\$0.00
49135		Department of Environmental Protection 59-17 Junction Boulevard Flushing NY 11373	Requesting permission due to hardship to replace, to leave as installed a 1600 amp main circuit breaker frame containing a 1200 amp circuit breaker where permanent signage will be affixed to the circuit breaker switchboard indicating maximum size breaker not to exceed 1200 amps in a building where the service is accessible to only qualified persons.	English Kills Phase 1 1106 Grand Street Brooklyn NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 12, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49136		KNC Electric Inc. 187-27 Linden Blvd. St. Albans NY 11412	Requesting permission to leave as installed a new 2 family building, that was wired without a separate meter and panel for the common area circuits.	1681 Castle Hill Avenue Bronx NY	Approved	\$350.00
Pending field inspection. Item void 11/18/08						
49137	Void	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requesting permission due to lack of space inside of the service room to allow 18 feet of service entrance conductors installed in auxiliary gutters that will refeed existing service switches on a job where a new C.T. is being installed.	25 West 54th Street New York NY	Denied	\$0.00
49138		Nivek Electrical Contracting, Inc. 301 East 119th Street New York NY 10035	Requesting permission to leave as installed outdoor service equipment fed by Con-Ed with a separate drop that supplies power to a cell site located on the roof of the building	101-09 103rd Avenue Queens NY	Approved	\$350.00
49139		Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requesting permission to leave as installed due to lack of space inside the building outdoor service equipment for FDNY communication system that will have a separate point of entry from Con-Ed and located behind locked gates.	FDNY 35 Empire Boulevard Brooklyn NY	Approved	\$350.00