

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
50906CO2		Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from May 2, 2012 meeting. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/21/19 Swap dwg #1 & 2 and 2 of 2-Revision 4.</p>				
55816	18A0221	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide both emergency conductor size and 50 LP too. 2) Provide normal side size of conductors for (ATS-H2, H2, H3, H1). 3) Provide emergency side size of conductors for (ATS-H2, H2, H3, H1). 4) Fix typo in HMSA-1 fuse size not matching in one line diagram, physical diagram and room layout. 5) Show physical diagram of RDB28 on one line diagram, 6) Please provide license #. 7) 2000A main CB gen conductor not shown feeding "HDPATS". 8) Conductor feeding HMSA-2 size is missing. 9) FA ssw 9A GEC undersize. 10) Is the busway service rated, how long is the busway, is it service busway? A(368.119). 11) Ground bus in sea-hold switchboard undersized and SEB-RES too. 1/23/19 1) Provide coordination between 1600A KRPC and downstream 1200A KRPC signed and sealed by P.E. 3/25/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55563	18A0444CO2	Requesting special permission to keep the installed elevator power feeder in the existing hoistway.	Approved	\$0.00
<p>Carry over from July, 18, 2018 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
56073	18A0561	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/14/18-1) Comply with 760.41 (a)-F.A Tap to be before ND.L & FPT00. 2) Show fire alarm xfmr at floor plan. 3) Verify available S.C. current at point of entry. 4) Provide coordination study & short circuit study signed & sealed by P.E. 5) 1200a BREAKER NEEDS GROUND FAULT L signal LSI-Generator side. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/24/19 1) Fire pump OCPD-emergency side-is oversized. 2) Confirm to follow recommended setting within the coordination study. 8/29/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/5/2020 Swap Dwg #FP 1 of 1-Revision 1 and dwg AB 1 of 1-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/23/2020 Dwg # FP 1 of 1 Rev - 1 Dwg# AB 1 of 1 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 7/2/2020</p>				
55559	18A0619	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55697	18A0631	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/14/18- 1) New & Existing busbars connected to 4000A S.SW are undersized-408.60 (E)(3). 2) Provide coordination between 4000A Aby & downstream new fuses 250 A4j & 1600A A4BQ. 3) Provide appropriate clearance to 1600A SW clear of all obstruction. 4) Electrical room to be included in asbestose abatement compliance doc. 5) Bonding on load side of 4000A fase unaccepted- Remove bonding at 1600A SW. 1/3/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/15/2021 Amended dwgs# O Rev 2 and P Rev 9. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/1/2021 Amended dwgs# O Rev 2 and P Rev 9 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/9/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55688	18A0634	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide a drip-in for all electric equipment. 2) Verify compliance with 110.26(F)-Verify if piping is not in dedicated space. 3) Verify if there is new electrical work, if all electric work is existing. 1/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/5/19 Swap Dwg # D-1809-30604-A Rev 2 and -B Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/1/2020 Swap dwg A-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55638	18A0636	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>OR 1) Provided Asbestos document doesn't include area of scope of work. 1/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55696	18A0641	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Jockey pump cond is undersized and provide tap length. 2) Provide 12" separation between FP service switch and ss#4. 2/1/2019 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/19/2020 Amended Plan # A081803 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/23/2020 Amended Plan # A081803 Rev-4 & A081804 Rev-2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
	18A0677	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>11/14/18- 1) ACP-5 control no. doc is not provided. 2) Provide bonding to SS#5. 3) Provide verticle bus size in "EM-DP" panel. 4) Fire Pump OCPD-Emergency side- is overfused. 5) Verify the amperage rating of fire pump Ats. 6) Provide 5' clearance to existing SS# 2,3 & 4 and provide 7' clearance between F.P. SSW and SS#5. 7) Cond. Feeds Ats #- normal side- is undersized- fix typo. 8) Clarify what is BFP. 9) Provide AIC rating & available S.C cuurent at ATS-L. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
55711	18A0680	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/14/18- 1) Show grounding of chain link fence & manhole cover. 2) Confirm proper egress from fences area land around the transformer and show termination locations at the xfmr. 3) Provide short circuit study signed & sealed for the high inrush& the xfmr by P.E. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/17/19 1) Verify bonding and grounding to existing and new service switches. 2) Verify generators is SDS or not SDS. 3) Confirm that transform OCPD is suitable for the transformer inrush current. 2/4/19 Job finalized.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55863	18A0683	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide JP tap length. 2) #4 AWG feeding both FP and JP undersized on 250 KW gen side. 3) Provide Asbestos Abatement compliance documents. 4) Fix typo on all ATS E instead of N. 5) Ground bus on MSB-3 undersized (Supposed to be 12.5% incoming). 1/10/19 1) Comply 2i5h 760.41(A)(1)-F.A. Tap to be before N.D.L. 2) Item #1 is not addressed Jockey Pump cond is undersized and provide tap cond length in both services 3) Provide coordination between 1600A breaker and downstream fuses in "EssB-2". 4) Comply with 230.95 and 215.10 5) Verify note regarding front accessible only sects in floor plan. 3/5/19 1) Conductor of 2HP jockey pump is still undersized. 2) Provide GFP to 1600A generator C.B. 3) If switch boards are front accessible only remove doors from the rear of switchboards. 4/25/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/17/2020 Amended Dwg# 2 of 3 Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/29/2021 Amended Plan # AB 1 of 3 Rev-4, 2 of 3 Rev-5 and 3 of 3 Rev- 2.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	18A0692	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Comply with 695.4(B)(3) and (4)-provide separate exclusive to F.P. service switch.</p>				
	18A0694	Requesting a SP for a Second Device connection to 1000kVA equipment.	Denied	\$0.00
<p>Provide a letter, signed and sealed by the elevator servicing company that the proposed conduit location will not interfere with the elevator operation and/or maintenance. 5/22/19 This work shall be filed with the NYC Electrical Advisory Board for review and approval.</p>				
	18A0699	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Provide detailed sequence of operation showing how the system operation when one of G1 & G2 fails and explain how normally closed tie br work. 2) Provide 4' clearance to the rear of 5KV power distribution switchgear-110.34(A). 3) Provide cutsheet of 5KV power distribution switchgear showing NRTL listing. 4) Test cabinet shall meet the requirement of T110.34A when testing breaker. 5) Verify the termination of 5KV cables derated according to NYC code. 6) Door to open outward with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55634	18A0727	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
11/14/18-1) Provide asbestos abatement. 2) Provide details on adding 4th set of 500 MCM TO EXISTING 1200A S.SW- provide the detail of the termination. 12/20/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55564	18A0736	Requesting a special permission to use Section 330.30(B) of the 2014 NEC to support MC cable at intervals of 10ft. Inside of a shaft.	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0737	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Provide 3' clearance to rear of ss#2 or provide barrier if front accessible only and provide appropriate clearance to the back of ATS-1. 2) Verify that existing bonding will be removed from existing SWBD A& B. 3) Provide sequence of operation for load shedding. 4) Provide gen cut sheet showing wiring info. 5) Provide interior floor plan showing clearances to PBGE-1- show controls. 6) If voltage transformer are provided for control, show them on one line. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
55645	18A0739	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Panic bards on all doors are required. 2) Provide switch after transformer T-FA(G). 1/8/19 1) Verify # of sets feed switchboard SB2G-one line doesn't match floor plan. 2) Verify that 8 sets conds feed switchboard SB1G are Con-ED conductors. 1/8/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/24/2021 Amended Dwgs# 1 , 2 & 3 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55644	18A0740	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/14/18-1) Jockey pump cond is undersized. 2) Remove bonding from "FA-SW-E(F)", "FA-SW-E(G)". 3) Provide 2HR Fire rated cond. To fire pump-emergency side. 4) Verify compliance with 700.10 (E)(2) for fire alarm. 5) Provide panic bars to doors in service room 1F. 6) Show F.A.S.W in service room. 7) Provide AIC rating of fire pump controller. 8) Physical doesn't match one line-SB2F- section #4. 9) FP emergency 200A or 400 amp where connected to generator @ 400A cf br. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. 5/24/2021 Amended Dwg# 1, 2, 3 & 4 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/8/19 Job finalized This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
56180	18A0743	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) One line dwg is not per advisory board format-provide busbars sizes & details of switchboard swbd B, D & E & verify that existing service switch boards are bonded & grounded. 2) Verify compliance with 705.12 (D) (2) and provide sequence of operation. 7/30/2019 1) Confirm NRTL Listing to Xfmr after new modification - confirm that Xfmr Listing will not be voided. 2) Confirm that there are no changes to service room. 3) Provide location of current limiting protector and clarify what is SG board in the Generator room, show in one line. 5/28/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
55639	18A0748	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
11/14/18- 1) Provided Coordination study to be performed, signed & sealed by P.E. 2) Provide asbestos abatement compliance doc. 1/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55553	18A0749	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55873	18A0751	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) physical & one line diagram not matching in middle compartment of new DPH.3-N BOH-1. 2) Clarify number of sets per phase and/or neutral feeding new 'DPH-B-N-BOH-1'. 3) Verify the incoming service voltage. 4) Fix typo for fuse size in 'DPH-B-N-BOH-1' section #3.. 2/15/19 1) Comment 1, 2 and 4 not addressed,. 2) Conductor feeds new 'BPH--N-BOH-1" is undersized. 4/25/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55956	18A0752	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify that 2000kva xfmr secondary vertical is bonded & grounded only in one location and show vertical grounding to 225kva xfmr secondary. 2)Comply with 450.3-provide primary OCPD to 225 KVA xfmr. 3) Comply with 230.9t5-Provide "GFP" to SS#1. 4) Provide panic bar to doors in new fence. 5) Provide cut sheet of new GE 4000A unfused sw. and siemens 400A switch showing listing & AIC rating and provide available S.C. current. 6) Termination details of new 250 MCM-MV cable into exist pull box-3. 7)Show the fence grounding. 1/2/19 1) Item #1,3, 4 and 7 are not addressed and #5 is partially addressed. 2) 225 KVA transformer primary OCPD is overfused=T450.3(A). 2/12/19 1) Item #2 from revision date 1/2/19 is not addressed. 2) Item #6 from Revision 11/2/18 is not addressed-Provide termination details of new 250 MCM-MV cable into existing pull-box#2. 4/4/19 - 1. Provide detail on splicing cables on Box 2 & the tap after this point. 5/28/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/21/2021 Ameded Dwgs# A Rev 0, B Rev 5 and C Rev 11. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55558	18A0758	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55640	18A0759	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 1) Very if generator is new or existing to confirm that new work bubbled. 1/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55797	18A0762	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination between 1200A SKLA in "MDP" panel and downstream breakers, signed and sealed by P.E.-"MDP" panel should not be series rated. 2) "GEC" of fire pump is undersized-T250.66. 3) Verify-3' clearance in front of trans "MB-1" distribution section. 3/21/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/12/2020 Amended Plan # A..2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55802	18A0763	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination & short circuit study signed & sealed by P.E.- MDP should not be series rated. 2) GEC of fire pump is undersized- T250.66. 3) Fix designation of "UP-T1" & "UP-T2" in cut sheet. 3/26/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/12/2020 Amended dwg # A Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/18/2020 Amended Plan # A.3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55648	18A0764	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide vertical bus size in "HDB" section #2. 1/10/19 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/5/2021 Amended plan# AB Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/1/2021 Amended Plan# AB Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	18A0765	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>11/14/18-1) Provide coordination & short circuit study signal & sealed by P.E. 2) Service Switch feeds "MDS-retail" in service B is overfused-fix typo- DWG #2. 3) GEC of fire pump is undersized- 250.66. Remove bonding & grounding from F.P & FA emergency switches. 5) Provide conds. Size feed load bank and 'GDP' panel. 6) Comply with 760.41 (D)(4). 7) Verify the AIC rating of all ATSS. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/8/2020</p> <ol style="list-style-type: none"> 1. GEC and EGC for Fire pump are undersized as per tables 250.66 & 250.122 2. Jockey pump to follow tap rules as per 430.28 & confirm compliance with 695.6(F), confirm that fire pump controller is not used as a junction box. 3. Conductor feeds GDP section #2 is undersized. 4. Confirm following the recommended setting within the coordination study. 				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55768	18A0768	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
11/14/18-1) Ground bar in main swbd undersized. 2) Provide services rated calculations for panels RPs.3)Follow tap rules for all RP's taps. 1/11/19 - 1. Provide coordinatoin between A4BY 800A fuse and down stream breaker in meter bank. 2/15/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55628	18A0769	Requesting a special permission to leave as installed, spliced service conductors	Approved	\$0.00
Provide documentation for the insulating material use. 12/21/18. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55650	18A0770	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestors Abatement document. 12/26/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/4/19 Swap Dwg A rev 1 12/11/19 Swap Dwg A rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55687	18A0771	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide cut sheets to new equipment showing NRTL listing and AIC rating.. 2) Provide Asbestos Abatement compliance document.. 1/31/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55653	18A0774	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide AIC rating and available S.C. Current at new distribution switchboard. 1/9/19 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55554	18A0775	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/3/19 Swap dwg #A.1 with stipulation to comply with 332.12(2) 6/28/19 Swap dwg #A.2				
55555	18A0777	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55744	18A0778	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
11/14/18 - 1) Provide asbestos abatement. 2) Verify available short curcuit current at fire pump controller. 3) Provide manufacture cut sheets. 2/6/19 - 1. Primary conds of 500kVA xfmsr are undersized. 2. Fire pump EGC is undersized - 1250.122. 2/26/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/12/19 1) Clearly mark and label all changes from previously approved plans (write notes for each changes). 2) Show UL listing for new equipments. 9/23/2019 Swap Dwg # P-3628-D-1 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/18/19 Swap Dwg # rev.4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/14/20 Dwg amended. Sheet 1-Revision 4.				
55689	18A0779	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide short study and selective coordination (series rating). 2) Verify max available short circuit at service entrance 20,000 amps. 1/11/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/8/20 Swap Dwg # A rev. 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/4/2020 Swap dwg #A.3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55701	18A0781	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
11/14/18- 1) Provide asbestos abatement. 1/10/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55565	18A0782	Material approval for 1000V PV equipment	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55905	18A0783	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide Asbestos Abatement compliance documents if PW1 form is submitted 22 subsection need to show control #. 2) Ground bar size is missing MSWBD #!. 3) Emergency side of FP need to be fire rated (Gen FP conductor should be fire rated) .. 4) Verify location of generated and big size of RP emergency side conductor? 5) Verify 3 wire of emergency side conductor and 4 wired on normal side.. 1/10/19 1) Incoming service conds are undersized with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Provide coordination between 800A A4BY and downstream breakers in MB1, 2, and 3. 3/8/19 1) Provided max load demand to be signed and sealed by P.E. 2) Item #2 from last revision is not addressed. 4/19/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/5/2021 Amended dwgs # 2 Rev 3, 3 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55599	18A0785	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
11/14/18- 1) One line does not match fuses lay out in last APEIO SWBD temp service A.. 12/7/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55633	18A0786	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
11/14/18-1) Ground strap of SS#1 is undersized. 2) Comply with 408.06 (A)- N.D.L to be on the loadside of bonding & grounding.. 12/19/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/2/2020 Amended Dwg # 1 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55560	18A0787	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/8/19 - 1. Provide panel B2 amperage rating. 2. Comply with 408.36. 5/10/19 Swap dwg 1-Rev 2				
55700	18A0788	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination between 800A ss#2 and downstream breakers in MB#1 an provide available s.c. current and the AIC rating at MB#1-St should ot be series rated. 12/31/18 1) Item #1 is partially addressed-provide coordination between 800A and downstream OCPD in MB3 #1 signed and sealed by P.E. 2/6/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/8/19 Swap Drawing No: P-3599-D-1 Rev.2. 2/28/2020 Swap dwg # P-3599-D-1-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/9/2021 Amended dwg# 1 Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55698	18A0789	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide clearances in front of new ss#5A. 2) Provide Asbestos Abatement. 1/11/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/2/19 Swap dwg #1 of 1-Revision 2.				
56120	18A0790	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
11/14/18- 1)Provide size of FP (Howise Power). 2)Provide Asbestos Abatement. 3) Fix Typo on new 400A ATS- switch labels. 12/31/18 1) Fire pump-OCPD-emergency side-is undersized. 2) Verify 2 hr fire rated to F.P. conductors. 3) Item #3 from last revision is not addressed. 4) Verify that new fuses provided is replacing to existing in same size or less. 11/7/19 1) Item #2 is partially addressed. 11/14/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
55561	18A0791	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/26/19 Swap Dwg ACS-D-13411-1 Rev 1 and -2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/11/2021 Amended plans# 1 & 2 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/20/2021 Amended plans# 1 & 2 Rev 3 . Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55557	18A0792	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55556	18A0793	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55654	18A0794	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination between 1600A KRPC and downstream fuse 600A FRN, signed and sealed by P.E. 2) Verify fire pump tap lug size on physical drawing. 3) Show fire pump service switch and "ARCS" service switch in electrical service room and verify location of F.A. service switch. 1/10/19 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/11/19 Swap Dwg # sheet 1 rev.2 and sheet 2 rev.2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/18/2020 Amended plans# 1 & 2 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/6/2021 Amended Plans# 1 & 2 Rev.4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

November 14, 2018

Approval #	Submission #	Type of Request	Status	Fee
56194	18A0795	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>1) Sectional bus feeds ssw#C1, C2 and C3 and vertical bus feeds ssw #C1 and C2 are undersized. 2) Verify that electrical scope of work is included within the Asbestos Abatement compliance documents provided. 1/6/2020 1) Provide coordination between 1600A & downstream 1000A KRPC fuses, signed & sealed by P.E. 9/24/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
55679	18A0798	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/14/18- 1) Fire pump OCPD- Emergency side is undersized 695.4 (B)(1). 2)Verify "MDB2" panel board amperage rating 1200A or 600A and S.C current rating cut sheet doesn't match one line. 3)Provide detailed short circuit current calcs to MDB1 and square D 600A meterbank. 4) Fix typo in all available S.C current notes. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/28/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/14/22020 Company name change to TFK Electric. 2/19/2020 1) 3 pole for fire alarm with neutral not accepted. 2) Verify conductor feeding 800A undersized. 4/2/2020 Dwg ammended Dwg 1 of 1-Rev.3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/2/2020 Dwg amendment Dwg 1 of 1-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				