

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47354CO2	06A0407CO2	Requested approval for the electric service equipment proposed to be installed	Hold	\$0.00
Carry over from October 25, 2006 meeting. . 1) Floor plan almost consistent with one-line. 2) Show locations of transformers 3) Service room elevations drawings should be provided or photos or pictures of room. 4) Provide proof from a testing agency that the existing service equipment is safe to operate and reuse.				
47394CO	06A0457CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from September 13, 2006 meeting.				
47437CO	06A0511CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 25, 2006 meeting. 1) Provide catalog info on Capstone generator, shunt trip switch and transfer switches. 2) Indicate status of util/gen/Capstone under all operating modes. 3) Show all feeders include N & G. 4) Indicate available service current. 5) Indicate when "future" is to be installed. Job finalized August 16, 2007.				
47451CO	06A0464CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 25, 2006 meeting.				
47465CO	06A0507CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 25, 2006 meeting.				

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47472CO	06A0510CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 25, 2006 meeting				
47508	06A0542	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47509	06A0551	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47510	06A0539	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47511	06A0541	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47512	06A0540	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47513	06A0538	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination protection. 2) Section view for Siemens switchboards. Job finalized 3/22/07.				
47514	06A0537	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide overcurrent protection for 300KVA XFMRs. 2) Clarify need for ?-Y XFMR for 300KVAs. 3) Provide switchboard/panel cuts. Finalized job 1/19/07.				
47515	06A0546	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide disconnect switch not FCO at 480V. 2) Site plan must show location of manhole and XFMR. Job finalized 11/20/06.				
47516	06A0533	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47517	06A0536	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) 'MSA' and 'MSB' main switches drawn backward. 2) Need disconnect switch (not FCO) at 480V for 30A ATS feed. 3) 15KVA XFMR for FCO panel grounded on wrong side. 4) Life safety ATSs with "future" emergency source must be locked in normal position. Job finalized 12/06				
47518	06A0525	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47519	06A0527	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47520	06A0529	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47521	06A0531	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Confirm all 3 incoming sets are tapped in 12"x12" trough for each load tap. Job finalized 12/12/06.				

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47522	06A0547	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47523	06A0552	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47524	06A0543	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) 1200 amp service switch to ground fault protected. 2) Provide disconnect link in 4000 amp service switches. Job finalized 11/16/06.				
47525	06A0554	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
47526	06A0549	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Through bus undersized. Job finalized 11/16/06.				

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47527	06A0544	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Coordinate fuses 600 amp TR with 1200 amp A4BY. Job finalized 11/16/06.				
47528	06A0523	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify 4 wire fuse cut out for fire alarm. 2) Reconfigure switchboard location for passage to Con-Ed box. Job finalized 11/20/06. 8/30/17 - 1) Provide 3000A A\$BQ SS# fuse coordination with downstream circuit breakers. 2) Show FA SS# bonding. 3) Remove multiple fusing for FA on EM side 9/28/17 - swap dwg with rev 3				
47529	06A0524	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Not in Advisory Board format. 2) 200 amp meter and service switch should be on one-line diagram. 3) Lincoln Electric title block can not be used.				
47530	06A0545	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) Service room doors to open out as per 110.26(c)(2). 2) Emergency panel can't be located inside of the service room 3) Special permission is required to install PVC non metallic conduit for service entrance conductors and fire pump feeders. 4) The size of the bond strap was omitted. 5) No equipment grounding conductor installed in the PVC conduit. 6) Verify the fire pump feeders. 7) Verify if the storage space inside of the service room is a room.				
47531	06A0548	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
1) Bond neutral to enclosure in 200 amp service switch. 2) Provide signage.				

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47532	06A0532	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Doors to service room to open out. 2) Neutrals in 400 amp service switches not bonded to the enclosures. 3) Verify service room doors. 4) Size of service entrance conductors omitted. 5) Fuse types not provided 1200 amp service switch or coordinated 1200 amp to 600 amp. 6) 1600 amp service switch not metered or coordinated with 600 amp fuses.				
47533	06A0534	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Special permission 47540, 745 7th Ave does not match the address of this drawing, 275 75th Ave.				
47534	06A0535	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Verify length of tap. 2) Provide details of tap box.				
47535	06A0526	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47536	06A0528	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47537	06A0530	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47538	06A0553	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Increase bus in FDP panel. 2) Increase take off bus both sections. Job finalized 1/19/07.				
47539	06A0550	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47540	^	Requesting permission due to not enough space to install new concrete encased conduits, to run unprotected MI service entrance conductors over 10 feet long between two separate but adjacent service rooms.	Denied	\$0.00
The job address on this sketch is 745 7th Ave., 745 7th Avenue does not match the drawings submitted, Cal. #47533, 275 7th Ave. the total length of the MI run omitted.				
47541	^^	Requesting permission due to the buildings structure, to leave one egress door to the service room.	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47542	^^^	Requesting permission not to provide a second means of egress to a service room due to the construction of the building.	Approved	\$0.00
47543	^^^^	Requesting permission to leave as submitted a second means of egress to a service room that requires a ladder to lead to a door.	Approved	\$0.00
47544	^^^^^	Requesting permission to retro fit 9 existing defective service switches with new interiors which will feed on the top and bottom of the switches due to the switches not operating properly once they are opened.	Hold	\$0.00
47545	^^^^^^	Requesting permission not to file Advisory Board drawings on an existing 4000 amp service where a 100 amp service switch fused at 70 amps was installed to provide power for Con Edison's steam station metering.	Approved	#Error
47546	^^^^^^^	Requesting permission to leave as certified a fire pump listed as suitable for use as service equipment which is direct connected to service entrance conductors.	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47547	^ ^ ^ ^ ^ ^ ^ ^	Requesting permission to leave as installed service equipment that is not grouped together in a one family building, an additional outdoor service for condo lighting was installed outdoors.	Approved	\$0.00
47548	^ ^ ^ ^ ^ ^ ^ ^ ^	Requesting permission due to lack of space inside of the service room to leave as installed a service switch on the outside of the building, where signage will be provided.	Approved	\$0.00
47549	^ ^ ^ ^ ^ ^ ^ ^ ^ ^	Requesting permission to leave as installed in 95 dwelling units the hood exhaust fan connected to the small appliance circuits.	Approved	\$0.00
47550	^ ^ ^ ^ ^ ^ ^ ^ ^	Requesting permission on a job where the contractor filed for work performed by others to leave as installed in one store (club) non compliance with 518.4.	Approved	\$0.00
With the stipulation that ground fault circuit breakers are installed on all of the circuits that do not comply with Section 518.4				
47551	^ ^ ^ ^ ^ ^ ^ ^ ^ ^	Requesting permission to leave as installed a building that was wired as a two family dwelling and the owner converted one dwelling unit to a doctor's office with the wiring method AC cable without an insulated grounding conductors.	Denied	\$0.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47552	^^^^^^^^^^^^^^ ^	Requesting permission to leave as installed a kitchen inside a place of assembly that is wired in 30% AC cable without an insulated grounding conductor.	Approved	\$0.00
With the stipulation that the circuits that don't contain the insulated grounding conductor are provided with ground fault protection.				
47553	06A0555	Requested approval for use in New York City of your Recessed CMH (Ceramic Metal Halide) Fixtures consisting of a steel mounting plate, socket whip assembly, ballasts, and junction boxes along with various trim figurations.	Approved	\$200.00

