

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47354CO2	06A0407CO2	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	The Plaza Hotel Fifth Avenue at Central Park South New York NY	Hold	\$0.00
Carry over from October 25, 2006 meeting. . 1) Floor plan almost consistent with one-line. 2) Show locations of transformers 3) Service room elevations drawings should be provided or photos or pictures of room. 4) Provide proof from a testing agency that the existing service equipment is safe to operate and reuse.						
47394CO	06A0457CO	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The Hub Parking Garage 3000-3002 3rd Avenue Bronx NY	Approved	\$0.00
Carry over from September 13, 2006 meeting.						
47437CO	06A0511CO	Another Nycer Electric Corp. 652 Sackett Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	Capstone Turbine 10203 Avenue D Brooklyn NY	Approved	\$0.00
Carry over from October 25, 2006 meeting. 1) Provide catalog info on Capstone generator, shunt trip switch and transfer switches. 2) Indicate status of util/gen/Capstone under all operating modes. 3) Show all feeders include N & G. 4) Indicate available service current. 5) Indicate when "future" is to be installed. Job finalized August 16, 2007.						
47451CO	06A0464CO	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	260 Beach 81st Street Far Rockaway NY	Approved	\$0.00
Carry over from October 25, 2006 meeting.						
47465CO	06A0507CO	AK Electrical Contracting Inc. 512 68th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	560 Park Avenue New York NY	Approved	\$0.00
Carry over from October 25, 2006 meeting.						

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47472CO	06A0510CO	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Target @ The Junction 2201 Nostrand Avenue Brooklyn NY	Approved	\$0.00
Carry over from October 25, 2006 meeting						
47508	06A0542	Salvatore Campisi & Sons Elecl Contrs, Inc. 453 Onderdonk Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	450 Seventh Avenue New York NY	Approved	\$650.00
47509	06A0551	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	UBS Securities 1285 6th Avenue New York NY	Approved	\$650.00
47510	06A0539	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1600 Broadway New York NY	Approved	\$650.00
47511	06A0541	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	1600 Broadway New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47512	06A0540	J.J. Rosenberg Electrical Contrs, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	1600 Broadway New York NY	Approved	\$650.00
1) Provide coordination protection. 2) Section view for Siemens switchboards. Job finalized 3/22/07.						
47513	06A0538	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	NYC Dept. of Environ. Protect. 122-68 Flatlands Avenue Brooklyn NY	Approved	\$650.00
1) Provide overcurrent protection for 300KVA XFMRs. 2) Clarify need for ?-Y XFMR for 300KVAs. 3) Provide switchboard/panel cuts. Finalized job 1/19/07.						
47514	06A0537	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	River Point Towers Apartments 555 Kappock Street Bronx NY	Approved	\$650.00
1) Provide disconnect switch not FCO at 480V. 2) Site plan must show location of manhole and XFMR. Job finalized 11/20/06.						
47515	06A0546	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Fordham Univ. Parking Fac. 440 East Fordham Road Bronx NY	Approved	\$650.00
1) Provide disconnect switch not FCO at 480V. 2) Site plan must show location of manhole and XFMR. Job finalized 11/20/06.						
47516	06A0533	A & R Electrical Maintenance, Inc. 69-61 Juniper Boulevard South Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	3rd Church of Christ 583 Park Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47517	06A0536	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Lincoln Center 140 West 65th Street New York NY	Approved	\$650.00
1) 'MSA' and 'MSB' main switches drawn backward. 2) Need disconnect switch (not FCO) at 480V for 30A ATS feed. 3) 15KVA XFMR for FCO panel grounded on wrong side. 4) Life safety ATSS with "future" emergency source must be locked in normal position. Job finalized 12/06						
47518	06A0525	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	356 West 58th Street New York NY	Approved	\$650.00
47519	06A0527	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	1 East 104th Street New York NY	Approved	\$650.00
47520	06A0529	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	8 West 40th Street New York NY	Approved	\$650.00
47521	06A0531	Al-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	106 Mott Street New York NY	Approved	\$650.00
Confirm all 3 incoming sets are tapped in 12"x12" trough for each load tap. Job finalized 12/12/06.						

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47522	06A0547	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Court Square LLC 45-31 Court Square Queens NY	Approved	\$650.00
47523	06A0552	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2400 Johnson Avenue Bronx NY	Approved	\$650.00
47524	06A0543	Atkinson Koven Feinberg, LLP 1501 Broadway, Suite 700 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 522 Fifth Avenue New York NY	Approved	\$650.00
1) 1200 amp service switch to ground fault protected. 2) Provide disconnect link in 4000 amp service switches. Job finalized 11/16/06.						
47525	06A0554	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	The Plaza Hotel Fifth Avenue at Central Park South New York NY	Hold	\$650.00
47526	06A0549	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	247 West 46th Street New York NY	Approved	\$650.00
Through bus undersized. Job finalized 11/16/06.						

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47527	06A0544	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	The Coronado 155 West 75th Street New York NY	Approved	\$650.00
Coordinate fuses 600 amp TR with 1200 amp A4BY. Job finalized 11/16/06.						
47528	06A0523	Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Republic of China to the U.N. 603 First Avenue New York NY	Approved	\$650.00
1) Verify 4 wire fuse cut out for fire alarm. 2) Reconfigure switchboard location for passage to Con-Ed box. Job finalized 11/20/06.						
47529	06A0524	Double D Electric Inc. 33 2nd Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	176-60 Union Turnpike Queens NY	Hold	\$650.00
1) Not in Advisory Board format. 2) 200 amp meter and service switch should be on one-line diagram. 3) Lincoln Electric title block can not be used.						
47530	06A0545	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Public School 245Q 384 Seneca Avenue Ridgewood NY	Denied	\$650.00
1) Service room doors to open out as per 110.26(c)(2). 2) Emergency panel can't be located inside of the service room 3) Special permission is required to install PVC non metallic conduit for service entrance conductors and fire pump feeders. 4) The size of the bond strap was omitted. 5) No equipment grounding conductor installed in the PVC conduit. 6) Verify the fire pump feeders. 7) Verify if the storage space inside of the service room is a room.						
47531	06A0548	Judd Electric Inc. 41-41 38th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1090 Amsterdam Avenue New York NY	Ok, but	\$650.00
1) Bond neutral to enclosure in 200 amp service switch. 2) Provide signage.						

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47532	06A0532	Staunton Chow, P.C. Engs. & Architects 100 West 32nd Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Columbia University 601 West 115th Street New York NY 10001	Hold	\$650.00
1) Doors to service room to open out. 2) Neutrals in 400 amp service switches not bonded to the enclosures. 3) Verify service room doors. 4) Size of service entrance conductors omitted. 5) Fuse types not provided 1200 amp service switch or coordinated 1200 amp to 600 amp. 6) 1600 amp service switch not metered or coordinated with 600 amp fuses.						
47533	06A0534	Levest Electric Corp. 325 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	275 7th Avenue New York NY	Hold	\$650.00
Special permission 47540, 745 7th Ave does not match the address of this drawing, 275 75th Ave.						
47534	06A0535	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	International Stock Exchange 60 Broad St., 27th and 28th Floors New York NY	Hold	\$650.00
1) Verify length of tap. 2) Provide details of tap box.						
47535	06A0526	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	625 Madison Avenue New York NY	Approved	\$650.00
47536	06A0528	Vertex Electrical Corporation 28-41 Steinway Street Long Island City NY 11103	Requested approval for the electric service equipment proposed to be installed	P.J. Clark's 44 West 63rd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47537	06A0530	OM Electric, Inc. 262 West 38th Street, Suite #603 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	6511 Ft. Hamilton Parkway Brooklyn NY	Approved	\$650.00
47538	06A0553	Bronxdale Electric, Inc. 1718 White Plains Road Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	Dyckeman Center 4055 10th Avenue New York NY	Approved	\$650.00
1) Increase bus in FDP panel. 2) Increase take off bus both sections. Job finalized 1/19/07.						
47539	06A0550	Folks Electrical, Inc. 670 Broadway New York NY 10012	Requested approval for the electric service equipment proposed to be installed	300 West 55th Street New York NY	Approved	\$650.00
47540	^	Lehr Construction Corp. 902 Broadway New York NY 10010	Requesting permission due to not enough space to install new concrete encased conduits, to run unprotected MI service entrance conductors over 10 feet long between two separate but adjacent service rooms.	Amalgamated Bank 275 7th Avenue New York NY	Denied	\$0.00
The job address on this sketch is 745 7th Ave., 745 7th Avenue does not match the drawings submitted, Cal. #47533, 275 7th Ave. the total length of the MI run omitted.						
47541	^^	Falco Electrical Services Inc. 2220 Voorhies Avenue Brooklyn NY 11232	Requesting permission due to the buildings structure, to leave one egress door to the service room.	150 East 35th Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47542	^^^	Square D/Schneider Electric 145 West 45th Street, Suite 1100 New York NY 10036	Requesting permission not to provide a second means of egress to a service room due to the construction of the building.	Fashion Industries H.S. 225 West 24th Street New York NY	Approved	\$0.00
47543	^^^^	Gessin Electrical Contractors, Inc. 791 East 139th Street Bronx NY 10454	Requesting permission to leave as submitted a second means of egress to a service room that requires a ladder to lead to a door.	67 Wall Street New York NY	Approved	\$0.00
47544	^^^^^	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission to retro fit 9 existing defective service switches with new interiors which will feed on the top and bottom of the switches due to the switches not operating properly once they are opened.	The Plaza Hotel Fifth Avenue @ Central Park South New York NY	Hold	\$0.00
47545	^^^^^^	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission not to file Advisory Board drawings on an existing 4000 amp service where a 100 amp service switch fused at 70 amps was installed to provide power for Con Edison's steam station metering.	1 East 57th Street New York NY	Approved	#Error
47546	^^^^^^^	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn NY 11220	Requesting permission to leave as certified a fire pump listed as suitable for use as service equipment which is direct connected to service entrance conductors.	88 Laight Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47547	^	Laser Lite Electrical, Inc. 40 Gaton Street Staten Island NY 10309	Requesting permission to leave as installed service equipment that is not grouped together in a one family building, an additional outdoor service for condo lighting was installed outdoors.	15, 25, 37 and 49 Giacomo Lane Staten Island NY	Approved	\$0.00
47548	^	Nivek Electrical Contracting, Inc. 301 East 119th Street New York NY 10035	Requesting permission due to lack of space inside of the service room to leave as installed a service switch on the outside of the building, where signage will be provided.	130-14 60th Avenue Queens NY	Approved	\$0.00
47549	^	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requesting permission to leave as installed in 95 dwelling units the hood exhaust fan connected to the small appliance circuits.	1490 Boston Road Bronx NY	Approved	\$0.00
47550	^	Manuel Sertzen Inc. 1545 White Plains Road Bronx NY 10462	Requesting permission on a job where the contractor filed for work performed by others to leave as installed in one store (club) non compliance with 518.4.	1930 Patterson Avenue Bronx NY	Approved	\$0.00
With the stipulation that ground fault circuit breakers are installed on all of the circuits that do not comply with Section 518.4						
47551	^	Mystic Electrical Corp. 1410 Nelson Avenue, Suite A Bronx NY 10452	Requesting permission to leave as installed a building that was wired as a two family dwelling and the owner converted one dwelling unit to a doctor's office with the wiring method AC cable without an insulated grounding conductors.	1461 Astor Avenue Bronx NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

November 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47552	^	Brooklyn Queens Electric Corp. 587 Manhattan Avenue Brooklyn NY 11222	Requesting permission to leave as installed a kitchen inside a place of assembly that is wired in 30% AC cable without an insulated grounding conductor.	Peter Luger Inc. 852 Driggs Avenue Brooklyn NY	Approved	\$0.00
With the stipulation that the circuits that don't contain the insulated grounding conductor are provided with ground fault protection.						
47553	06A0555	Conservation Technology, Ltd. 2783 Shermer Road Northbrook IL 60002	Requested approval for use in New York City of your Recessed CMH (Ceramic Metal Halide) Fixtures consisting of a steel mounting plate, socket whip assembly, ballasts, and junction boxes along with various trim figurations.		Approved	\$200.00