

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46048CO	04A0510CO	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The Hearst Building 959 Eighth Avenue New York NY	Ok, but	\$0.00
Carry over from December 15, 2004 meeting. Auto fire pump breaker not consist with previous submission.						
46428CO2	05A0285CO2	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	Mutual Redevelopment Houses 321 Eight Avenue New York NY	Approved	\$0.00
Carry over from July 20, 2005 meeting.. Merlin-Gerin to confirm series rating of breaker.						
46547CO	05A0360CO	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	UBS 85 Avenue of the Americas, Floor 15 New York NY	Approved	\$0.00
Carry over from August 17, 2005 meeting.						
46605CO	05A0410CO	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	145 Brooklyn Avenue Brooklyn NY	Hold	\$0.00
Carry over from August 17, 2005 meeting. 1) No coordination between the 800 amp AHBQ and Distribution EDP-3 500 and 400 amp TR fuses. Should be AZK's. 2) No mixing of 3 and 4 pole ATS. 3) Where is 800 amp ATS being fed from?						
46634CO	05A0433CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	2 Gold Street New York NY	Approved	\$0.00
Carry over from September 14, 2005 meeting.						

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46743	05A0532	CSA Engineering Services 37 Milry Brook Riad Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	Cabrini Hospital 227 East 19th Street New York NY	Ok, but	\$650.00
Clarify 4-wire system when step-up XFMR indicates Delta system.						
46744	05A0533	Triad Engineers & Constructors, Inc. 2740 Route 10 West Morris Plains NJ 07950	Requested approval for the electric service equipment proposed to be installed	Rochdale Village Power Plant 132-11 Bedell Street Jamaica NY	Approved	\$650.00
46745	05A0536	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	Roosevelt Island Operating Corp. 686 Main Street New York NY	Approved	\$650.00
46746	05A0537	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Chelsea Art Tower 545 West 25th Street New York NY	Approved	\$650.00
46747	05A0538	Hylan Electrical Contracting, Inc. 1150 South Avenue, Corporate Park Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	NYS-DOT 28-11 Queens Plaza North Long Island City NY	Approved	\$650.00
1) Submit cuts on new generator and generator distribution equipment. 2) Provide floor plan with dimensions for generator distribution equipment.						

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46748	05A0539	Integral Electrical Power & Control Corp. 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	NYU-Building #3 25 Union Square West New York NY	Approved	\$650.00
46749	05A0540	Barbaro Electric Co., Inc. 331 38th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	385 5th Avenue New York NY	Approved	\$650.00
46750	05A0541	Dynamic Electric Service Inc. 14-17 110th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	468-470 Park Avenue South New York NY	Approved	\$650.00
46751	05A0542	BMS Electric, Inc. 33-13 58th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Trump Building "C" 200 Riverside Boulevard New York NY	Approved	\$650.00
46752	05A0543	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Avalon Cooper Sq. Phase II 1 East 1st Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46753	05A0544	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	90 West Street New York NY	Approved	\$650.00
Delete unfused switch.						
46754	05A0545	Woodland Electrical Contracting Corp. 4601 White Plains Road Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	East Houston Street Residence 310 East Houston Street New York NY	Approved	\$650.00
46755	05A0546	B & S Electrical Contracting Co., Inc.. 4317 15th Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	1 Bay Street Landing Staten Island NY	Approved	\$650.00
46756	05A0547	Lewin Electric Corp. 6205 18th Avenue Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	Bonafide Estates Inc. 41 West 25th St.,-Bsmt New York NY	Approved	\$650.00
46757	05A0548	Lewin Electric Corp. 6205 18th Avenue Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	Bonafide Estates Inc. 48 West 38th St.,-Bsmt New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46758	05A0549	L.E.A. Electric Corp. 2112 Broadway, Suite 204 New York NY 10023	Requested approval for the electric service equipment proposed to be installed	134-40 Springfield Bayside NY	Approved	\$650.00
46759	05A0550	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	263 9th Avenue New York NY	Approved	\$650.00
Show 2nd fusing on one-line.						
46760	05A0551	Up Town Electric, Inc. 5-28 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Bontanical Gardens 2756 Dr. Theodore Kazimiroff Blvd. Bronx NY	Approved	\$650.00
46761	05A0552	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 1585 Broadway New York NY	Approved	\$650.00
46762	05A0553	Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	The Princeton Club of NY 15 West 43rd Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46763	05A0554	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	731 Flushing Avenue Brooklyn NY	Approved	\$650.00
46764	05A0555	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	102-10 66th Road Queens NY	Approved	\$650.00
46765	05a0556	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	49-57 Crown Street Brooklyn NY	Approved	\$650.00
46766	05A0557	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	90-75 Sutphin Blvd. Jamaica NY	Approved	\$650.00
46767	05A0558	TFD and Sons Electric Inc. 424 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	226 West 46th Street New York NY	Approved	\$650.00
with the stipulation that: 1) Change fire pump service switch 600% of motor FLA. 2) Remove old DC circuit breaker.						

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46768	05A0559	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Charter Mac 625 Madison Avenue New York NY	Hold	\$650.00
1) Service entrance to be encased in concrete. 2) 800 amp feeder does not comply with tap rules.						
46769	05A0560	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Apple Bank 2112 Broadway New York NY	Approved	\$650.00
Second fusing for 800 amp service switch not provided.						
46770	05A0561	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Barclay's 200 Park Avenue New York NY	Approved	\$650.00
46771	05A0562	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	Jewish Community Center 1466 Manor Road Staten Island NY	Denied	\$650.00
1) 480 volt fire alarm cut to be changed to switch and shown on one line diagram. 2) ATS not shown on 1-Line. 3) Fire alarm ATS should not be in service room. 4) Emergency power not provided.						
46772	05A0563	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	PS IS 93M 501-503 West 152nd Street New York NY	Approved	\$650.00
1) Feed to fire pump not fire rated. 2) FLA for fire pump not provided. 3) 30 amp fire alarm cutout indicated as switch. 4) Bus on load side 4000 amp service should be rated at 800 square inch.						

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46773	05A0564	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	45 East 89th Street New York NY	Denied	\$650.00
1) Verify that ATS in service room is not for life safety. 2) ATS information does not indicate 3 or 4 pole. 3) Generator not provided with over current device. 4) Generator output feed not properly sized. 5) 800 trans S meter feeds over 4000 amps of equipment. 6) Generator must comply Building Department requirements.						
46774	05A0565	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	415 Leonard Street Brooklyn NY	Denied	\$650.00
1) Short circuit calculation not provided.. 2) No coordination between 800 fuses and circuit breakers. 3) Panel PPHR and PPH overcurrent not provided. 4) Feeders not sized on drawing. 5) Jockey pump wired with MI no need.						
46775	05A0566	B & G Electrical Contractors of NY Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	689 Fifth Avenue New York NY	Approved	\$650.00
46776	05A0567	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	4 East 66th Street New York NY	Approved	\$650.00
46777	05A0568	Arnold Finkelstein, Lic. Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	1995 First Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

November 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46778	05A0569	Gilston Electrical Maintenance Corp. 453 East 175th Street Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	380 Lenox Avenue New York NY	Approved	\$650.00
Take off bus undersized.						
46779	05A0570	Concorde Electrical Services, Inc. 6701 8th Avenue Brooklyn NY 11228	Requested approval for the electric service equipment proposed to be installed	CVS 750 Sixth Avenue New York NY	Approved	\$650.00
46780	05A0571	Campbell and Dawes Ltd. Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	120 Wall Street New York NY	Approved	\$650.00
46781	05A0572	Gessin Electrical Contractors, Inc. 791 East 139th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	40 Mercer Street New York NY	Approved	\$650.00
1) Increase take off bus. 2) Show cable size to common trough.						
46782	05A0573	Eric & NG Electrical Inc. 153 Suffolk Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	1300 Metropolitan Avenue Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46783	05A0574	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Queens Crossing 138-20 38th Avenue Flushing NY	Approved	\$650.00
500 amp fuse to be lowered to 400 to coordinate						
46784	05A0575	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	375 Park Avenue New York NY	Approved	\$650.00
46785	05A0576	Stat Electric, Inc. 118-21 Queens Blvd.-suite 311 Queens NY 11375	Requested approval for the electric service equipment proposed to be installed	Nextel #NY2473 79-11 41st Avenue Elmhurst NY	Approved	\$650.00
46786	05A0577	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	15 Metro Tech-Roof Top Brooklyn NY	Approved	\$650.00
46787	05A0578	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Atlas Park-Building #6 80th Street & Cooper Avenue Glendale NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46788	05A0579	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	310 West 52nd Street New York NY	Approved	\$650.00
1) Glastic barrier fire pump. 2) End box height.						
46789	05A0580	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	The Clarett Tower 11 East 29th Street New York NY	Approved	\$650.00
46790	05A0581	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	Staten Island Rail Yard 331 Western Avenue Staten Island NY	Approved	\$650.00
46791	05A0531	Kleinknecht Electric Company, Inc. 252 West 37th Street-9th Floor New York NY 11018	Requested approval for the electric service equipment proposed to be installed	Credit Suisse First Boston 315 Park Avenue South New York NY	Approved	\$650.00
46792	05A0535	Kleinknecht Electric Company, Inc. 252 West 37th Street-9th Floor New York NY 11018	Requested approval for the electric service equipment proposed to be installed	Takashimaya 693 5th Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46793	05A0530	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Memorial Sloan Kettering  New York NY	Hold	\$650.00
1) Clarify scope of work between new and existing work. 2) Engineer to appear at next meeting.						
46794	05A0582	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1415 Richmond Avenue Staten Island NY	Approved	\$650.00
46795	05A0583	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11110	Requested approval for the electric service equipment proposed to be installed	485 5th Avenue New York NY	Approved	\$650.00
46796	05A0584	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1360 Ocean Parkway Brooklyn NY	Approved	\$650.00
46797	05A0585	New Grand Electric Inc. 71-73 Allen Street #302 New York NY 10002	Requested approval for the electric service equipment proposed to be installed	380 Lafayette Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46798	05A0586	Hugh O Kane Electric Co., Inc. 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYCHA Ocean Bay Apts  Rockaway NY	Hold	\$650.00
<p>1) Provide mechanical interlocks on high voltage switchgear with signage on switches. 2) Provide grounding on secondary of transformer. 3) Provide interlock to shut down switchgear when back of cabinet is opened or provide signage on switchgear. 4) Clearances issuers in switchgear room, egress add additional doors. 5) Provide sequence of operative for interlocks.</p>						
46799	05A0587	High-Tech Electrical Services Corp. 36-33 23rd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	CBS 51 West 52nd Street New York NY	Approved	\$650.00
46800	05A0588	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	29 West 57th Street New York NY	Approved	\$650.00
46801	05A0589	A.T.J. Electrical Inc. 33-61 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	993 Park Avenue New York NY	Approved	\$650.00
46802	-	V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requesting permission to leave as installed BX cable as a wiring method in a place of public assembly.	1081 3rd Avenue New York NY	Approved	\$350.00

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46803	--	Able Electrical Serv. & Maint. Inc. 161 Van Dike Street Brooklyn NY 11231	Requesting permission to leave as installed service equipment installed on the outside of a building that has one commercial and two residential units.	41 Dumont Street Staten Island NY	Approved	\$350.00
46804	---	Laszlo Bodak Engineer, PC 45 West 36th Street, 3rd Floor New York NY 10018	Requesting permission to install new service equipment in an vaulted area where the old service was located.	St. Honore Café 857 Broadway New York NY	Approved	\$0.00
46805	----	Paul Verardi, Licensed Electrician 176 Canal Street Staten Island NY 10304	Requesting permission to not group together service equipment due to no room in the existing service room, signage will be provided at each service.	1409 Richmond Avenue Staten Island NY	Approved	\$0.00
46806	-----	J Star Electric, Inc. 32 East 31st Street New York NY 10016	Requesting permission due to corrosion and mechanical indury issues to install the 100 amp service switch outdoors inside of an NEMA 3R enclosure that will feed the salt shed building.	NYCDOS Pike Slip New York NY	Approved	\$0.00
46807	-----	RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requesting permission due to lack of space inside of the service room to install a new 200 amp service switch that will provide power to a cell site on the outside of a building.	300 West Service Road Staten Island NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**November 16, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46808	--	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to install Schedule 80 PVC conduit as a partial wiring method for 14 two family outdoor underground services and to also install Schedule 80 PVC as a wiring method to feed outdoor air conditioning units.	y Bch Blvd., Bch 73rd St. & Bch 74 Rockaway NY	Approved	\$0.00
46809	05A0534	Daybrite Capri Omega 776 South Green Street Tupelo MS 38802	Requested approval for use in New York City of your Recessed HID Downlight. Model/Series: OM13980		Hold	\$200.00
1) Listing documentation does not cover the remote ballast construction submitted.      2) There is a discrepancy between drawing 13980, the submittal letter and the listing , for example: distance between ballast pan and the fixture, the gauge of the products (20GA. Or 16GA). 3) 1/2" hole in junction box not acceptable.						
46810	05A0590	Tyco Thermal Controls Raychem 11 Exeter Pass Colts Neck NJ 07722	Requested approval for the use in New York City of your Multiple-entry power/splice/tee connection with junction box for Raychem heating cable. Model/Series Numbers: JBM Series.		Denied	\$200.00
!) No power cord. 2) Plastic box not approved for other than residential maximum 3 stories indoor only.						