

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
44658CO	03A0061CO	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	325 Hudson Street(FOCAL) New York NY	Hold	\$250.00
Carryover from February 26, 2003. No new information.						
44672CO	03A0091CO	Allran Electric of New York Inc. 88-25 138th Street Jamaica NY 11435	Requested approval for the electric service equipment proposed to be installed	Staten Island Hospital 475 Seaview Avenue Staten Island NY	Approved	\$250.00
Carryover from May 14, 2003 meeting.						
45139CO	03A0481CO	Arc Electrical & Mechanical Contrs, Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Hunter College 695 Park Avenue New York NY	Approved	\$250.00
Carry over from August 13, 2003 meeting. Revision provided on 3/23/04.						
45229CO	03A0556CO	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	120 Broadway New York NY	Approved	\$250.00
45234CO	03A0560CO	North Point Electrical Corporation 651 Bay Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	Bird S. Coler Memorial Hospital 900 Main Street Roosevelt NY	Approved	\$250.00
Carryover from October 15, 2003 meeting.						

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45239CO	03A0589CO	Flemington Electrical Maintenance Inc. 207 West 25th Street-7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Ultra Flex Packaging Corp. 494 Wortman Street Brooklyn NY	Approved	\$250.00
Carryover from October 15, 2003 meeting.						
45244CO	03A0594CO	Robert Garcia Electrical Contracting Corp. 500 Trinity Avenue, Suite 1-B Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	224 West 18th Street New York NY	Approved	\$250.00
Carryover from October 15, 2003 meeting.						
45251CO	03A0567CO	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	New York Stock Exchange 11 Wall Street New York Ny	Approved	\$250.00
Carryover from October 15, 2003 meeting.						
45253CO	03A0569CO	ICOR Associates, LLC 21 Commerce Drive Cranford NJ 07016	Requested approval for the electric service equipment proposed to be installed	1710 Broadway New York NY	Approved	\$250.00
Carryover from October 15, 2003 meeting.						
45258CO	03A0576CO	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Macy's Building 47-44 31st Street Long Island City NY	Approved	\$250.00
Carryover from October 15, 2003 meeting.						

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45288	03A0615	Al-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	2860 Steinway Street Queens NY	Ok, but	\$250.00
1. New fire pump switch fuse type not consistent with size clarify conduit & feeder sizes. 2. Indicate detail of tapping 1 set to multiple sets.						
45289	03A0616	Chase Electric, Inc. 97-45 99th Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	250 East 30th Street New York NY	Ok, but	\$250.00
1. Reuse notes to reflect current New York City Electrical Code. 2. Title blocks indicate Cutler-Hammer & Siemens. Who is the manufacturer of new equipment?						
45290	03A0617	J.G. Electrical Installations, Inc. 66-05 60th Place Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	Charles Schwab 1356 3rd Avenue New York NY	Ok, but	\$250.00
Indicate feeder size & bus size of commercial trough.						
45291	03A0618	Approved Electric Corp. 3578 White Plains Rd, Suite 107 Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	4901 Henry Hudson Parkway Bronx NY	Approved	\$250.00
45292	03A0619	Joseph Sgroi & Sons, Inc. 34-06 44th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	School of Visual Arts 209 East 23rd Street New York NY	Approved	\$250.00

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45293	03A0620	Dooley Electric Co., Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Lutheran Med. Ctr Project 150 55th Street Brooklyn NY	Approved	\$250.00
Relocate 200 amp switch to provide 36" clearance.						
45294	03A0621	Call Electric Co. 35-21 Ninth Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	1700 Broadway New York NY	Ok, but	\$250.00
Relocate 200 amp switch to provide 36" clearance.						
45295	03A0622	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The Helena 601 West 57th Street New York NY	Approved	\$250.00
Relocate 200 amp switch to provide 36" clearance.						
45296	03A0623	Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requested approval for the electric service equipment proposed to be installed	21 South End Avenue New York NY	Approved	\$250.00
Relocate 200 amp switch to provide 36" clearance.						
45297	03A0604	Gilman Construction Co., Inc. 46-37 Vernon Boulevard Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Macy's Queens Ctr Mall 91-23 Queens Blvd. Queens NY	Hold	\$250.00
Submit complete drawings showing accurate depiction of existing equipment.						

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45298	03A0605	Trico Electric Corp. 1453 38th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	5 Penn Plaza New York NY	Approved	\$250.00
45299	03A0607	S.P.B. Electrical Contractors 55 John Street, 14th Floor New York NY	Requested approval for the electric service equipment proposed to be installed	Silverstein Properties 530 Fifth Avenue New York NY	Approved	\$250.00
45300	03A0609	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	92-59 59th Avenue Queens NY	Hold	\$250.00
1. Confirm max 65KA available at new distribution switchboard. 2. Provide room layout 3. Remove neutral ground on distribution switchboard. 4. Provide coordination curves. 5. Size bus bars per new code.						
45301	03A0613	Tappan Electric Inc. 1613 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	Rosco Industries 144-31 91st Avenue Jamaica NY	Approved	\$250.00
45302	03A0639	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	2130 McDonald Avenue Brooklyn NY	Approved	\$250.00

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45303	03A0611	Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	tside Engine Generators at Rikers Isl Queens NY	Approved	\$250.00
45304	03A0612	Miller Wholesale Electrical Supply Co., Inc 23-33 Spring Street Morristown NJ 07960	Requested approval for the electric service equipment proposed to be installed	Bronx House of Detention Bronx NY	Approved	\$250.00
1. Provide bus bar sizing per current code. 2. Reuse notes per current code. 3. Provide Con Ed short circuit current & impedance.						
45305	03A0640	Verde Electric Corp. 811 Whittier Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	611 5th Avenue New York NY	Approved	\$250.00
45306	03A0624	Compsec Electric Corporation 31-54 12th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	45-02 Ditmars Blvd. Queens NY	Ok, but	\$250.00
Need location of fire pump or concrete encasement.						
45307	03A0625	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	5th Avenue Prebyterian Church 7 West 55th Street New York NY	Ok, but	\$250.00
1. 3000 amp service switch-increase bus size. 2. 400 amp fuse, change type FRN to type LPN.						

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45308	03A0626	Alom Electrical Co., Inc. 148 22nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Riverside South Building "C" 9 Freedom Place New York NY	Approved	\$250.00
45309	03A0627	Savery S. Manfredonia, P.E., P.C. 14 Ponds Lane Purchase NY 10577	Requested approval for the electric service equipment proposed to be installed	401 5th Avenue New York NY	Approved	\$250.00
45310	03A0628	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Abraham Joshua Heschel H.S. 20 West End Avenue New York NY	Approved	\$250.00
45311	03A0629	Innovative Engineering, Inc. 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	2461 Knapp Street Brooklyn NY	Approved	\$250.00
45312	03A0630	Power-Tech Installation Electrical Contracto 321 Columbia Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	1330 Avenue of the Americas New York NY	Approved	\$250.00

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45313	03A0631	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Brooklyn College-Chiller Plant 2900 Bedford Avenue Brooklyn NY	Approved	\$250.00
45314	03A0632	Dynamic Electric Service Inc. 14-17 110th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	730 Park Avenue New York NY	Approved	\$250.00
45315	03A0633	Marcel Electrical Contracting Corp. 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	19-23 St. Marks Place New York NY	Approved	\$250.00
45316	03A0634	tros Automated Electrical Construction Co 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	5 Hanover Square New York NY	Approved	\$250.00
45317	03A0635	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	1095 Park Avenue New York NY	Hold	\$250.00
Clarify 2 "6x6" trough with 1 set of 350 MCM.						

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45318	03A0636	Kleinknecht Electric Company, Inc. 940 Eighth Avenue New York NY 10019	Requested approval for the electric service equipment proposed to be installed	AOL-Time Warner 10 Columbus Circle New York NY	Ok, but	\$250.00
1. Change conductors to 3 - sets 600 MCM each side. Size of ATS, & its location.						
45319	03A0637	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	LG Sign @ Bertelmann Bldg. 1540 Broadway New York NY	Approved	\$250.00
45320	03A0638	Applied Electric Corporation Building Number 4, New York Naval Shipyard Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	Marriot Courtyard 866 Third Avenue New York NY	Approved	\$250.00
45321	03A0602	JMJ Electric Corp. 247 West 30th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	415 West 13th Street New York NY	Ok, but	\$250.00
Need conductors size on the load side of the 400 amp switch.						
45322	03A0608	Eastern Electric Corp. 425 Lexington Avenue, 3rd Floor New York NY 10017	Requested approval for the electric service equipment proposed to be installed	227 East 45th Street New York NY	Approved	\$250.00

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45323	03A0610	Lippolis Electric, Inc. 445 Fifth Avenue Pelham NY 10803	Requested approval for the electric service equipment proposed to be installed	Salanter Akiba Riverdale H.S. West 259th Street Bronx NY	Denied	\$250.00
<p>1. There are more than 30 conductors in the trough(a barrier can be installed and noted on drawing), the length of the trough and it's location is to be indicated on the drawing. 2. The service bus is undersized. 3. The equipment on the room layout drawing is not marked and Con Edison's point of entry is not shown. 4. Bonding and grounding of the 400 amp service switch is not shown on the drawing. 5. The bonding jumper in the 4000 amp service switch has a neutral link installed(not permitted). 6. The title block on the drawings must show contractors anme and the job location.</p>						
45324	03A0614	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	640 5th Avenue New York NY	Ok, but	\$250.00
<p>1. 2nd 400 amp fuses chanbe to LPN's. 2. Raceway type between 1200 & distribution. 3. Raceway type on Line side of 1200 amp switch.</p>						
45325	03A0600	Windsor Inc. 116-03 Metropolitan Avenue Kew Gardens NY 11418	Requested approval for the electric service equipment proposed to be installed	51-60 Marathon Parkway Queens NY	Approved	\$250.00
<p>.</p>						
45326	03A0601	R.J. Electrical Contractor 201-15 Linden Blvd. St. Albans NY 11412	Requested approval for the electric service equipment proposed to be installed	24 West 40th Street New York NY	Denied	\$250.00
<p>1. The 2000 amp unfused disconnect switch is not permittred as a service switch. 2. Because of the unfused 2000 amp switch there are more than 6 service switches. 3. The location of the end box must be clarified. 4. The wiring method for the service entrance and wire size must be shown on the drawing. 5. Neutral conductors and disconnect link not shown on the drawing. 6. Show bonding and grounding of the service switches. 7. Drawings were not submitted as per the Advisory Board Rules.</p>						
45327	03A0603	Scientific Electric Company, Inc. 900 Edgewater Road Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	Stuyvesant Town Oval New York NY	Denied	\$250.00
<p>1. Service layout does not match the one line diagram. 2. No neutral bond or ground for the service switches are shown on the drawing. 3. Disconnect switch is noted as a service switch. 4. No mechanical ventilation is provided in the service room. 5. Service entrance and service bus are undersized. 6. Service switch #4 drawn backwards on the drawing. 7. Grounding and bonding on the load side of transformer disconnect switch is not shown on the drawing. 8. Special permission is need for service switch #4 to be located in a separate room.</p>						

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45328	03A0606	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	The Rockefeller University 1230 York Avenue New York NY	Denied	\$250.00
1. The second fusing on the load side of the generator distribution switch gear is not shown on the drawing(also must be coordinated). 2. Generator room layout is not provided. 3. Distribution room layout is not provided. 4. Bonding and grounding of the generator is not shown on the drawing(depends on type of transfer switch used 3 or 4 pole).						
45329	----- -----	Loring Consulting Engineers 21 Pennsylvania Plaza New York NY 10001	Requesting permission for a building that is being voluntarily electrically upgraded that has 6 existing traction elevators to confirm that the owner need not comply with Article 27-396-4 of the NYC Building Code that requires a minimum of 3 elevators to simultaneously be powered for the back up generator.	Buchmann Tower 680 Fifth Avenue New York NY	Denied	\$0.00
The New York City Electrical Advisory Board cannot grant permission for your request. You can contact Technical Affairs at the construction unit of the Department of Buildings and the Fire Department for their approvals.						
45330	----- -----	Z.S. Engineering, P.C. 90 Tulip Avenue Floral Park NY 11001	Requesting a variance to allow connection of the dedicated fire alarm ATS to the emergency generator bus for the existing Class E fire alarm and voice communication system.	333 West 34th Street New York NY	Approved	\$0.00
45331	----- --	Edward & Zuck P.C., Consulting Engineer: 315 Park Avenue South New York NY 10010	Requesting permission to power a Class E fuse cutout by tapping feeders on the load side of the generator the circuit lengths would be in excess of 500-1000 feet.	Rockefeller Center 1250 & 1270 6th Ave., 20 W. 50th S New York NY	Hold	\$0.00
More info.						

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45332	-----	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requesting permission on a property listed as one block and lot with 3 separate buildings and supplied by Con-Edison with 2 points of service entry in one building to install a service in each separate building and to run the service entrance conductors underground in Schedule 80 PVC, with all elbows and sutups to be galvanized conduit	450 Kent Avenue Brooklyn NY	Ok	\$0.00
Concept approval only.						
45333	----- ---	Ips 105 Raider Boulevard, Suite 103 Hillsborough NJ 08844	Requesting concept approval of a service room layout with a 4000 amp automatic transfer switch with a front clearance of 4'3".	Clay Park Labs, Inc. 1700 Bathgate Avenue Bronx NY	Denied	\$0.00
The New York City amendments to the 1999 National Electrical Code Section 230-64.b(1) requires at least five feet in front of a switchboard if it is installed in one line.						
45334	----- ---	Mac Electrical Contracting Inc. 6919 8th Avenue Brooklyn NY 11229	Requesting permission to leave as installed one service entrance standpipe that feeds a 2 gang meterpan that supplies power to two one family buildings in 8 locations.	7, 46, 48, 50, 52, 54 and 56 Betty Ct Staten Island NY	Hold	\$0.00
45335	-----	Flemington Electrical Maintenance Inc. 207 West 25th Street-7th Floor New York NY 10001	Requesting permission to leave as installed service entrance conductors that run approximately 35 feet to a 200 amp service swtich located in the rear of the building. The run is installed in EMT 22' above the floor.	474, 480 and 486 Forest Avenue Staten Island NY	Denied	\$0.00
The New York City amendments to the 1999 National Electrical Code Section 230-70.(a) states that the service disconnection means shall be installed at a readily assessable location inside a building or structure nearest the point of entrance of the service conductors.						
45336	-----	Lilker Associates Consulting Engs, P.C. 1001 Avenue of the Americas New York NY 10018	Requesting permission to install 5 lighting circuits that supply power to 4, 400 watt metal halide fixtures on 20 amp circuits instead of 15 amps.	84-40 101st Ave Richmond Hill NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45337	----- -	DiRusso Eeetrical Contracting 63-23 Metropolitan Avenue Middle Village NY 11379	Requesting permission to leave as installed two 1600 amp service in two different locations at the same address.	1255 Scabury Avenue Bronx NY	Approved	\$0.00
With signage.						
45338	-----	MF Electrical Service Co., Inc. 3323 Merritt Avenue Bronx NY 10475	Requesting permission to leave as installed approximately 200 #12 conductors in a 10" x 10" x 12' long trough.	1402 Atlantic Avenue Brooklyn NY	Denied	\$0.00
Section 27-3063.f and Bulletin #142.6 of the old New York City Electrical Code does not permit more than 32 conductors to be installed in a trough and the sum of the cross-sectional areas of all contained conductors shall not exceed twenty percent of the interior cross-sectional area of the wireway, except where splices and taps are made within the gutter.						
45339	----- ---	A/C Electric Inc. 32 Union Square East New York NY 10003	Requesting permission to ground a 30 amp fire alarm cutout by tapping the existing 3/0 ground conductor with a #10 solid ground conductor that terminates to the neutral of the fire alarm cutout.	1 Madison Avenue New York NY	Approved	\$0.00
45340	-----	Northgate Electric Corporation 225 West 34th Street, Suite 901 New York NY 11746	Requesting permission to leave as installed a fire alarm fuse cutout that is powered by tapping the line side of a circuit breaker panel that is fed by a 400 amp service switch.	5435 1st Avenue Brooklyn NY	Denied	\$0.00
The feed that supplies power to the fire alarm Class E fuse cut-out must be tapped on the line side of the 400 amp service switch or from the Con-Ed end box. On a 265/460 volt service, a service switch and meter must be installed ahead of the step down transformer supplying power to the fuse cut-out.						
45341	-----	High-Tech Electrical Services Corp. 36-33 23rd Street Long Island City NY 11106	Requesting permission to install electrical panels in eight electrical closets with 36" clearances between the side of the panel and the front of 460/277 volt 200 amp bus duct switch.	Bank of New York 139 Flatbush Avenue Brooklyn NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45342	----- -	Laser Lite Electrical, Inc. 40 Gaton Street Staten Island NY 10309	Requesting permission not to group together service equipment in a two family building with no common areas.	31 Maxi Court Staten Island NY	Approved	\$0.00
45343	----- --	Plaza Electrical Contractors Inc. 20 Richmond Valley Road Staten Island NY 10309	Requesting permission not to group together service equipment in a two family building with no common areas.	20 Richmond Valley Road Staten Island NY	Approved	\$0.00
45344	----- ---	Laser Lite Electrical, Inc. 40 Gaton Street Staten Island NY 10309	Requesting permission to install plastic approved electrical boxes that will be used with Romex in approximately 500 homes under the old New York City Electrical Code.	----- ----- -----	Approved	\$0.00
45345	03A0641	Thomas & Betts/Lightalarms 8155 T & B Boulevard Memphis TN 38125	Requested approval for use in New York City of your Self-Contained, Emergency Lighting Unit Equipment. Model/Series No. Series RD.	----- ----- -----	Approved	\$75.00
45346	03A0642	Thomas & Betts/Emergi-Lite 8155 T & B Boulevard Memphis NY 38125	Requested approval for use in New York City of your Surface Mounted Emergency Lighting Unit, Self-Powered. Model/Series Nos. 12JSM36-2150-KDS	----- ----- -----	Approved	\$75.00

ADVISORY BOARD CALENDAR

November 19, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45347	03A0643	Thomas & Betts/Emergi-Lite 8155 T & B Boulevard Memphis NY 38125	Requested approval for use in New York City of your Recessed Emergency Lighting Unit, Self-Powered. Model/Series Nos. 12RSM36-2150-KDS.	----- ----- -----	Approved	\$75.00
45348	03A0644	Thomas & Betts/Emergi-Lite 8155 T & B Boulevard Memphis NY 38125	Requested approval for use in New York City of your Surface Mounted Emergency Lighting Unit, Self-Powered. Model/Series Nos. 12LSM110-2150-KDS.	----- ----- -----	Approved	\$75.00
45349	03A0645	Krueger International 1220 Bellevue Street Green Bay WI 54302	Requested approval for use in New York City of your Office Furnishing. Model/Series Nos.: Model True/Volition, Series #TRU and #VOL followed by additional suffixes.	----- ----- -----	Approved	\$75.00
Office Furnishing, Model/Series Nos: Model True/Volition, Series #TRU and #VOL only. The relocatable power taps were withdrawn from your submittal and are not included in this approval.						
45350	03A0646	J.A. Lee Electric Co. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	3511-3515 Barnes Avenue Bronx NY	Approved	\$250.00
45351	03A0647	J.A. Lee Electric Co. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	33-23 Union Street Flushing NY	Approved	\$250.00