

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0142CO2	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	NYC Smilow Emer. Pwr Sys 522 First Avenue New York NY	On Hold	\$0.00
Carryover from August 13, 2014 meeting. 1) Sync board access is not code compliant describe lockout system for generators when accessing rear of board. 2) Provide lighting in rear of sync board.						
52631	14A0332	Twins Electric Corporation 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	542 West 112th Street New York NY	Approved	\$650.00
	14A0397CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	523 East 70th Street New York NY	On Hold	\$0.00
Carry over from August 13, 2014 meeting. Coordination study does not show coordination. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/26/14 Job changed all existing equipment now bubbled as new. Job must be refiled and re-reviewed.						
53146	14A0422CO	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	71 Smith Street Brooklyn NY	Approved	\$0.00
Carry from October 22, 2014 meeting. 1) Fire pump aluminum equipment grounding conductors undersized on load side of service switch. 2) Fire pump emergency feeder not fire rated. 3) Verify whether generator is separately derived or not, F.A. switches bonded and 4 pole ATS used. 4) EGC's for F.A. system undersized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. 4/22/15 Rejected Genset to be bonded and grounded not remote switches. Drawing says no neutral but there are neutrals leaving the genset and switchboard ESS-R-1 is not bonded and grounded. 7/27/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52899	14A0428CO	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	30-19 Crescent Street Queens NY	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) Fire pump emergency feeder underfused, verify MI cable in concrete. 2) Correct voltage to 120/208 on cut sheets. 3) Relocate surge protector for 3" front clearance. 4) ATS-CR-2 overfused. 5) Transformer for elevator secondary length not shown, no secondary protection provided. 6) Verify MI cable installed in concrete for fire pump. 3/30/15 Job finalized This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	14A0430CO	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	204 2nd Avenue New York NY	Rejected	\$0.00
<p>Carry over from October 22, 2014 meeting. Fire pump feeder on emergency side to be taken ahead of main switch on secondary of transformer. 10/30/15 Rejected. 1) Provide details that fire pump tap does not share tap with OCPD. 2) Provide/confirm that fire pump controller is service rated or provide F.P. switch.</p>						
	14A0474CO	Daidone Electric, Inc. 66-02 Central Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	630 1st Avenue New York NY	On Hold	\$0.00
<p>Carry over from October 22, 2014 meeting. Not in Advisory Board format.</p>						
	14A0475CO	Noble Electric Contracting Co. Inc. 1794 Clinton Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	Tallman Islands WPCP 27-01 Powells Cove Blvd. Queens NY	Pending	\$0.00
<p>Carryover from September 10, 2014 meeting. MCC-2 must be suitable for use as service entrance equipment. Show neutral bonding and grounding.</p>						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52743	14A0530CO	Leslu Electric Corp, 118-01 Liberty Avenue, 2nd Floor Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	1234 Broadway New York NY	Approved	\$0.00
Carry over from October 22, 2014 meeting. 1) Verify that the 1000 KVA service room is 2 hour fire rated. 2) Show clearances in front of new equipment. 1/12/15 Rejected. 7' clearance required between front of service switch #3 and service switch #6, show clearance in front of new meter bank on drawings see Section 230.64(B)(1). 1/15/15 Job finalized.						
	14A0538CO	Anthony G. Ferry Inc. 1916 Park Avenue New York NY 10037	Requested approval for the electric service equipment proposed to be installed	One Fifth Avenue New York NY	Pending	\$0.00
Carry over from October 22, 2014 meeting. 11/19/14 Siemen's cuts to show 700A/Sq in for service bus.						
52632	14A0539CO	DeFalco Electric 25-54 22nd Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	140 6th Avenue New York NY	Approved	\$0.00
Carry over October 22, 2014 meeting. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.						
52790	14A0540CO	Prime Light Electrical Construction 245 Eighth Avenue New York NY 10011	Requested approval for the electric service equipment proposed to be installed	180 Central Park South New York NY	Approved	\$0.00
Carry over from October 22, 2014 meeting. 1) Add another egress door on other side of the room or comply with 110.26(c)(2)(B). 2) Verify that individual sets of conductor are bundled together in the wireway feeding the new board. 3/4/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/21/15 Swapped A and C-Rev-2s, B-Rev-1. 8/17/15 Swapped drawings A and C, Revision 3; B-Revision 2.						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52863	14A0541CO	Lilker Associates Consulting Engs. PC 1001 Avenue of the Americas New York NY 10018	Requested approval for the electric service equipment proposed to be installed	1776 Broadway New York NY	Approved	\$0.00
Carry over from October 22, 2014 meeting. 1) Show fuse types in existing distribution board 1. 2) Verify RHH conductor to future fire pump service switch. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/25/16 Swapped drawing A-Revision 1 and Drawing C-Revision 2.						
	14A0542	MSR Electrical Construction 31 Bay Street Brooklyn NY 11231	Requesting permission to install IEEE 1580 Type P MOR Polyrad XT-125 armored and sheathed multi-conductor cable in a Class 1, division 1 environment, Wards Island sewage treatment plant.	7 Wards Island Manhattan NY	Denied	\$0.00
52616	14A0548	Irwin Associates 247 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	555 5th Avenue New York NY	Approved	\$650.00
OR						
52793	14A0550CO	M.C. Electrical NY, Inc. 835 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	75 Ninth Avenue New York NY	Approved	\$0.00
7/23/15 Swapped FP40-01-Revision 2; 9/14/15 Swapped drawing FP40-01-Revision 3; 12/18/15 Swapped drawing FP40-1-Revision 4. 3/28/16 Swapped drawing FP40-01-Revision 6-Last swap.						
52866	14A0554CO	Discover Electric Inc. 58-10 58th Place Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	1501 Pitkin Avenue Brooklyn NY	Approved	\$0.00
Carry over from October 22, 2014 meeting. Equipment grounding conductors undersized. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52633	14A0555CO	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 11101	Requested approval for the electric service equipment proposed to be installed	Olympic Tower 641 Fifth Avenue New York NY	Approved	\$0.00
Carry over from October 22, 2014 meeting. 1/19/16 Swapped drawings AB40-1, Revision 1 and SB40-3, Revision 2.						
	14A0556	Striano Electric Co., Inc. 246 Park Avenue Garden City Park NY 11040	Requested approval for the electric service equipment proposed to be installed	NYU-Hayden Hall 33 Washington Square West New York NY	Rejected	\$650.00
8/26/15 Verify that PVC conduits are concrete encased.						
	14A0563	Hatzel & Buehler, Inc. 230 Park Avenue, Suite 925 New York NY 10169	Requested approval for the electric service equipment proposed to be installed	AT & T 1114 6th Avenue New York NY	Rejected	\$650.00
OR 4/20/15 Rejected. Approval 52615 is to change fuses for one 400A switch in existing switchboard #3. New revised drawings are for a new switchboard #4 which requires a new submission and approval number.						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53015	14A0566	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	133 Greenwich Street New York NY	Approved	\$650.00
<p>1) Show feeders to bus duct. 2) Verify sets of conductors from transformer secondary to fire pump ATS. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3) Transformer T-3 should be 480V Delta-208Y/120V. 4) Transformer F.A. requires secondary OCPD. 5) Confirm closing rating for primary switch of transformer T-1 adequate for inrush. 4/24/15 Item #1 partially removed, Explain 4 sets of 4-750 and 1 600 KCM ground in 8-4" conduits. 4/30/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52612	14A0569	J.A. Lee Electric, Inc. 23-55 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	85 East End Avenue New York NY	Approved	\$650.00
OR						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0570	J.A. Lee Electric, Inc. 23-55 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	154-18 Cross Island Park Queens NY	Administrative Closure	\$650.00
<p>1) Roll up generator to comply with Section 700.6(G). With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Confirm generator grounding. 3) Show ratings of existing ATS(4000A?). 5/25/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/20/16 This job is void in lieu of Cal. #54287, Submission #16A0953</p>						
52637	14A0579CO	Intelogic Electric, Inc. 254 40th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	38 West 32nd Street New York NY	Approved	\$0.00
Carry over from October 22, 2014 meeting.						
52747	14A0584CO	Dynamic Electrical Contractors Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	215 East 64th Street New York NY	Approved	\$0.00
Carry over from October 22, 2014 meeting. 1) General notes not on drawing. 2) Signage to be provided on each service door indicating where the other service is located. 3) Incoming fault current not shown. 4) Show tap detail in trough. 2/2/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/21/15 Swapped drawing 1 of 1, Revision 2.						
52858	14A0586CO	Horsepower Electric 188 21st Street, 2nd Floor Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	443 Greenwich Street New York NY	Approved	\$0.00
Carry over October 22, 2014 meeting. Show wiring method from 1600 amp service switch to distribution panel. 3/23/15/ Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/25/16 Swapped drawings 1,2 and 3-Revision 2.						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0587CO	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Fordham Law School 150 West 62nd Street New York NY	Rejected	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) Verify compliance with 445.13. 2) Verify feeder size to 75 KVA step up transformer and transformer is in same room as fire pump With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/30/15 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/21/15 Rejected. 1) 300 KW transformer overfused. 2) 3 sets 750 to AP-10A overfused.</p>						
52635	14A0588CO	Jeco Electric 1162 Intervale Avenue Bronx NY 10459	Requested approval for the electric service equipment proposed to be installed	899 Westchester Avenue Bronx NY	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting,. 4/18/16 Swapped drawing 1-Revision 3.</p>						
53004	14A0591CO	GRX Euro Electric Corp. 18-02 26th Road Astora NY 11102	Requested approval for the electric service equipment proposed to be installed	555 Bergen Avenue Bronx NY	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) Fire pump feeder to be fire rated, fire pump service switch to be grounded and bonded. 2) Service switches 5 and 6 to be ground. 3) Verify that fuse in 100 amp disconnect switches are FRN's. 4) Service switches 2,3 and 4 overfused. 5) Service entrance conductors to service switches 2,3 and 4 undersized. 6) Provide supplemental ground in service switch #2. 7) Show coordination between service #2 and 2nd fusings. 4/29/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0593CO	Tritech Electrical & Data Inc. 4288 Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	401 First Avenue New York NY	Pending	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) SA equipment blocking doorway. 2) Show front of fire pump switch. 3) Emergency fire alarm switch bonded and grounded on new separately derived system. Confirm gen grounding. 4) Emergency fire pump feeder overfused, conductors on load side of ATS undersized, EGC undersized, not fire rated, fire pump normal feeder overfused. 5) Generator frame not grounded. 6) Equipment grounding conductors on load side of retail trough undersized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7) Indicate chosen gen manufacturer.</p>						
52636	14A0595CO	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	55 Prospect Street Brooklyn NY	Approved	\$0.00
Carry over from October 22, 2014 meeting.						
52860	14A0597CO	QEC Electrical Service Corp. 31-10 37th Avenue, Suite 500 Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	30-30 Northern Blvd, Queens NY	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. Verify vertical bus sizes supplying 1200 amp disconnect switches on main board. 3/23/15 Submitted one additional plan (one copy) for equipment elev. That was not in original set ACS-D-11739-4. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/21/16 Swapped drawings 1, 2 and 3-Revision</p>						
	14A0598CO	Verde Electric Corp. 811 Whittier Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	Christies Fine Art 62 Imlay Street Brooklyn NY	On Hold	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) Provide recommission documentation from original manufacturers of the electrical equipment that was relocated. 2) Verify who will be installing the service entrance conductors. 3) Explain splice chambers. 4) Show clearances at transformer termination compartments. 5) Show concrete encasement for service cables.</p>						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52638	14A0599CO	Electrical Specialty Enterprises Inc. 1122 Coney Island Avenue Brooklyn NY 11230	Requested approval for the electric service equipment proposed to be installed	1 Bay Street Staten Island NY	Approved	\$0.00
Carry over from October 22, 2014 meeting.						
	14A0600	Enterprise Electrical Systems, Inc. 502 Coney Island Avenue Brooklyn NY 11218	Requesting permission to leave as installed a 2 family building where the basement common areas branch circuits are supplied from an individual dwelling unit.	292 Sackett Street Brooklyn NY	On Hold	\$350.00
Pending further information						
	14A0601	Enterprise Electrical Systems, Inc. 502 Coney Island Avenue Brooklyn NY 11218	Requesting permission to leave as installed a 2 family building where the basement common areas branch circuits are supplied from an individual dwelling unit.	294 Sackett Street Brooklyn NY	On Hold	\$350.00
Pending further information						
	14A0602	Enterprise Electrical Systems, Inc. 502 Coney Island Avenue Brooklyn NY 11218	Requesting permission to leave as installed a 2 family building where the basement common areas branch circuits are supplied from an individual dwelling unit.	296 Sackett Street Brooklyn NY	On Hold	\$350.00
Pending further information						
	14A0603	Enterprise Electrical Systems, Inc. 502 Coney Island Avenue Brooklyn NY 11218	Requesting permission to leave as installed a 2 family building where the basement common areas branch circuits are supplied from an individual dwelling unit.	298 Sackett Street Brooklyn NY	On Hold	\$350.00
Pending further information						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0604CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University Morningside Campus New York NY	On Hold	\$0.00
Carry over from October 22, 2014 meeting. 1) 1-Line drawing not in Advisory Board format. 2) Cut sheets of equipment not provided.						
52746	14A0605CO	Roma Electric Corp. 30-75 14th Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	393 West End Avenue New York NY	Approved	\$650.00
Carry over from October 22, 2014 meeting. 1) Line and load side of bus feeding 2500 amp service switch undersized. 2) Verify feeder size to F.A. switch #10 or #8. 3) Provide Siemens cuts showing proper bus sizing. 2/2/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52639	14A0606	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	90 Park Avenue New York NY	Approved	\$650.00
52640	14A0607CO	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	50 North Fifth Street Brooklyn NY	Approved	\$0.00
Carry over from October 22, 2014 meeting						
52613	14A0608	Hatzel & Buehler, Inc. 230 Park Avenue, Suite 925 New York NY 10169	Requested approval for the electric service equipment proposed to be installed	AT & T 350 5th Avenue New York NY	Approved	\$650.00
OR 4/29/15 Swapped Revision 1.						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52789	14A0609	J.A. Lee Electric, Inc. 23-55 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	450 West 15th Street New York NY	Approved	\$650.00
Verify 2500 amp fuses in 2000 amp service switch #2. 3/4/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52785	14A0610	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Governor's Island New York NY	Approved	\$650.00
1) Short circuit coordination study requires PE stamp. 2) Correlate breaker designations on 1-Line and sequence of operation documentation breaker positions (No/Nc) should be shown in normal operating conditions. 3/4/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52787	14A0612	I.P. Electrical Inc. 143 30th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	321 West 35th Street New York NY	Approved	\$650.00
<p>Fire pump emergency feeders not fire rated and underfuses. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/4/15 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52619	14A0614	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	12-16 43rd Avenue Queens NY	Approved	\$650.00
OR						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52620	14A0615	MWB Electric Corp. 64-32 Admiral Avenue Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	1155 Park Avenue New York NY	Approved	\$650.00
OR						
	14A0617	Nunez Electric, Inc. 32-14 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	John Jay College-Haaren Hall 899 10th Avenue New York NY	Pending	\$650.00
OR 1) Verify feeder sets supplying switchboard MS-C. 2) Section bus size not shown in MS-C where retro fit was made.						
52917	14A0622CO	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	111 East 48th Street New York NY	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) Verify height of overhead pull box in service room. 2) Verify that MI cables do not have transition boxes and feed equipment directly. With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/30/15 Job finalized. With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52641	14A0623CO	Prince Electrical Contracting Corp. 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	180 Ludlow Street New York NY	Approved	\$650.00
Carry over from October 22, 2014 meeting.						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52844	14A0625	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	43-25 Hunter Street Long Island City NY	Approved	\$650.00
<p>1) Service end box "A" not shown in electrical service room "B", A1 drawing. 2) Vertical bus in DPL-2A undersized, Drawing A1. 3) Verify amount of sets feeding split panel DPH-2A, Drawing A1. 4) Secondary of transform not protected for roof fire pump, Drawing A1. 5) Provide reduced neutral calculations for meter bank feeders Drawing A1. 6) Verify 10' taps out of retail trough Drawing A1. 7) Explain disconnect switch ahead of fire alarm transformer show length of secondary conductors, Drawing B1. 8) Fire alarm transformer secondary bonded in 2 locations, Drawing B1. 9) Service A neutral link installed on line side of main bonding jumper. 10) Feeders to TDP-2B are overfused, Drawing C1. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/20/15 With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53189	14A0626	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU 383 Lafayette Street New York NY	Approved	\$650.00
<p>Camlock connection to comply with Section 700.6(G). 8/18/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52642	14A0628	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	9901 34th Avenue Queens NY	Approved	\$650.00
<p>With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
52643	14A0629	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	143-10 101st Avenue Queens NY	Approved	\$650.00
<p>With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/25/15 Swapped Drawings 1 and 2, Rev 1s.</p>						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52857	14A0630	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	41 East 22nd Street New York NY	Approved	\$650.00
<p>1) Tapped conductors feeding 600 amp fused disconnect switch undersized. 2) Step up transformers overfused. 3) Feeder size from service switch #1 to HDE-LV-SC not shown. 4) Verify that low in rush transformers are being installed. With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 3/23/15 with the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/23/15 Job finalized. With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Fire Rated Enclosure’s must comply with the following:                      1. A P.E. or R.A. must file a PW1 as an AIT 3.                      2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52861	14A0631	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	180 Myrtle Avenue Brooklyn NY	Approved	\$650.00
<p>Service neutral conductor taps to be on utility side of neutral disconnect link. With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/23/15 Job finalized. With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52617	14A0634	CHT Electric Corp. 922 East 233rd Street Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	111 Nassau Street New York NY	Approved	\$650.00
OR 12/17/15 Swapped Drawing 1-Revision 1.						
52883	14A0638	Einstein Electrical Corporation 42-16 28th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	Birchwood Apartments 102-10 66th Road Queens NY	Approved	\$650.00
<p>1) Provide listing report from the NRTL for cogen and inverter systems. 2) 1/0 fused at 200 amps from inverter to cogen disconnect switch. 3) Show type of transformer being used and bonding and grounding of it. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/10/15 Swapped Drawing 1-Revision 2.</p>						
52644	14A0639	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1221 6th Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52905	14A0641	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	221 West 29th Street New York NY	Approved	\$650.00
<p>Provide available short circuit current at breaker panel locations With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52891	14A0642	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	33-25 Washington Square West New York NY	Approved	\$650.00
<p>1) Where is new tap being made from, existing board not shown, is it in another building. Show on 1-line. 2) Incoming fault current not shown. 3) Listing documentation for transformer not provided UL listed per cut sheet. 4) Substation not mechanically ventilated. 5) Bus undersized on load side of 1000 KVA transformer. 3/25/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/24/15 Swapped Drawing 1, Revision 2. 5/18/16 Swapped drawing 1-Revision 3</p>						
52862	14A0643	LoBello Electric Installation Corp. 3150 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	1211 Madison Avenue New York NY	Approved	\$650.00
<p>1) Show coordination between 1200 amp fuses and circuit breakers. 2) Show short circuit current at panel and type of breakers. 3) Incoming fault current not shown 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52621	14A0644	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	New York Life Insurance Co. 51 Madison Avenue New York NY	Approved	\$650.00
<p>OR 10/6/15 Swapped drawings A and B, Revision 1s.</p>						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52645	14A0645	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	522 Fifth Avenue New York NY	Approved	\$650.00
52646	14A0646	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	225 Liberty Street New York NY	Approved	\$650.00
52647	14A0648	Allstate Electric Corp. 555 Eighth Avenue, Suite 809 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	225 Liberty Street New York NY	Approved	\$650.00
52842	14A0649	M.C. Electrical NY Inc. 843 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	SL Green 10 East 53rd Street New York NY	Approved	\$650.00
Service bus undersized in switchboard SS-C. 3/20/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53053	14A0650	EDM Electric, Inc. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Ronald McDonald House of NY 405 East 73rd Street New York NY	Approved	\$650.00
1) Provide listing documentation for cogen unit as complete assembly from a NRTL. 2) Transformer T-1 secondary bonded at 2 location. 3) Equipment grounding conductors undersized from generators to transformer T-1. 4) Verify that service room is mechanically ventilated. 5) Discrepancy of address between drawign and letter(73rd/76th?) 6) Verify code clearance between new pullbox and new wireway. 5/28/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0651	Merit Electrical Corp. 161 21st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	2008 Broadway New York NY	On Hold	\$650.00
1) Drawing not in Advisory Board format. 2) Short circuit to be performed by a PE bearing the stamp. 12/1/14 Rejected 1) line does not show bonding and grounding of service equipment. 2) Cut sheet of new panel not provided. 3) Item #2 not addressed.						
52878	14A0652	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	11 Times Square New York NY	Approved	\$650.00
1) Show 3rd level breaker on coordination curve. Verify coordinate with downstream 600A breaker. 2) Verify CT cabinet spec. 298/377. Both shown on drawings. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/4/15 Swapped Drawing 1, Revision 2						
52879	14A0653	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	925 Hunts Point Avenue Bronx NY	Approved	\$650.00
1) SSW-2 1 Line does not match physical. 2) Show fuse types in Trans S switches. 3) Line side F.A. tap undersized. Provide EGC on load side load side conductors undersized. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/27/16 Swapped drawing 1 and 2-Revision 2.						
53201	14A0654	Falco Electrical Services, Inc. 2220 Voorhies Avenue Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	321 Rider Avenue Bronx NY	Approved	\$650.00
1) Verify that dedicated service room is 2 hour fire rated. 2) Confirm closing rating of transformer primary switch is adequate for transformer inrush. 8/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/30/15 Swapped 1and 2, Revision 2s.						
52614	14A0655	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue New York NY	Approved	\$650.00
OR						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0656	Highline Electric Corp. 168-01 Rockaway Blvd. Jamaica NY 11434	Requested approval for the electric service equipment proposed to be installed	1736 Bathgate Avenue Bronx NY	Rejected	\$650.00
1) 1 Line does not match physical. 2) Service bus feeding 2000 and 1200 amp service switches undersized. 3) Show bus size feeding service switch #2. 4) Show size of through bus on load side of service switch #2 and section bus sizes. 5) Siemens cut to show proper bus sizes. 3/4/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/17/14 Rejected Contractor's name can't be changed on submittals, Refiling required by new contractor.						
	14A0657	OM Electric, Inc. 262 West 38th Street, Suite 1202 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	189 Berry Street Brooklyn NY	Administrative Closure	\$650.00
See Cal. #53161.						
52649	14A0658	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	50 Rockefeller Center New York NY	Approved	\$650.00
52650	14A0659	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Industry City, Building #19 168 39th Street Brooklyn NY	Approved	\$650.00
52622	14A0660	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	345 East 69th Street New York NY	Approved	\$650.00
OR 4/21/15 Swapped Revision 1.						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52651	14A0661	G. Poulakis Electrical Contracting, Inc. 23-82 Brooklyn Queens Expressway Long Island City NY 11103	Requested approval for the electric service equipment proposed to be installed	30-40 21st Street Queens NY	Approved	\$650.00
2/17/16 Swapped drawing 1, Revision 1.						
52652	14A0662	Jeco Electrical Service Corp. 1162 Intervale Avenue Bronx NY 10459	Requested approval for the electric service equipment proposed to be installed	2950-2960-2970 W. 24th St. Brooklyn NY	Approved	\$650.00
1/19/16 Swapped drawings 1,2 and 3-Revision 1s. 4/18/16 Swapped drawing 1,2 and 3-Revision 2s.						
52624	14A0663	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	900 Main Street New York NY	Approved	\$650.00
OR						
52623	14A0666	Dynamic Electrical Contractors 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Kennedy School 2212 3rd Avenue New York NY	Approved	\$650.00
OR 10/25/16 Swapped drawing 1-Revision 1.						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52918	14A0667	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	252 East 57th Street New York NY	Approved	\$650.00
<p>1) Fire alarm not connected to generator. Show gen on 1-Line With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Provide barrier to block access to rear of service switchboard. 3/30/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Provide barrier to block access to rear of service switchboard. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52653	14A0668	Approved Electric Corp. 3550 White Plains Road Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	1700 York Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53190	14A0669	A to Z Electl Maint. & Service Corp. 307 Seventh Avenue, Suite 403 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	781 5th Avenue New York NY	Approved	\$650.00
<p>1) Show normal feed to new 400 ATS for phone room panel. 2) Feeders on load side of generator overfused With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Fire Rated Enclosure's must comply with the following:</p> <p>1. A P.E. or R.A. must file a PW1 as an ALT 3.</p> <p>2. A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.</p> <p>3. The fire proofing must be performed by a certified fire proofing installer. 6/19/15 Rejected. Verify front clearance for F.A. disconnect(emerg). 8/18/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52618	14A0674	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	AT & T DAS 245 Park Avenue New York NY	Approved	\$650.00
OR						

# ADVISORY BOARD CALENDAR

**November 19, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52792	14A0679	E D Electrical Inc. 5402 7th Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	46 Nevins Street Brooklyn NY	Approved	\$650.00
<p>1) Verify 3' clearance in front of MP IDP. 2) Show size of main bonding jumper With the stipulation: With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3) FDNY requires EGC's in F.A. circuits. 3/4/15 With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/20/16 Swapped drawing 1-Revision 3.</p>						