

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0142CO2	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carryover from August 13, 2014 meeting. 1) Sync board access is not code compliant describe lockout system for generators when accessing rear of board. 2) Provide lighting in rear of sync board.				
52631	14A0332	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
	14A0397CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
<p>Carry over from August 13, 2014 meeting. Coordination study does not show coordination. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/26/14 Job changed all existing equipment now bubbled as new. Job must be refiled and re-reviewed.</p>				
53146	14A0422CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry from October 22, 2014 meeting. 1) Fire pump aluminum equipment grounding conductors undersized on load side of service switch. 2) Fire pump emergency feeder not fire rated. 3) Verify whether generator is separately derived or not, F.A. switches bonded and 4 pole ATS used. 4) EGC's for F.A. system undersized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. 4/22/15 Rejected Genset to be bonded and grounded not remote switches, Drawing says no neutral but there are neutrals leaving the genset and switchboard ESS-R-1 is not bonded and grounded. 7/27/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/25/17 - swap dwg 1 of 2 & 2 of 2 rev 3 3/22/18 - Swap dwg with Rev 4</p>				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52899	14A0428CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) Fire pump emergency feeder underfused, verify MI cable in concrete. 2) Correct voltage to 120/208 on cut sheets. 3) Relocate surge protector for 3" front clearance. 4) ATS-CR-2 overfused. 5) Transformer for elevator secondary length not shown, no secondary protection provided. 6) Verify MI cable installed in concrete for fire pump. 3/30/15 Job finalized This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/27/17 - swap dwg AB50 1 of 2 rev 4, SB50 1 of 1 rev 6</p>				
54744	14A0430CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. Fire pump feeder on emergency side to be taken ahead of main switch on secondary of transformer. 10/30/15 Rejected. 1) Provide details that fire pump tap does not share tap with OCPD. 2) Provide/confirm that fire pump controller is service rated or provide F.P. switch. 9/14/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	14A0474CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
<p>Carry over from October 22, 2014 meeting. Not in Advisory Board format.</p>				
	14A0475CO	Requested approval for the electric service equipment proposed to be installed	Pending	\$0.00
<p>Carryover from September 10, 2014 meeting. MCC-2 must be suitable for use as service entrance equipment. Show neutral bonding and grounding.</p>				
52743	14A0530CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) Verify that the 1000 KVA service room is 2 hour fire rated. 2) Show clearances in front of new equipment. 1/12/15 Rejected. 7' clearance required between front of service switch #3 and service switch #6, show clearance in front of new meter bank on drawings see Section 230.64(B)(1). 1/15/15 Job finalized.</p>				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0538CO	Requested approval for the electric service equipment proposed to be installed	Pending	\$0.00
Carry over from October 22, 2014 meeting. 11/19/14 Siemen's cuts to show 700A/Sq in for service bus.				
52632	14A0539CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over October 22, 2014 meeting. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.				
52790	14A0540CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 22, 2014 meeting. 1) Add another egress door on other side of the room or comply with 110.26(c)(2)(B). 2) Verify that individual sets of conductor are bundled together in the wireway feeding the new board. 3/4/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/21/15 Swapped A and C-Rev-2s, B-Rev-1. 8/17/15 Swapped drawings A and C, Revision 3; B-Revision 2.				
52863	14A0541CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 22, 2014 meeting. 1) Show fuse types in existing distribution board 1. 2) Verify RHH conductor to future fire pump service switch. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/25/16 Swapped drawing A-Revision 1 and Drawing C-Revision 2. 12/5/19 Swap Dwg # D-1410-25956-A Rev 2 and -C Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
	14A0542	Requesting permission to install IEEE 1580 Type P MOR Polyrad XT-125 armored and sheathed multi-conductor cable in a Class 1, division 1 environment, Wards Island sewage treatment plant.	Denied	\$0.00

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52616	14A0548	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				
52793	14A0550CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
7/23/15 Swapped FP40-01-Revision 2; 9/14/15 Swapped drawing FP40-01-Revision 3; 12/18/15 Swapped drawing FP40-1-Revision 4. 3/28/16 Swapped drawing FP40-01-Revision 6-Last swap.				
52866	14A0554CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 22, 2014 meeting. Equipment grounding conductors undersized. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52633	14A0555CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 22, 2014 meeting. 1/19/16 Swapped drawings AB40-1, Revision 1 and SB40-3, Revision 2.				
	14A0556	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
8/26/15 Verify that PVC conduits are concrete encased.				
	14A0563	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
OR 4/20/15 Rejected. Approval 52615 is to change fuses for one 400A switch in existing switchboard #3. New revised drawings are for a new switchboard #4 which requires a new submission and approval number.				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
53015	14A0566	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show feeders to bus duct. 2) Verify sets of conductors from transformer secondary to fire pump ATS. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3) Transformer T-3 should be 480V Delta-208Y/120V. 4) Transformer F.A. requires secondary OCPD. 5) Confirm closing rating for primary switch of transformer T-1 adequate for inrush. 4/24/15 Item #1 partially removed, Explain 4 sets of 4-750 and 1 600 KCM ground in 8-4" conduits. 4/30/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/2/2017 - 1) Emergency feeder for fire pump (1 suhp) required 2hr fire rated. 2) emergency & normal fire pump (40hp) feeder required 2hr fire rated. 3) verify number of sets feeding future retail ss at 28th floor. 5/23/17 - 1) item # 2 is partially addressed. 6/22/17 - swap dwg A,B rev 4 8/31/17 - swap dwg with rev 4A 9/29/17 - SWAP DWG REV 4A REVISED</p>				
52612	14A0569	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0570	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
<p>1) Roll up generator to comply with Section 700.6(G). With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Confirm generator grounding. 3) Show ratings of existing ATS(4000A?). 5/25/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/20/16 This job is void in lieu of Cal. #54287, Submission #16A0953</p>				
52637	14A0579CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 22, 2014 meeting.				
52747	14A0584CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 22, 2014 meeting. 1) General notes not on drawing. 2) Signage to be provided on each service door indicating where the other service is located. 3) Incoming fault current not shown. 4) Show tap detail in trough. 2/2/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/21/15 Swapped drawing 1 of 1, Revision 2.				
52858	14A0586CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over October 22, 2014 meeting. Show wiring method from 1600 amp service switch to distribution panel. 3/23/15/ Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/25/16 Swapped drawings 1,2 and 3-Revision 2.				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0587CO	Requested approval for the electric service equipment proposed to be installed	Rejected	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) Verify compliance with 445.13. 2) Verify feeder size to 75 KVA step up transformer and transformer is in same room as fire pump With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/30/15 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/21/15 Rejected. 1) 300 KW transformer overfused. 2) 3 sets 750 to AP-10A overfused.</p>				
52635	14A0588CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting,. 4/18/16 Swapped drawing 1-Revision 3.</p>				
53004	14A0591CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) Fire pump feeder to be fire rated, fire pump service switch to be grounded and bonded. 2) Service switches 5 and 6 to be ground. 3) Verify that fuse in 100 amp disconnect switches are FRN's. 4) Service switches 2,3 and 4 overfused. 5) Service entrance conductors to service switches 2,3 and 4 undersized. 6) Provide supplemental ground in service switch #2. 7) Show coordination between service #2 and 2nd fusings. 4/29/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0593CO	Requested approval for the electric service equipment proposed to be installed	Pending	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) SA equipment blocking doorway. 2) Show front of fire pump switch. 3) Emergency fire alarm switch bonded and grounded on new separately derived system. Confirm gen grounding. 4) Emergency fire pump feeder overfused, conductors on load side of ATS undersized, EGC undersized, not fire rated, fire pump normal feeder overfused. 5) Generator frame not grounded. 6) Equipment grounding conductors on load side of retail trough undersized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7) Indicate chosen gen manufacturer.</p>				
52636	14A0595CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 22, 2014 meeting.				
52860	14A0597CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. Verify vertical bus sizes supplying 1200 amp disconnect switches on main board. 3/23/15 Submitted one additional plan (one copy) for equipment elev. That was not in original set ACS-D-11739-4. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/21/16 Swapped drawings 1, 2 and 3-Revision. 1/10/19 Swpa dwg 1,2 & 3-Revision 5 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 12/31/19 Swap Dwgs 1, 2 & 3 rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0598CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carry over from October 22, 2014 meeting. 1) Provide recommission documentation from original manufacturers of the electrical equipment that was relocated. 2) Verify who will be installing the service entrance conductors. 3) Explain splice chambers. 4) Show clearances at transformer termination compartments. 5) Show concrete encasement for service cables.				
52638	14A0599CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 22, 2014 meeting.				
	14A0600	Requesting permission to leave as installed a 2 family building where the basement common areas branch circuits are supplied from an individual dwelling unit.	On Hold	\$350.00
Pending further information				
	14A0601	Requesting permission to leave as installed a 2 family building where the basement common areas branch circuits are supplied from an individual dwelling unit.	On Hold	\$350.00
Pending further information				
	14A0602	Requesting permission to leave as installed a 2 family building where the basement common areas branch circuits are supplied from an individual dwelling unit.	On Hold	\$350.00
Pending further information				
	14A0603	Requesting permission to leave as installed a 2 family building where the basement common areas branch circuits are supplied from an individual dwelling unit.	On Hold	\$350.00
Pending further information				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0604CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carry over from October 22, 2014 meeting. 1) 1-Line drawing not in Advisory Board format. 2) Cut sheets of equipment not provided.				
52746	14A0605CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Carry over from October 22, 2014 meeting. 1) Line and load side of bus feeding 2500 amp service switch undersized. 2) Verify feeder size to F.A. switch #10 or #8. 3) Provide Siemens cuts showing proper bus sizing. 2/2/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/24/18 - swap dwg # 1 of 2, 2 of 2 Rev 2				
52639	14A0606	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
52640	14A0607CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 22, 2014 meeting				
52613	14A0608	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 4/29/15 Swapped Revision 1.				
52789	14A0609	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify 2500 amp fuses in 2000 amp service switch #2. 3/4/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52785	14A0610	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Short circuit coordination study requires PE stamp. 2) Correlate breaker designations on 1-Line and sequence of operation documentation breaker positions (No/Nc) should be shown in normal operating conditions. 3/4/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/21/17 - swap dwg 2 of 3 rev 1</p>				
52787	14A0612	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Fire pump emergency feeders not fire rated and underfuses. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/4/15 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52619	14A0614	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				
52620	14A0615	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0617	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
OR 1) Verify feeder sets supplying switchboard MS-C. 2) Section bus size not shown in MS-C where retro fit was made.				
52917	14A0622CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. 1) Verify height of overhead pull box in service room. 2) Verify that MI cables do not have transition boxes and feed equipment directly. With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/30/15 Job finalized. With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized “Nationally Recognized Testing Laboratory” (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52641	14A0623CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Carry over from October 22, 2014 meeting.				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52844	14A0625	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Service end box "A" not shown in electrical service room "B", A1 drawing. 2) Vertical bus in DPL-2A undersized, Drawing A1. 3) Verify amount of sets feeding split panel DPH-2A, Drawing A1. 4) Secondary of transform not protected for roof fire pump, Drawing A1. 5) Provide reduced neutral calculations for meter bank feeders Drawing A1. 6) Verify 10' taps out of retail trough Drawing A1. 7) Explain disconnect switch ahead of fire alarm transformer show length of secondary conductors, Drawing B1. 8) Fire alarm transformer secondary bonded in 2 locations, Drawing B1. 9) Service A neutral link installed on line side of main bonding jumper. 10) Feeders to TDP-2B are overfused, Drawing C1. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/20/15 With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/14/2017 - swap dwg A1 rev 2, b rev 1, b1 rev 2, c rev 2, c1 rev 2. D rev 4. E rev 3 5/2/18 - swap dwg A1 - rev 3, dwg D - Rev 5</p>				
53189	14A0626	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Camlock connection to comply with Section 700.6(G). 8/18/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/15/2020 Swap drawings # A Rev # 5, #B Rev # 3 and #C Rev #4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52642	14A0628	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/5/18 - Swap dwg with Rev 1</p>				
52643	14A0629	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/25/15 Swapped Drawings 1 and 2, Rev 1s. 3/7/18 - swap dwg with Rev 2. 12/6/18 Swap dwg #1 and 2-Revision 3.</p>				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52857	14A0630	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Tapped conductors feeding 600 amp fused disconnect switch undersized. 2) Step up transformers overfused. 3) Feeder size from service switch #1 to HDE-LV-SC not shown. 4) Verify that low in rush transformers are being installed. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 3/23/15 with the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/23/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 3/23/15 with the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/17/2017 - comply section 230.64 (B) for fire alarm and time warner ss#1 and maintain 5' working clearance. 8/22/17 - swap dwg # A Rev 5, #B Rev 2, #C Rev 1, # D Rev 4, #E Rev 6. 4/29/2021 Amended Plan # A Rev- 6 and # E Rev-7.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52861	14A0631	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Service neutral conductor taps to be on utility side of neutral disconnect link. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/23/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/30/17 1) Changes made on drawing are not identified. 2) 4000A CT as per one line. 3/15/17 - swap dwg 1&2 rev 3</p>				
52617	14A0634	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 12/17/15 Swapped Drawing 1-Revision 1.				
52883	14A0638	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide listing report from the NRTL for cogen and inverter systems. 2) 1/0 fused at 200 amps from inverter to cogen disconnect switch. 3) Show type of transformer being used and bonding and grounding of it. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/10/15 Swapped Drawing 1-Revision 2.				
52644	14A0639	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/2/2020. Swap dwg # AB40-1 of 1-Revision 1; AB41-1 of 1-Revision 1; SB41-01 of 1-Revision 1; SB40-2 of 3-Revision 1; FP40-1-Revision 3 and AB42-1 of 1-Revision . Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52905	14A0641	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Provide available short circuit current at breaker panel locations With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52891	14A0642	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Where is new tap being made from, existing board not shown, is it in another building. Show on 1-line. 2) Incoming fault current not shown. 3) Listing documentation for transformer not provided UL listed per cut sheet. 4) Substation not mechanically ventilated. 5) Bus undersized on load side of 1000 KVA transformer. 3/25/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/24/15 Swapped Drawing 1, Revision 2. 5/18/16 Swapped drawing 1-Revision 3</p>				
52862	14A0643	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show coordination between 1200 amp fuses and circuit breakers. 2) Show short circuit current at panel and type of breakers. 3) Incoming fault current not shown 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52621	14A0644	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 10/6/15 Swapped drawings A and B, Revision 1s.</p>				
52645	14A0645	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52646	14A0646	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
52647	14A0648	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
52842	14A0649	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Service bus undersized in switchboard SS-C. 3/20/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53053	14A0650	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide listing documentation for cogen unit as complete assembly from a NRTL. 2) Transformer T-1 secondary bonded at 2 location. 3) Equipment grounding conductors undersized from generators to transformer T-1. 4) Verify that service room is mechanically ventilated. 5) Discrepancy of address between drawign and letter(73rd/76th?) 6) Verify code clearance between new pullbox and new wireway. 5/28/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 5/5/17 - swap dwg 35 AB Rev 2				
	14A0651	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Drawing not in Advisory Board format. 2) Short circuit to be performed by a PE bearing the stamp. 12/1/14 Rejected 1) line does not show bondin and grounding of service equipment. 2) Cut sheet of new panel not provided. 3) Item #2 not addressed.				
52878	14A0652	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Show 3rd level breaker on coordination curve. Verify coordinate with downstream 600A breaker. 2) Verify CT cabinet spec. 298/377. Both shown on drawings. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/4/15 Swapped Drawing 1, Revision 2				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
	14A0653	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
<p>1) SSW-2 1 Line does not match physical. 2) Show fuse types in Trans S switches. 3) Line side F.A. tap undersized. Provide EGC on load side load side conductors undersized. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/27/16 Swapped drawing 1 and 2-Revision 2. 2/27/17 - 1. Comply with the section 110.26 (A) & (E) for 30A switches 3/24/2017 - Comment 1 is not address. Comply section 110.26 (A)(3). Work space shall be clear and extend from grade, floor or platform to the heigh required by 110.26 (E)</p>				
53201	14A0654	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify that dedicated service room is 2 hour fire rated. 2) Confirm closing rating of transformer primary switch is adequate for transformer inrush. 8/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/30/15 Swapped 1 and 2, Revision 2s.</p>				
52614	14A0655	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				
	14A0656	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
<p>1) 1 Line does not match physical. 2) Service bus feeding 2000 and 1200 amp service switches undersized. 3) Show bus size feeding service switch #2. 4) Show size of through bus on load side of service switch #2 and section bus sizes. 5) Siemens cut to show proper bus sizes. 3/4/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/17/14 Rejected Contractor's name can't be changed on submittals, Refiling required by new contractor.</p>				
	14A0657	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
See Cal. #53161.				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52649	14A0658	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/14/2017- swap dwg rev 1				
52650	14A0659	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
52622	14A0660	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 4/21/15 Swapped Revision 1.				
52651	14A0661	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/17/16 Swapped drawing 1, Revision 1.				
52652	14A0662	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/19/16 Swapped drawings 1,2 and 3-Revision 1s. 4/18/16 Swapped drawing 1,2 and 3-Revision 2s.				
52624	14A0663	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				
52623	14A0666	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 10/25/16 Swapped drawing 1-Revision 1.				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52918	14A0667	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire alarm not connected to generator. Show gen on 1-Line With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Provide barrier to block access to rear of service switchboard. 3/30/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Provide barrier to block access to rear of service switchboard. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/26/17 - swap dwgs 1,2 & 3 rev 2's 8/3/18 - 1) Provide F.P. cond size from splice box to F.P. controller for F.P. # 1,2 & 3 2) Verify 5 foot clearance to F.P. Switchboard. 10/3/18 Swap dwg #1,2 and 3-Revision 4</p>				
52653	14A0668	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
53190	14A0669	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show normal feed to new 400 ATS for phone room panel. 2) Feeders on load side of generator overfused With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PW1 as an ALT 3. 2. A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 6/19/15 Rejected. Verify front clearance for F.A. disconnect(emerg). 8/18/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

November 19, 2014

Approval #	Submission #	Type of Request	Status	Fee
52618	14A0674	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR				
52792	14A0679	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify 3' clearance in front of MP IDP. 2) Show size of main bonding jumper With the stipulation: With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3) FDNY requires EGC's in F.A. circuits. 3/4/15 With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/20/16 Swapped drawing 1-Revision 3.</p>				