

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 113-00-E

Report of Material and Equipment Acceptance Division

Manufacturer - Systems Sensor, A Division of Pittway, 3820 Stern Avenue,
St. Charles, IL. 60174

Trade Name(s) - System Sensor.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S911, Project 98NK28459A, Volume 46, Section 1, Issued
February 8, 1999 and UL letter dated March 30, 2000.

Description -Approval is requested for Systems Sensor's smoke detector as follows:

Model Number	Description
TC840A1001	Addressable intelligent ionization, photoelectric, thermal type

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated April 18, 2000, F.P. Index 0004029.

Recommendation - That the above units be accepted on conditions that all uses, locations and installations comply with the New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3 inclusive as applicable including the NFPA as appropriate, the UL listing, the manufacturer's instructions, the Fire Department Directives, and with Electrical Code of the City of New York.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 27, 2000

Examined By Mark Juelnicz