



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 113-08-E

Manufacturer: New Chapco, LLC
20-1 Denlar Drive,
Chester, CT 06412

Trade Name(s): CookSafe

Product: Range hood with built in fire system
MEA Index #270-20 - Filters

Pertinent Code Section(s): Reference Standard RS 13-3

Prescribed Test(s): UL 507 and UL 300A

Laboratory: Intertek

Test Report(s): Project #3153309 issued March 10, 2008, revised
April 17, 2008.

Description: CookSafe model CV, is a patented combination hood with integrated fire system that monitors heat through a patented sequence of sensors that (1) turns on fan to high position if not on already at 1st set temperature (2) sounds a local and/or remote alarm, along with shutting down the stove at 2nd higher set temperature and (3) releases a fire suppressant liquid chemical at the last higher set temperature resulting from a cooking fire, as well as shutting off the gas or electricity to the stove.

Terms and Conditions: The above-described electric heating cabinets are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical, Building and Fire codes.

2. Installation shall not obstruct access for operation and servicing.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Division.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance August 22, 2008
Examined By Donald [Signature]