

ADVISORY BOARD CALENDAR

November 30, 2019

Approval #	Submission #	Type of Request	Status	Fee
	BK00053	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>12/31/19 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01 https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf: The §4000-01 Rule includes but not limited to the following: a) The service is below 1000KVA, no plan examination is required for this job.</p>				
BK00123A1	BK00123	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/16/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. Additional Comments: - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 8/14/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
	BK00126	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>11/27/19 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01 https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf: The §4000-01 Rule includes but not limited to the following: a. All drawings must include PE/RA Seal and sign. b. Fire Alarm is double tap not permitted. c. Size of Fire Alarm tapping conductor must be 10% of the tapped conductor. d. Verify Neutral is reduced according to section 220.61(B).</p>				

ADVISORY BOARD CALENDAR

November 30, 2019

Approval #	Submission #	Type of Request	Status	Fee
BK00126A	BK00126	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/9/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> · Contact Con-Edison regarding Blue Book requirements. · It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. · It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. · It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. · Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 				
BK00168A1	BK00168	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>2/5/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work</p>				
BK00171A	BK00171	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>6/24/2020. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BK00180A	BK00180	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1/10/20 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 				

ADVISORY BOARD CALENDAR

November 30, 2019

Approval #	Submission #	Type of Request	Status	Fee
BK00184A	BK00184	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/3/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> · Contact Con-Edison regarding Blue Book requirements. · It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. · It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. · It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. · Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 				
BK00214A1	BK00214	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/20/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department.. 6/21/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work 				

ADVISORY BOARD CALENDAR

November 30, 2019

Approval #	Submission #	Type of Request	Status	Fee
BX00089A1	BX00089	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/22/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> -Contact Con-Edison regarding Blue Book requirements. -It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. -It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. -It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. -Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 6/2/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 6/11/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 				
BX00122A1	BX00122	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/17/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 5/10/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 				
BX00191A1	BX00191	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>2/7/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/10/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

ADVISORY BOARD CALENDAR

November 30, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00017A	MN00017	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/19/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> · Contact Con-Edison regarding Blue Book requirements. · It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. · It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. · It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. · Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 				
MN00090A1	MN00090	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/17/19 Plans Review Comments:</p> <p>1. Comply with 450.3 at "SS-A", "DS-D" & "SS-E". 4/7/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>4/30/2021 Job finalied. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
MN00116A	MN00116	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 				

ADVISORY BOARD CALENDAR

November 30, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00130A	MN00130	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/20/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 				
MN00134A	MN00134	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/26/19 1) Contact Con-Edison regarding Blue Book requirements.</p> <p>2) It is applicant responsibility to Maintain Listing for all new, and modified existing equipment.</p> <p>3) It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement.</p> <p>4) It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement.</p> <p>5) Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department.</p>				
	MN00136	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>11/25/19 1). The engineering single line plan shall be submitted based on new NYC 4000-01 Rule https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf, no bus bar sizes to be shown and the P.E. seal and sign shall be included in all plans.</p> <p>2. Provide note to confirm NRTL listing.</p> <p>3. Provide available S.C. current & AIC rating at point of entry & new equipment.</p> <p>4. Provide current rating for new SEB copper detail.</p> <p>5. New area of work should be bubbled.</p> <p>6. Equipment clearance shall be clearly shown in floor plan.</p> <p>7. Confirm bonding & grounding as per article 250.</p> <p>8. One line drawing is required not a riser diagram. Also direct applicant to our new rule 4000-01.</p> <p>9. EPR cover sheet is missing owner signature</p>				

ADVISORY BOARD CALENDAR

November 30, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00152A	MN00152	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/25/19 1) Contact Con-Edison regarding Blue Book requirements. 2) It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. 3) It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. 4) It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. 5) Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department..</p>				
MN00161A	MN00161A	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/30/19 1. Ground electrode conductor to new service switch is undersized - Table 250.66. 2. Confirm 5 feet clearance for new service switch as per 230.64. 1/10/2020 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
MN00175A	MN00175	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/17/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. Additional Comments: - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department.</p>				
	MN00179	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>2/18/2020 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01 https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf The §4000-01 Rule includes but not limited to the following: a. The submitted plans do not require a plan review. The area of new work is after the second level of OCPD and, there is no new 1000KVA or above equipment was shown on the plans.</p>				

ADVISORY BOARD CALENDAR

November 30, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00183A1	MN00183	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
4/10/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00197A1	MN00197	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
12/20/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. Additional Comments: - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 3/3/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/3/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00213A1	MN00213	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
12/18/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. Additional Comments: - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 6/24/2021 Job finalized. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/14/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

ADVISORY BOARD CALENDAR

November 30, 2019

Approval #	Submission #	Type of Request	Status	Fee
QN00074A3	QN00074	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/16/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. Additional Comments: - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 8/10/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/21/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
QN00163A	QN00163A	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1/29/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. Additional Comments:</p>				
	QN00178	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1/8/20 1. Confirm the main existing service switch fuse is A4BQ or KRPC - coordination does not match the one line.</p>				
SI00210A1	SI00210	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>6/22/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				