

Report of Materials and Equipment Acceptance Division

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 114-07-E (Correction)

Manufacturer: Power-Plex Electronics, Inc., #23, 2900 Argentia

Road, Mississauga, Ontario CANADA L5N 7X9

Trade Name(s): Honeywell Power products

Product: Fire alarm equipment

Pertinent Code Section(s): Subchapter 17 & Reference Standard RS 17

Prescribed Test(s): UL 1481 – "Power Supplies for Fire Protective

Signaling Systems"

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): 1. UL File S8922, Project 04CA52920, issued

July 10, 2006

2. UL File S8922, Project 04CA52920, issued

July 11, 2006

3. UL File S8922, Project 04CA52920, Issued

July 12, 2006.

Description: Fire alarm equipment, series HP300/400/600, are remote, compact power supplies and battery chargers.

Model numbers are:

HP300ULX	HP400ULX	HP600ULX
HP300ULM	HP400ULM	HP600ULM
HP300ULPD4CB	HP400ULPD8CB	HP600ULPD16CB
HP300ULACM4	HP400ULPD4CB	HP600ULPD8CB
	HP400ULACM8	HP600ULACM4
	HP400ULACM4	HP600ULACM8

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated August 7, 2007, F.P. Index #0704042A.

Terms and Conditions: The above-described units are accepted on condition that:

- 1. All uses, configurations, arrangements and functions, application and installations shall comply with all applicable provisions of New York City Building Code, specifically Subchapter 17 and Reference Standards 17-3 through 17-5. Further, the installation shall be in accordance with the manufacturer's recommendation, and UL standards.
- 2. UL listing requirements and limitations shall be complied with.
- All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance

Examined By