



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 117-08-E

**Manufacturer:** Whirlpool Corporation  
303 Upton Drive  
St. Joseph, Michigan 49085

**Trade Name(s):** Maytag, Whirlpool

**Product:** Commercial gas-fired tumble dryers  
MEA Index #200-20 – Dryers

**Pertinent Code Section(s):** 27-800, 27-807, RS 14-2 (ANSI Z223.1)

**Prescribed Test(s):** RS 14-6 (ANSI Z21.5.1)

**Laboratory:** CSA International

**Test Report(s):** Master Contract #154166, Report 1956345

**Description:** Commercial gas-fired tumble dryers for use in coin laundries or non-coin institutional laundries. The machines are manufactured with an electronic processor, and are operated with a non-pay, coin-pay or card-reader operation.

Type: (Located on serial plate)	Load Capacity	Input Rating (Btu/hr)
(B,C,D)HLV-NAT-1206006-EL24	18 lbs.	24,000
(B,C,D)CLV-NAT-1206012-MC24	18 lbs.	24,000

**Terms and Conditions:** The above-described commercial gas-fired clothes dryer is accepted with the following conditions:

1. Units shall be fired by natural gas only.
2. Minimum installed clearances from combustible construction shall be as follows: front – 1 inches (with ventilation requirement of 48 square inches near the bottom and 24 square inches near the top); sides – 0 inches; rear – 0 inches.
3. Provision for combustion air and ventilation air shall be made in accordance with Section 27-807 and other applicable Code requirements.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 29, 2008

Examined By Simon Derkshon