

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or materials has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

**MEA 120-00-E  
Report of Material and Equipment Acceptance Division**

**Manufacturer - Lennox Industries Inc., 200 S. 12<sup>th</sup> Avenue, Marshallton, IA 50158.**

**Trade Name - Lennox**

**Product - Air cooled condensing units.**

**Pertinent Code Sections - RS 13-6 (ANSI B9.1), RS 13-8 (UL 303), RS 13-11 (UL1995).**

**Laboratory - Underwriters Laboratories Inc.**

**Test Report - UL file SA11694 dated April 14, 2000.**

**Description - Air cooled remote mounted condensing units, model 12ACC, designed for the system. Unit consists of hermetic sealed compressor, air cooled condenser with fan and safety controls. Units, with model numbers and nominal cooling capacities, are listed below:**

<b>Model No.</b>	<b>Mfr.'s Specified Nominal Cooling Capacity (Tons)</b>
12ACC-24	2.0
12ACC-30	2.5
12ACC-36	3.0
12ACC-42	3.5
12ACC-48	4.0
12ACC-60	5.0

**Recommendation - That the above described air cooled condensing units be accepted for outdoor installation, when utilizing refrigerant R-22, under the following conditions:**

1. All equipment shall be furnished with permanently affixed metal tags stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
3. Approval if all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 7/27/2000  
Examined by S.M. Prasad