



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 121-83-E Vol. III

Manufacturer: Rheem Manufacturing Company, 2600 Gunter Park Drive East, Montgomery Alabama 36109.

Trade Name(s): Rheem.

Product: Electric storage tank water heaters.

Pertinent Code Section(s): 27-787.

Prescribed Test(s): RS 14-6 (UL 1453). Underwriters

Laboratory: Test Laboratories Inc,

Report(s): UL file E11867 Vol. 1 Section 12 dated August 27, 2001.

Description: Automatic storage type electric water heaters, lowboy or tall, as tabulated below. Unit consists of glass-lined sheet steel tank immersion type heating element, factory installed anode rod, high limit relief valve. Water heater tank is hydrostatically tested for 150 psi working pressure. Units with model numbers, storage capacities and electrical wattages are listed below.

Model No.	Storage Capacity Gallons	Electrical Wattage
82SV20(-1)(-2)	20	3500-4500
82V30(01)(-2)	30	3500-4500
S2SV30(-1)(-2)	30	3500-4500
RHES PRO30-2-A	30	3500-4500
82V40 (-1) (-2)	40	3500-4500
82SV40(-1)(-2)	40	3500-4500
RHES PRO40-2-A	40	3500-500
82SV50-2	50	3500-4500
RUES PRO45-2-A	50	3500-4500
82V52	52	3500-4500
82V66-2	66	3500-4500
82V80-2	80	3500-4500
82 V120-2	120	3500-4500
82MV30-2	30	3500-500
RHEMPRO30-2-A	30	3500-500
82MV52(-1)(-2)	52	3500-4500
83VR40-2	40	3500-4500
RHE PRO40-2-A	40	3500-4500
83XR40-2	40	3500-500
83VR52-2	52	3500-4500
RHE PRO52^2-A	52	3500-4500
83VR66-2	66	3500-4500
RHE PRO66-2-A	66	3500-4500
83VR80-2	80	3500-4500
83XR80-2	80	3500-500
RHEPRO80-2-A	80	3500-4500
83MVR52-2	52	3500-4500
83MXR52-2	52	3500-4500
RHEMPRO52-2-A	52	3500-4500

Note: 1. Unit shall be installed on noncombustible flooring. Minimum installed clearances to combustible construction shall be in accordance with RS 14-15.

Terms and Conditions - That the above described electric water heaters, installed as per clearances to combustible construction specified above, be accepted under the following conditions:

1. Automatic temperature and pressure relief valve, properly sized for heater and MEA accepted, and operating temperature limit controls shall be furnished for heater installation.
2. All shipments and deliveries of such equipment shall be provided with a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department before installation.

Final Acceptance November 9, 2005

Examined By Siam Derphudan