

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48088CO	07A0397CO	Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Queens District 14 Salt Shed 5110 Almeda Avenue Far Rockaway NY	Ok, but	\$0.00
Carry over from August 15, 2007 meeting. Provide site plan.						
48258CO		Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requesting permission to leave as submitted a single means of egress to a 1000 KVA service room due to having no room to install a legal exit.	Queens District 14 Salt Shed Queens NY	Approved	\$0.00
Carry over from October 17, 2007 meeting.						
48269CO		Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requesting permission to leave as installed 8 sets of 500 MCM MC cable fused at 1000 amps where the cable contains #2 equipment grounding conductor	Atria River Project 3718-3726 Henry Hudson Parkway Riverdale NY	Approved	\$0.00
Carry over from October 17, 2007 meeting. With the stipulation that a trip setting ground fault circuit breaker set to trip at 1000 amp is installed as per 250.122(F)(2) and 2 revised copies of drawings showing the changes are given to the Advisory Board Chairman to switch.						
48281CO	07A0526CO	Infinity Electrical Contractors, Inc. 22-10A 35th Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	20 Maiden Lane New York NY	Approved	\$0.00
Carry over from November 14, 2007 meeting.						
48315CO	07A0560CO	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Commerce Bank 1873 Broadway New York NY	Approved	\$0.00
Carry over from November 14, 2007 meeting.						

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48317CO	07A0562CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New York Hospital Queens 56-45 Main Street Queens NY	Approved	\$0.00
Carry over from November 14, 2007 meeting. 1) Provide mechanical ventilation in service rooms. 2) Provide missing bus sizes for 2000 amp switches MSDD11. 3) Coordinate 4000 to 2000 amp switches. 4) Ground transformer. 5) Barrier off between transformers. Job finalized 01/23/08.						
48329	07A0565	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	11 Times Square, 640 8th Avenue New York NY	Ok, but	\$650.00
1) Ground wires must be sized per 250.122. 2) Approval does not include generator and generator switchboard, separate submission required.						
48330	07A0644	LJM Engineering Group The Aviary, 439 RT. 46 East Rockaway NJ 07866	Requested approval for the electric service equipment proposed to be installed	Park West Imaging 315 West 57th Street New York NY	Hold	\$650.00
1) Drawings not submitted in Advisory Board rule format, tap detail, taps, grounding, buss bars, switches to whether they are bonded or not after service switches. 2) New service switches are installed in adjacent room not grouped with other service switches with out special permission. 3) Service room layout does no show clearances.						
48331	07A0635	Interphase Electric Corp. 5304 Seventh Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	R & T Building 48-34 35th Street Long Island City NY	Hold	\$650.00
1) Verify front and rear of switchboard. 2) Show dimensions of side clearance of the switchboard. 3) Five feel clearance needed in front of switchboard. 4) 30 amp circuit breaker for FA should be a fuse cutout. 5) Manufacturer's cut sheet for paralleling gear not submitted. 6) Bus sizes of paralleling gear not provided. 7) Bonding and grounding of generators not shown. 8) 30.3 switch for fire suppressor from service switchboard should be FCO. 9) Load ban feeder undersized.						
48332	07A0634	Daniel Borriello Electric, Inc. 1468 86th Avenue New York NY 11228	Requested approval for the electric service equipment proposed to be installed	2166 Coney Island Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48333	07A0638	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	33 University Place, 44 Bsmt, 1st Fl. New York NY	Approved	\$650.00
48334	07A0637	Lite Tron Electrical Corp. 236 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	80 Metropolitan Avenue Brooklyn NY	Approved	\$650.00
48335	07A0602	A.T.J. Electrical Co., Inc. 33-61 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Public School PS-95X 3961 Hillman Avenue Bronx NY	Approved	\$650.00
48336	07A0599	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Whole Foods 103 Warren Street New York NY	Approved	\$650.00
48337	07A0600	Jorob Contracting and Electrical Co. Inc. 104-29 Jamaica Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	12 East 41st Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48338	07A0601	Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	303 East 51st Street New York NY	Approved	\$650.00
48339	07A0629	Joma Electrical Contracting Co. 218 31st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	271 Scholes Street Brooklyn NY	Approved	\$650.00
1) Service bus undersized. 2) Bus sizes in distribution board not provided. Job finalized 6/9/08.						
48340	07A0568	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Fire Pump Work 10 East 53rd Street New York NY	Approved	\$650.00
1) Neutral in fire pump service switch not bonded to enclosure. 2) Supplemental ground not provided in fire pump service switch. 3) Existing 4000 service switch drawn incorrectly. Job finalized 1/11/08.						
48341	07A0639	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	John Dewey High School 2475 Stillwell Avenue Brooklyn NY	Approved	\$650.00
Tap for 400 amp disconnect switch undersized (10%) 600KCM. Job finalized 1/7/08.						
48342	07A0640	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	PS-IS 102 Queens 55-24 Van Horn Street Elmhurst NY	Approved	\$650.00
Fire pump circuit on emergency side not fire rated. Job finalized 1/23/08.						

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48343	07A0641	Roland J. Wertz, Inc. 436 Beach 129th Street Belle Harbor NY 11694	Requested approval for the electric service equipment proposed to be installed	1862 East 2nd Street Brooklyn NY	Approved	\$650.00
Con Edison does not allow the grounding conductor to be terminated in the meter pan or Con-Ed box move ground to service switch. Job finalized 1/23/08.						
48344	07A0632	Urban Power & Lighting, Inc. 227 49th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Flushing Town Center 40-22 College Point Boulevard College Point NY	Approved	\$650.00
1) Provide supplemental ground on service SB-G, and SB-E. 2) Verify that service room is mechanically ventilated. 3) Show conductor sizes tapped from trough that feed 2-600 and 1-400 amp disconnect switches. 4) 2-600, and 1-400 amp disconnect switches, neutrals bonded after 1600A service switch. Job finalized 2/25/08.						
48345	07A0613	H.P. Electrical Desgins Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	450 Washington Street New York NY	Approved	\$650.00
48346	07A0618	Lakhani & Jordan Engineers, P.C. 50 East 42nd Street, Suite 1001 New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 5th Avenue New York NY	Approved	\$650.00
1) Existing fire pump connection on load side of service switch check fuse size of fire pump switch fuse. 2) No coordination 4000A fuse 12000A CB. Need special permission. Job finalized 1/7/08.						
48347	07A0619	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Trinity Real Estate 435 Hudson Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48348	07A0620	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	485 Lexington Avenue New York NY	Approved	\$650.00
48349	07A0621	OM Electric, Inc. 262 West 38th Street, Suite 603 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	600 Broadway New York NY	Approved	\$650.00
48350	07A0622	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	H.S. for Health Professionals 345 East 15th Street New York NY	Approved	\$650.00
48352	07A0623	KGK Electric 50-01 25th Avenue, Suite 3 Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	454 Manhattan Avenue New York NY	Approved	\$650.00
48353	07A0624	Samson Electric Corp. 47-10 33rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	119 West 40th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48354	07A0625	Samson Electric Corp. 47-10 33rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Chelsea Market 75 9th Avenue New York NY	Approved	\$650.00
48355	07A0626	June Electric Corp. 2025 Continental Avenue, Suite 5E Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	130 Bradhurst Avenue New York NY	Approved	\$650.00
48356	07A0627	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	11-24 31st Avenue Long Island City NY	Approved	\$650.00
48357	07A0630	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	New York Times at College Pt. Flushing, NY	Approved	\$650.00
1) Provide overall system 1-line diagram. 2) Provide additional info on 5 KV front accessible switchgear. Job finalized 3/11/08.						
48358	07A0566	Knight Electrical Services Corp. 111 Eighth Avenue, Suite 526 New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Metropolitan Museum of Art 1000 Fifth Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48359	07A0567	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	East River Science Park 450 East 29th Street New York NY	Hold	\$650.00
1) One line does not match physical's 400 amp switch in MSB-B board and SSB-E fuses. 2) Barrier off behind SSB-B equipment must be front accessible. 3) Fire rated door to ATS room not provided. 4) Provide elevation drawing for service room bus takeoffs. 5) 4000 amp service switch not provided w/GFP in MSB-B. 6) Generator room layouts not provided and equipment layout. 7) Clarify feed to jockey pump and 30 amp FCO on emergency side, can't share same box. 8) Emergency circuit for fire pump not fire rated. 9) Provide ground fault indication on generators. 10) 3000 amp bus duct fused at 4000 amps. Does not match physical. 11) Correct switch and fuse on bus duct SSB-C and SSB-D. 12) Provide short circuit calculations for LPE-S and E panel. 13) Provide ventilation in service room.						
48360	07A0646	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	6405 Yellowstone Boulevard Forest Hills NY	Approved	\$650.00
1) Bonding and grounding not shown on drawing. 2) Neutral links not provided in service switches. 3) Bus size not provided for panelboard off of the 1200 amp service switch. Job finalized 2/25/08.						
48361	07A0633	Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456	Requested approval for the electric service equipment proposed to be installed	200 West 90th Street New York NY	Hold	\$650.00
1) 5 feet clearance needed in front of service equipment. 2) Show tap detail in troughs. 3) Verify if trough on conduit is being installed for service entrance, where is end box located? 4) Provide pictures of the service room showing job conditions.						
48362	07A0645	PJS Electric, Inc. 10 43rd Street, Box #L15 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	DEP Spring Creek Flatlands Avenue Brooklyn NY	Denied	\$650.00
1) One drawing not submitted in Advisory Board format. 2) Bonding and grounding not shown.						
48363	07A0636	Lite Tron Electrical Corp. 236 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Chelsea Piers-Pier 59 New York NY	Hold	\$650.00
1) Submission not n Advisory Board format. 2) Bonding and grounding not shown. 3) Contractor's name not on drawings' title box. 4) Clarify who is submitting drawing Cosentini Cal. #48027 or Lite Tron Cal. #48363. 5) Transformer not grounded. 6) Show where existing 5000 amp service switch feeds 7) 800 CT does not match 1 line.						

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48364	07A0603	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	621 West 46th Street New York NY	Approved	\$650.00
Increase bus size in panel or decrease fuse size to 1200 amp. Job finalized 1/8/08.						
48365	07A0631	J.E.R. Electric Corp. 1392 Commerce Avenue Bronx NY 10461	Requested concept approval for	1450 Broadway New York NY	Approved	\$0.00
48366	07A0605	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	CBRE 501 Seventh Avenue New York NY	Approved	\$650.00
48367	07A0604	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	New York Palace Hotel 455 Madison Avenue New York NY	Approved	\$650.00
48368	07A0628	Jeminis Electrical Contractors, Inc. 18-01 120th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	1765 Townsend Avenue Bronx NY	Approved	\$650.00
1) Front clearance 5' must be maintained in front of 1200 amp service equipment. 2) Service room doors to open out with panic hardware. 3) Show selectivity between circuit breakers and short circuit. 4) Conductor from fire pump junction box to motor is undersized. Job finalized March 21, 2008.						

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48369	07A0642	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	420 East 59th Street New York NY	Approved	\$650.00
Length of tap not provided. Job finalized 1/23/08.						
48370	07A0643	Jusler Electrical Corporation 26-16 Skillman Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	One Park Avenue New York NY	Approved	\$650.00
Middle section of distribution board 1-1/4x5 bus is undersized. Job finalized 1/23/08.						
48371	07A0647	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	515 9th Avenue New York NY	Ok, but	\$650.00
1) Fire pump service switch undersized and not identified. 2) Feeders off of service switch #4 are undersized. 3) Bus sizes not provided on service switch 2 and 3. 4) Service switch #1,2,3 and 5 show no selectivity to 2nd fusing. 5) Check note under panel DB-B.						
48372	07A0617	AL-lectric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	301 West 57th Street New York NY	Approved	\$650.00
48373	07A0606	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Ethan Allan 1010 Third Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48374	07A0607	Belway Electric NYC, LLC 38 East 29th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	AT & T Web Hosting 811 Tenth Avenue New York NY	Approved	\$650.00
48375	07A0606	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Southtown Bldg. #5 415 Main Street Roosevelt Island NY	Approved	\$650.00
48376	07A0609	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Southtown Bldg. #6 405 Main Street Roosevelt Island NY	Approved	\$650.00
Fire pump circuit conductors undersized. Job finalized 1/7/08.						
48377	07A0610	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	351 West 21st Street New York NY	Approved	\$650.00
48378	07A0611	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Avalon Morningside 401 West 110th Street New York NY	Approved	\$650.00
1) Panel TDP-W the undergrounded conductors feeds neutral bar. 2) Service room doors to open out w/panic hardware. Job finalized 1/7/08.						

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48380	07A0614	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	PS/IS 798K 696 Jamaica Avenue Brooklyn NY	Approved	\$650.00
48381	07A0615	Approved Electric Corp. 3578 White Plains Rd, Suite 107 Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	57 West 75th Street New York NY	Approved	\$650.00
Increase bus to 1200 amp service switch. Job finalized 11/17/08.						
48382	07A0616	Positive Electro Mechanical Corp. 1327 60th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Linden Boulevard Bldg. Study 206-20 Linden Boulevard Queens NY	Approved	\$650.00
48383	07A0648	Metro York Electrical, Inc. 23-86 BQE Long Island City NY 11103	Requested approval for the electric service equipment proposed to be installed	Bowery Bay 45-41 Berrian Blvd. Queens NY	Hold	\$650.00
1) Drawing not submitted in Advisory Board format. 2) Designer to appear at meeting to explain job and to show if job is all new if equipment is existing.						
48384		Sidney Electrical Contracting Inc. 1950 Coney Island Avenue Brooklyn NY 11223	Requesting permission to install underground service entrance conductors in non metallic Schedule 80 conduit.	Wolfson 501 Cedar Hill Road Far Rockaway NY	Approved	#Error

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48385		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to install underground service entrance conductors in concrete encased non metallic conduits	123-50 Roosevelt Avenue Flushing NY	Approved	\$0.00
<p>Note: Underground service lateral conductors do not require equipment bonding conductors to be installed in the conduits between the property line box and the interior copper detail box, however, if there is a manhole enclosure with a metallic ring in the run, the ring shall be bonded to the neutral conductors.</p>						
48386		DVL Consulting Engineers Inc. 137 Fifth Avenue New York NY 10010	Requesting permission to install underground concrete encased service laterals conductors in rigid non metallic conduit	New School-PS 276M 55 Battery Place New York NY	Approved	\$0.00
48387		Techno-Volt Electric, Inc. 22-77 Steinway Street Astoria NY 11105	Requesting permission to install two ground fault protected receptacles in one outlet box mounted in the wall next to the kitchen cabinet instead of providing two receptacle outlets on the cabinet in 70 apartments.	31-01 Vernon Blvd. Long Island City NY	Denied	\$0.00
48388		Urban Power and Lighting, Inc. 227 49th Street Brooklyn NY 11220	Requesting permission to extend 1900 intermediate metal conduit runs by adding two feet of liquid-tight metallic conduit that will feed the last fixture outlets in an open wall parking garage.	Flushing Town Center 40--28 College Point Blvd. Queens NY	Approved	\$0.00
48389		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to replace a 480 volt circuit breaker panel with new in an existing electrical closet (8'x36") where the clearances do not comply with 110.26 (A)(1), and 110.26(A)(3).	299 Park Avenue New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48390		Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requesting permission due to lack of space inside of a new service room to install copper bus ties approximately 26 feet to feed service equipment in a two hour fire rated service room.	East River Science Park 450 East 29th Street New York NY	Hold	#Error
Pending elevation drawings as per 48359 comments.						
48391		Ideal Electric & HVAC Co. Inc. 235 India Street Brooklyn NY 11222	Requesting permission to install a neon transformer in a residential apartment where the secondary voltage is 4000 volts with a open voltage of 0 volts.	15 Central Park West New York NY	Denied	\$0.00
48392		Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requesting permission to install 8 service switches on one set of service entrance conductors that will provide power for 3 fire pumps located in a remote switchboard with a common bus.(Cal. #48287).	74 DeKalb Avenue Brooklyn NY	Approved	\$0.00
48393		Jen-Mar Electric Service Inc. 63 Flushing Avenue-Bldg. #274 Brooklyn NY 11205	Requesting permission to	63 Montgomery Avenue Staten Island NY	Approved	\$0.00
With the stipulation that signage is provided as per 230.2(E).						
48394	07A0649	Antares Enterprises 10838 Bloomfield Avenue Santa Fe Springs CA 90670	Requested approval for use in New York City of your Fluorescent Lighting Fixtures. Model/Series Numbers: Odyssey T4 and Geminix T5		Hold	\$200.00
1) Installation instructions must be provided. 2) Is there a limit of how many fixtures can be connected together? 3) Your application must state portable under cabinet and display lighting.						

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48395	07A0650	Connectrac 163 Leslie Street Dallas TX 75207	Requested approval for use in New York City of your Steel Receptacle and Cover. 8-Wire, 4-Circuit power jumper and infeed, and floor-mounted raceway components Connectrac U Series		Hold	\$200.00
Need letter of authorization from "Byrne" only as part of listed multi outlet assy. "Connectrac" surface MTD. Floor raceway, min #12 AWG conductor.						
48396	07A0651	Connectrac 163 Leslie Street Dallas TX 75207	Requested approval for the use in New York City of your Duplex Receptacle System with 24' flex conduit and floor-mounted raceway Components. Connectrac I Series.		Hold	\$200.00
Need letter of authorization from "Byrne" only as part of listed multi outlet assy. "Connectrac" surface MTD. Floor raceway, min #12 AWG conductor.						
48397	07A0652	Connectrac 163 Leslie Street Dallas TX 75207	Requested approval for use in New York City of your Steel Junction Box with 24' flex conduit and floor-mounted raceway components. Connectrac M Series.		Hold	\$200.00
Need letter of authorization from "Byrne" only as part of listed multi outlet assy. "Connectrac" surface MTD. Floor raceway, min #12 AWG conductor.						
48398	07A0653	Nuheat Industries Limited 1689 Cliveden Avenue, Delta B.C. Canada V3M 6V.	Requested approval for use in New York City of your Indoor floor warming electrical cable sets. Model/Series Numbers: N1Cxxxxyy and N2Cxxxxyy (xxx and yyy denoting square feet range).		Denied	\$200.00
The CSA report does not include Model N1C or N2C cable sets and does not include Nuheat as listee.						
48399	07A0654	Flextherm Inc. 2400 de la Province, Longueuil Quebec Canada, J4G 1G	Rquested approval for use in New York City of your Indoor floor warming electrical cable sets. Model/Series: GSxxxCzzzz and GSxxxKzzzz(xxx denoting voltage & zzzz for length in feet)		Approved	\$200.00
Cable only.						

ADVISORY BOARD CALENDAR

December 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48400	07A0655	True Comfort Floor Heating Inc. 2400 del la Province, Longueuil uebec, Canada J4G 1G	Requested approval for use in New York City of your Indoor floor warming electrical cable sets. Model/Series Numbers: PSxxx3zzz(where xxx denotes voltage & zzz for length in feet)		Hold	\$200.00
Provide CSA report showing True Comfort as listee						
48401		Quantum Electric Corporation 36-24 34th Street Long Island City NY 11106	Requesting permission not to file full Advisory Board drawings for the addition of a new 200 amp service switch that will provide power to a limited service fire pump	Community Service 105 22nd Street New York NY	Hold	\$0.00
Advisory Board drawings must be submitted, however, Section 230.72 allows water pumps that provide power for pipe protection to be located remote from the other service switches.						
48402		Jaros, Baum and Bolles 80 Pine Street New York NY 10005	Requesting permission to leave as installed 120 volt underwater fountain lighting that will be ground fault protected	767 5th Avenue New York NY	Approved	\$0.00