

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50473CO2	10A0478CO2	Universal Electric Corporation 168 Georgetown Road Canonsburg PA 15317	Requested approval for use in New York Starline Track Busway and Starline Plug-in Raceway Model/Series Numbers: B400, B400N, B400G, B400NG and Accessories & SB20, SB20G, SB40, SB40G, SB60, SB60G and Accessories.		Approved	\$0.00
Carry over from November 14, 2012 meeting.						
50741CO	11A0224CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	157 West 57th Street New York NY	Approved	\$0.00
Carry over from June 15, 2011 meeting. Verify that turbine switch is 100% rated. Job finalized 3/15/13.						
51543	12A0200CO	Campbell and Dawes Electl Contrs Ltd, 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	Deloitte & Touche 30 Rockefeller Plaza New York NY	Approved	\$0.00
Carry over from September 12, 2012 meeting. Transformer grounding electrode undersize. Job finalized 1/15/13.						
	12A0225CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mount Sinai Center 1470 Madison Avenue New York NY	Denied	\$0.00
Carry over from September 12, 2012 meeting.						
51555	12A0245CO	Cedar Electrical Contractors, Inc. 317 Madison Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	141 East 88th Street(North Side) New York NY	Approved	\$0.00
Carry over from October 17, 2012 meeting. 1) Remove closet from the service room. 2) Show clearance in front of the service entrance box. 3) Service room door to open outwards. 4) Short circuit calculations not provided at HPD and RDP panels. 5) Attached curves do not match 1 Line drawing. 6) Provide documentation showing the interrupting ratings of panels HDP. Manufacturer's cut sheets of equipment not provided. Job finalized 1/17/13.						

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51552	12A0246CO	Cedar Electrical Contractors, Inc. 317 Madison Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	141 East 88th Street(South Side) New York NY	Approved	\$0.00
Carry over from October 17, 2012 meeting. 1) Room layout drawing not provided. 2) Equipment grounding conductors undersized. 3) Provide cut sheet of 800 amp Trans s with 800 amp switch. 4) Verify wiring method for F.P. Job finalized 1/17/13.						
51549	12A0307CO	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	New York Aquarium 514 Surf Avenue Brooklyn NY	Approved	\$0.00
1) Remove 3/0 equipment grounding jumper in transformer is factory installed. 2) AIC of panel is undersized. Job finalized 1/15/13.						
51564	12A0321CO	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JPMC 1 Chase Manhattan Plaza New York NY	Approved	\$0.00
Carry over from November 14, 2012 meeting. 1) F.P service switch fuses undersize. 2) F.P. emergency feeder fuses undersize. Job finalized 1/16/13.						
52170	12A0331	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Caspary Hall 1230 York Avenue New York NY	Approved	\$650.00
1) Main bonding jumper and grounding electrode not provided at 500 KVA transformer or 800 amps secondary disconnect switch. 2) Verify grounding electrode provided for 300 KVA transformer. 3) Service room to be mechanically ventilated. 9/16/13 Items 1 and 2 not addressed, changes for short circuit study not marked on new study. 2/20/14 job finalized.						
51550	12A0332	Heso Electrical Inc. 33-06 Ditmars Blvd. Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	343 Gold Street Brooklyn NY	Approved	\$650.00
Change fuses to LPN's. Job finalized 1/11/13.						

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51487	12A0333	M.R. Electrical Service LLC 115 Heyward Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	341 Eastern Parkway Brooklyn NY	Approved	\$650.00
51488	12A0334	C.T. Electric Inc. 55 Garnet Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Daughters of Divine Charity 850 Hylan Blvd. Staten Island NY	Approved	\$650.00
51489	12A0335	Litespeed Electric, Inc. 135 West 29th Street, Suite 301 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Center for Family Representation 89-14 Parsons Boulevard Queens NY	Approved	\$650.00
51490	12A0336	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	New York Life Insurance Co. 51 Madison Avenue New York NY	Approved	\$650.00
52063	12A0337	Allstate Electric Corp. 555 Eighth Avenue, Suite 809 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	33 Whitehall Street, Basement New York NY	Approved	\$650.00
1) Show conduit sizes, and how many conduits are being installed. 2) Provide termination for grounding electrode conductor in fire alarm switch. 12/19/13 job finalized.						

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51491	12A0338	Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	JP Morgan Chase 270 Park Avenue New York NY	Approved	\$650.00
51492	12A0339	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Time Inc. 1271 Avenue of the Americas New York NY	Approved	\$650.00
51493	12A0340	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	55 West 26th Street New York NY	Approved	\$650.00
51559	12A0341	Absolute Electrical Contracting, Inc. One Cross Island Plaza New York NY 11422	Requested approval for the electric service equipment proposed to be installed	210 East 86th Street New York NY	Approved	\$650.00
Service room door to open outwards. Job finalized 1/18/13.						
	12A0342	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	211 East 13th Street New York NY	On Hold	\$650.00
1) Feeders over fused 2500 amps. 2) 5' clearance in front S/S 200A not provided. 3) Feeder overfused 2500 amps S/S. 4) Two means of egress not provided for S/S room.						

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51558	12A0343	A & R Electrical Maintenance, Inc. 85-44 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	4339-4347 White Plains Road Bronx NY	Approved	\$650.00
1) Main landing jumper not provided at 600 amps s/s at trans s. 2) Fire rated conductors cannot be installed for the fire pump. (Only concrete encasement). Job finalized 1/18/13.						
51609	12A0344	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	The Beacon School 521 West 43rd Street New York NY	Approved	\$650.00
1) Bus undersized in swbd #1. 2) Generator and distribution cut sheets not provided. 3) Verify that fire rated conductors are not being installed. 4) Vertical bus sizes not show on drawing. 5) Column blocking front of service switch #5. 6) 1 Line drawing does not match manufacturers cut sheet 800 amp sq'. Job finalized 3/28/13. 5/20/16 Swapped 1 and 2-Revision 3.						
	12A0345	New Phase Electrical Contractors, Inc. 725 East 136th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	200 West 86th Street New York NY	On Hold	\$650.00
51505	12A0346	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU Langone Med. Ctr-Energy 550 First Avenue New York NY	Approved	\$650.00
Indicate cogen grounding resistor switching in sequence of operation for black start mode and sync back to Con ED. Job finalized 12/20/12.						
51494	12A0347	Royal Electrical & Wiring Corp. 27-07 BQE West Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	62 Avenue B New York NY	Approved	\$650.00
5/13/14 Swapped Rev 1. 7/22/14 Swapped 1 and 2 Rev 5 and added HDP physical.						

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51556	12A0348	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	40 North 4th Street Brooklyn NY	Approved	\$650.00
1) 10' tap conductors at 400 amp trans-s/disc. Sw. undersize. 2) Fire pump meter ILine drawing does not match room layout drawings. Job finalized 1/17/13.						
51495	12A0349	USA Electrical Services 77-08 21st Avenue East Elmhurst NY 11370	Requested approval for the electric service equipment proposed to be installed	540 Main Street New York NY	Approved	\$650.00
51516	12A0350	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	154 West 70th Street New York NY	Approved	\$650.00
Tap conductors at 600 amps disconnect switch ct undersize (2 sets 300 kilil cu=570 amps). Job finalized 12/28/12.						
51517	12A0351	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Boston Properties 540 Madison Avenue New York NY	Approved	\$650.00
#6 supplemental grounding electrode and building steel undersize Article 250.53 D(z). Job finalized 12/28/12.						
51518	12A0352	RPM Electric Inc. 480 10th Avenue New York NY 10018	Requested approval for the electric service equipment proposed to be installed	641-637 West 50th Street New York NY	Approved	\$650.00
Supplemental grounding electrode to building steel undersize. Job finalized 1/2/13.						

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51519	12A0353	Goldstar Electrical 59-24 57th Street Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	364 6th Avenue New York NY	Approved	\$650.00
1) Need signs at both service room doors. 2) Supplemental grounding electrode not provided at new 800 amp s/s. Job finalized 12/28/12.						
51610	12A0354	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	400 Park Avenue South New York NY	Approved	\$650.00
1) #6 supplemental grounding electrode to building steel undersize Article 250.66 and Article 53(D)(z). 2) Submit neutral load calculation s/s #1 s/s #2 and #3. 3) Relabel s/s 2000 amps. 2/25/13- #2 not address. New- #(4) S,S, #4 feeders overfused/undersized Article 240.4(c). Job finalized 3/28/13. 6/21/16 Swapped drawings 1,2 and 3-Revision 7						
51520	12A0355	E.S.B. Electric Corp. 250 Walton Avenue, Suite 25 Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Hotel Edison 228 West 47th Street New York NY	Approved	\$650.00
1) #6 supplemental grounding electrode to building steel undersize Article 250.77/Article 250.53(D). 2) 400A retail trans-s switch backward on drawing. Job finalized 12/28/12. 1/30/15 Swapped Drawings 1,2, and 3, Revision 3.						
51496	12A0356	E.S.B. Electric Corp. 250 Walton Avenue, Suite 25 Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	205 West 39th Street New York NY	Approved	\$650.00
	12A0357	Campbell and Dawes Ltd. Electl Contrs. 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	544 West 19th Street New York NY	Denied	\$650.00
1) Water damaged equipment and its association to be replaced. 2) Contractor submitted original drawings from 2005 submitted by originally by Wade Electric Co and documentation from the original manufacturer or a nationally recognized testing laboratory not provided attesting that the electrical equipment was found safe to re-energize and use for the future.						

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51497	12A0358	Arc Electl & Mechanical Contrs, Corp. 28 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Newtown Creek 329 Greenpoint Avenue Brooklyn NY	Approved	\$650.00
	12A0359	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	7 Hanover Square New York NY	On Hold	\$650.00
<p>1) Verify that feeders comply with 590.4(B). 2) Tap conductors to temp switchboard 2 &amp; 4 undersized. 3) Temp feeders to switchboard 1 &amp; 3 over fused. 4) Where is the location of new temp electrical service room? 5) Generator and open feeders supplying the premises to comply with 590.4 (B) Exception for qualified people. 6) Verify how conductors are being installed. 12/10/13 See attached letter from contractor that the temporary service was removed and the new service is installed, the approval # for the new service is 51611, submittal #13!0061 for the 2/20/2013 meeting was "pending" Approved on 3/28/13.</p>						
51551	12A0360	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	175 Water Street New York NY	Approved	\$650.00
51512	12A0361	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	400 West 12th Street New York NY	Approved	\$650.00
<p>Show size of vertical bus in switchboard 1 last section. Job finalized 12/26/12.</p>						
51498	12A0362	Copper City Electric Corp. 330 East 38th Street-Suite 5G New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Thor Equities 284 Livingston Street Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0363	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	NY Hilton 1335 Sixth Avenue New York NY	On Hold	\$650.00
1) Temp feeders over fused. 2) Equipment grounding conductors undersized. 3) Temp equipment to comply with Advisory Board clearances.						
51499	12A0364	Commercial Electric Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Cushman & Wakefield 119 West 40th Street New York NY	Approved	\$650.00
51521	12A0365	Platinum Electrical Contracting, Inc. 478 Wild Avenue Staten NY 10314	Requested approval for the electric service equipment proposed to be installed	101 Avenue of the Americas New York NY	Approved	\$650.00
1) 277/480V 2000 amp switch to be ground fault protected. 2) Verify that ATS are 3 pole type. 3) Coordinate fusing 2000 to 1350. 4) Loads out of emergency distribution board not identified. Job finalized 1/2/13. 12/10/13 Swapped Rev 3. 4/16/14 Swapped Revision 4.						
	12A0366	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	100 Wall Street New York NY	Denied	\$650.00
Verify whether there is 3 or 1 generators. 12/28/12-No good new (1) submit cut sheet for DLO cable to verify cable as dual rating. 2/20/13-Temp. service ent. Installations not as per Article 590.4(A).						
51500	12A0367	Anthony G. Ferry Inc. 1916 Park Avenue New York NY 10037	Requested approval for the electric service equipment proposed to be installed	240 Manhattan Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51592	12A0368	Meir Electrical Corp. 423 East 78th Street New York NY 10021	Requested approval for the electric service equipment proposed to be installed	American Jewish Committee 165 East 56th Street New York NY	Approved	\$650.00
Service room door to open outwards. Job finalized 3/14/13.						
51501	12A0369	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 Fifth Avenue New York NY	Approved	\$650.00
	12A0370	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	199 Water Street New York NY	On Hold	\$650.00
1) Service entrance conductors to 1600 amp service switches undersized. 2) Bus sizes in swbd TDP-1 and TDP-2 not shown. 3) Generator to have ground fault protection. 4) Fire pump emergency feeder to be fire rated. 5) Generator cut sheet not provided. 6) Service room doors to open outward.. 7) Verify which equipment will stay and which equipment will be removed.						
	12A0371	4000 Electric Corp. 1244 Ogden Avenue Bronx NY 10452	Requesting permission to omit an additional insulated equipment grounding conductor in a wiring method that is used to connect devices in medical examination rooms.	3056 Third Avenue Bronx NY	Denied	\$0.00
51502	12A0372	Limongelli Electric Corp. 214-41 42nd Avenue, Fourth Floor Bayside NY 11361	Requesting permission to replace existing load side meter bank disconnect switches with new where the height of the disconnect switches will be approximately 7'5" off of the floor in a building that has trained maintenance staff	401 East 34th Street New York NY	Approved	\$0.00
With the stipulation that a ladder is provided at each meter bank location with permanent signage stating: This ladder is to stay in this location for accessing the meterbanks disconnect switches.						

# ADVISORY BOARD CALENDAR

**December 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0373	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requesting permission to replace storm damaged medium voltage 15KV switch and medium voltage transformer like and kind as per Advisory Board approval 46888	Ocean Bay Apartments, Bldg 22 444 Beach 54th Street Far Rockaway NY	Denied	\$0.00
1) Special permission is not for an exact one for one replacement. 2) Was entire service switchgear and distribution panelboards water damaged? 3) Were underground feeders water damaged? 4) Commission documentation from the original manufacturers for switch enclosure and refurbished switches not provided. 5) Advisory Board drawings showing complete details to be submitted.						
	12A0374	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requesting permission to replace a storm damaged medium voltage transformer like and kind as per Advisory Board approval 46888.	Ocean Bay Apartments, Bldg 14 410 Beach 54th Street Far Rockaway NY	Denied	\$0.00
1) Special permission is not for an exact one for one replacement. 2) Was there any other damaged equipment besides the transformer? 3) Advisory Board drawings showing complete details to be submitted.						
51503	12A0375	Teknion Limited 1150 Flint Rd. Toronto, ON, Canada M3J2J	Requested approval for use in New York City of your Teknion Interpret Furniture System.		Approved	\$200.00
51522	12A0376	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	100 Maiden Lane New York NY	Approved	\$0.00
#6 supplemental grounding electrode to building steel undersize Article 250.53(D) service A & B. Job finalized 12/28/12.						