

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|---|--|--|----------|--------|
| 46881CO | 06A0030CO | A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433 | Requested approval for the electric service equipment proposed to be installed | Desmond Tutu Educ. Ctr 175 9th Avenue New York NY | Approved | \$0.00 |
| Carry over from January 25, 2006 meeting. Service bus in CT cabinet undersized. Job finalized on 4/24/07. | | | | | | |
| 47285CO | 06A0341CO | Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418 | Requested approval for the electric service equipment proposed to be installed | 23-45 Caton Place New York NY | Hold | \$0.00 |
| Carry over from July 12, 2006 meeting. 1) 2 switches installed before fire pump feeder. 2) Neutral not bonded to enclosure in 800 amp service switch. 3) Tap for fire pump feed taken off of switchboard. 4) Short circuit calculations not provided, service switch and meter banks. 5) 800 amp switch for fire pump in same room as service equipment. 6) Doors to service door to open out. | | | | | | |
| 47489CO | 06A0462CO | Hi-Rite Electric Corp. 1335 61st Street Brooklyn NY 11219 | Requested approval for the electric service equipment proposed to be installed | 199 Lafayette Street New York NY | Denied | \$0.00 |
| Carry over from October 25, 2006 meeting. 1) Service conductors are undersized. 2) Tap of a tap is not permitted. | | | | | | |
| 47525CO | 06A0554CO | Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121 | Requested approval for the electric service equipment proposed to be installed | The Plaza Hotel Fifth Avenue at Central Park South New York NY | Hold | \$0.00 |
| Carry over from November 15, 2006 meeting. The service bus must be increased to comply with the old NYC code. | | | | | | |
| 47532CO | 06A0532CO | Staunton Chow, P.C. Engs. & Architects 100 West 32nd Street New York NY 10001 | Requested approval for the electric service equipment proposed to be installed | Columbia University 601 West 115th Street New York NY | Approved | \$0.00 |
| Carry over from November 15, 2006 meeting. | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|---|--|--|----------|----------|
| 47534CO | 06A0535CO | P.E. Stone, Inc. 50 Watts Street New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | Int'l Stock Exchange 50 Broad Street, 27th and 28th Floor: New York NY | Approved | \$0.00 |
| Carry over from November 15, 2006 meeting. | | | | | | |
| 47554 | 06A0563 | Philco Electrical Contractors 3183 East Tremont Avenue Bronx NY 10461 | Requested approval for the electric service equipment proposed to be installed | Sweet Sams Bakery 1261 Seabury Avenue Bronx NY | Approved | \$650.00 |
| | | | | | | |
| 47555 | 06A0562 | T & T Electrical Corp. 24-30 47th Street Astoria NY 11103 | Requested approval for the electric service equipment proposed to be installed | La Casa Del Sol 34-63 3rd Avenue Bronx NY | Approved | \$650.00 |
| 1) 400 and 200 amp disconnect switches neutrals are bonded. 2) Service room doors to comply with 110.26 (c) (2) A & B. Job finalized 1/22/07. | | | | | | |
| 47556 | 06A0561 | Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036 | Requested approval for the electric service equipment proposed to be installed | Pier 88 632 12th Avenue New York NY | Hold | \$650.00 |
| 1) 15 ATS #16 3 or 4 pole. 2) Bond neutral to enclosure in transformer #19. 3) Doors to substation #2 does not comply with 110.26 c2 A,B. 4) Indicate switch/fuse sizes on single line. 5) Provide short circuit coordination study. 6) Provide FCO for F.A. 7) F.P. controller & ATS not permitted in service room. | | | | | | |
| 47557 | 06A0559 | Trince Electric Inc. 330 East 35th Street New York NY 10016 | Requested approval for the electric service equipment proposed to be installed | 65 Central Park West New York NY | Approved | \$650.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|---|--------------|--|--|--|----------|----------|
| 47558 | 06A0583 | Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451 | Requested approval for the electric service equipment proposed to be installed | PS 245 378 Seneca Avenue Ridgewood NY | Approved | \$650.00 |
| | | | | | | |
| 47559 | 06A0557 | Royal Electric and Wiring Corp. 27-07 BQE West Woodside NY 11377 | Requested approval for the electric service equipment proposed to be installed | 55 Berry Street Brooklyn NY | Approved | \$650.00 |
| 1) Verify feeder to 1200 amp panelboard. 2) Provide proper clearances inside of service room. 3) 3rd fuse not provided. 4) 1200 amp service panelboard neutral not bonded to enclosure. Job finalized 12/19/06. | | | | | | |
| 47560 | 06A0588 | Dola Electrical Co., Inc. 3044 E. Tremont Avenue Bronx NY 10461 | Requested approval for the electric service equipment proposed to be installed | 1601 Bronxdale Avenue Bronx NY | Approved | \$650.00 |
| 1) Neutral on transformer secondary not bonded to building steel. 2) Primary 125% full load secondary 250A fu. 3) Feeder on load side of 400 amp disconnect switch undersized. 4) Protected by fuse. 5) Tap for 200A switch must comply w/10ft tap rule. Job finalized 1/19/07. | | | | | | |
| 47561 | 06A0571 | Dooley Electric Co., Inc. 45-54 37th Street Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | Cooper Square Hotel 25 Cooper Square New York NY | Approved | \$650.00 |
| | | | | | | |
| 47562 | 06A0569 | Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY | Requested approval for the electric service equipment proposed to be installed | 100 Jay Street Brooklyn NY | Approved | \$650.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|---|--|--------------------------------------|----------|----------|
| 47563 | 06A0567 | Gilston Electrical Maintenance Corp. 453 East 175th Street Bronx NY 10457 | Requested approval for the electric service equipment proposed to be installed | 301 West 118th Street New York NY | Approved | \$650.00 |
| + | | | | | | |
| 47564 | 06A0565 | Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309 | Requested approval for the electric service equipment proposed to be installed | 270 East Burnside Avenue Bronx NY | Approved | \$650.00 |
| 47565 | 06A0574 | S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215 | Requested approval for the electric service equipment proposed to be installed | 1510 2nd Avenue New York NY | Approved | \$650.00 |
| 1) Fire pump service switch (5) is connected to through bus after s.s #1. 2) 500KVA XFMR to be grounded at XFMR or secondary main switch. Job finalized 1/17/06. | | | | | | |
| 47566 | 06A0576 | S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215 | Requested approval for the electric service equipment proposed to be installed | 200 West End Avenue New York NY | Approved | \$650.00 |
| 1) 500KVA XFMR to be grounded at XFMR or secondary main switch. 2) S.S. #4 fuse undersized for F.P. 3) F.P. feeder to be rated. Job finalized 10/29/07. | | | | | | |
| 47567 | 06A0577 | Power Tech Electric Corp. 245 West 29th Street New York NY 10001 | Requested approval for the electric service equipment proposed to be installed | 245 Broadway New York NY | Ok, but | \$650.00 |
| Construct new wall to put drain pipe outside switchboard room. | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|---|--|---|----------|----------|
| 47568 | 06A0580 | Vertex Electrical Corporation 28-41 Steinway Street Long Island City NY 11103 | Requested approval for the electric service equipment proposed to be installed | 545 W. 110th St., a.k.a 2840 Bdwy New York NY | Approved | \$650.00 |
| Provide fusing for 4-500 KCM, 1600A too large. Job finalized 1/3/07. | | | | | | |
| 47569 | 06A0582 | Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232 | Requested approval for the electric service equipment proposed to be installed | 9 E. 42nd St., a.k.a. 317 Madison Av New York NY | Approved | \$650.00 |
| | | | | | | |
| 47570 | 06A0587 | CSA Engineering Services 37 Miry Brook Road Danbury CT 06810 | Requested approval for the electric service equipment proposed to be installed | 110 East 59th Street New York NY | Approved | \$650.00 |
| 1) Provide confirmation that taps feeding panels CLP-1 and CLP-2 do not exceed 25 ft.. 2) Coordinate details for panel 'PLP' with 1-Line diagram. Job finalized 2/9/07 | | | | | | |
| 47571 | 06A0589 | J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | 37-60 88th Street New York NY | Approved | \$650.00 |
| | | | | | | |
| 47572 | 06A0560 | Jeco Electrical Service Corp. 1162 Intervale Avenue Bronx NY 10459 | Requested approval for the electric service equipment proposed to be installed | 756 Myrtle Avenue Brooklyn NY | Approved | \$650.00 |
| 1) Service bus feeding the 3-600 amp service switches is undersized. 2) Bonding and grounding not shown on drawing. 3) Neutral disconnect link not provided in 1200 panelboard. Job finalized 1/22/07. | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|--|--|--|----------|----------|
| 47573 | 06A0558 | B.A.P. Electric Corp. 470 Austin Place Bronx NY 10455 | Requested approval for the electric service equipment proposed to be installed | Mount Hope Community Ctr. 55 East 175th Street Bronx NY | Approved | \$650.00 |
| 1) Service entrance conductors have to be in sets of 500MCM. 2) Service entrance conductors are undersized. Job finalized 12/19/06. | | | | | | |
| 47574 | 06A0556 | Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416 | Requested approval for the electric service equipment proposed to be installed | 2 Gold Street New York NY | Hold | \$650.00 |
| Drawing to light can't be read. | | | | | | |
| 47575 | 06A0586 | Dal Electrical Corp. 218 52nd Street Brooklyn NY 11220 | Requested approval for the electric service equipment proposed to be installed | 157 Chambers Street New York NY | Hold | \$650.00 |
| 1) Drawing does not show where the fire pump is located. 2) Fire pump feeder not fire rated. 3) Provide short circuit calculations between service switch #1 and new panel TDP. 4) Neutral conductor not bonded to enclosure in fire pump service switch. 5) Clarify feed to fuse cutout. 6) Conductor sizes omitted in existing switchgear. | | | | | | |
| 47576 | 06A0564 | Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416 | Requested approval for the electric service equipment proposed to be installed | 1330 1st Avenue New York NY | Ok, but | \$650.00 |
| Explain how reduced neutral calculations were determined. | | | | | | |
| 47577 | 06A0570 | Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356 | Requested approval for the electric service equipment proposed to be installed | Peter Cooper Village/Stuyvesant 280 First Avenue New York NY | Hold | \$650.00 |
| 1) 2nd door required as per 110.26c2. 2) Provide Advisory Board clearances in front of 3000 amp service switch. | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|---|--|--|----------|----------|
| 47578 | 06A0568 | Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219 | Requested approval for the electric service equipment proposed to be installed | General Theological Seminary 175 Ninth Avenue New York NY | Approved | \$650.00 |
| | | | | | | |
| 47579 | 06A0566 | Robert B. Samuels Inc. 48 West 25th Street New York NY 10010 | Requested approval for the electric service equipment proposed to be installed | Emigrant Savings Banks 6 East 43rd Street New York NY | Approved | \$650.00 |
| | | | | | | |
| 47580 | 06A0572 | Consentini Associates Consulting Engs. Two Pennsylvania Plaza New York NY 10121 | Requested concept approval of | Alliance Bernstein 1345 Avenue of the Americas New York NY | Approved | \$650.00 |
| With the stipulation that full Advisory Board drawings are submitted for approval. | | | | | | |
| 47581 | 06A0573 | Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416 | Requested approval for the electric service equipment proposed to be installed | Battery Park Site #3 70 Little West Street New York NY | Approved | \$650.00 |
| GFP protection needed on 1200 amp transformer secondary switch. Finalized 1/19/07. | | | | | | |
| 47582 | 06A0575 | Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121 | Requested approval for the electric service equipment proposed to be installed | 551 Madison Avenue New York NY | Approved | \$650.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|---|--------------|--|---|---|----------|----------|
| 47583 | 06A0578 | Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416 | Requested approval for the electric service equipment proposed to be installed | 15 William Street New York NY | Approved | \$650.00 |
| 480 volt 1200 amp transformer secondary switch not GF protected. Finalized job 1/19/07. | | | | | | |
| 47584 | 06A0579 | Solar Electric Systems Inc. 452 West 55 Street New York NY 10019 | Requested approval for the electric service equipment proposed to be installed | 100 West 18th Street New York NY | Approved | \$650.00 |
| 47585 | 06A0581 | Atlas--Acon Electric Service Corp. 283 Hudson Street New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | 25-11 Hunters Point Avenue Long Island City NY | Approved | \$650.00 |
| 47586 | 06A0585 | Levest Electric Corp. 325 West 37th Street New York NY 10018 | Requested approval for the electric service equipment proposed to be installed | Amalgamated Bank 275 7th Avenue New York NY | Approved | \$650.00 |
| 47587 | 06A0590 | J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | 81-11 45th Avenue Elmhurst NY | Approved | \$650.00 |
| New distribution panel no coordination 800A A4BT-500A A2K. Job finalized 12/18/07. | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|---|--------------|--|--|---|----------|----------|
| 47588 | 06A0584 | Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416 | Requested approval for the electric service equipment proposed to be installed | NY Mets New Stadium Queens NY | Hold | \$650.00 |
| | | | | | | |
| 47589 |) | Trincity Electric Inc. 134-47 Springfield Boulevard Springfield Gardens NY 11413 | Requesting permission due to a corrosive area, Far Rockaway, Queens to install overhead service entrance conductors in Schedule 80 non metallic conduits on 12 buildings. | 2107, 2109, 2111 & 2115 Dix Ave, Far Rockaway NY | Approved | \$0.00 |
| | | | | | | |
| 47590 |)) | Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220 | Requesting permission to direct connect a fire pump controller that, is listed "suitable for use as service equipment" in a building, where the fire pump is located 60 feet away from the Con-Ed box. | 31-33 East 28th Street New York NY | Approved | \$0.00 |
| With the stipulation that signage is provided in the service rooms as per 230.(2)(E), and the service entrance conduits comply with 230.6 of the NEC. | | | | | | |
| 47591 |))) | Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451 | Requesting permission on a drawing Cal. #47468 presently on hold to leave the service room with one door of egress. | 25 Fifth Avenue New York NY | Hold | \$0.00 |
| Field inspector to check job site to determine if 2nd door can be installed. | | | | | | |
| 47592 |)))) | H & L Electric Inc. 41-11 28th Street Long Island City NY 11101 | Requesting permission to connect multi outlet assembly's by hand wired heavy duty rubber cords due to movement of the telescoping lift consoles. | 911 Center Metro Tech Center Brooklyn NY | Approved | \$0.00 |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|---|--------------|--|--|--|----------|----------|
| 47593 |))))) | A. Ceriello Electric, Inc. 15 Carroll Street Brooklyn NY 11231 | Requesting permission due to a hardship to replace, to leave as installed AC cable as the wiring method inside a place of assembly. | 213-215 North 8th Street Brooklyn NY | Approved | \$0.00 |
| With the stipulation that where the AC cable can be replaced with MC cable is corrected, and where the AC cable can't be replaced, ground fault circuit breakers must be installed on those circuits. | | | | | | |
| 47594 |))))) | D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464 | Requesting permission due to a hardship to replace, to leave as installed AC cable as the wiring method inside of a place of assembly. | Gramercy Park Tavern 2 Lexington Ave New York NY | Approved | \$0.00 |
| With the stipulation that ground fault circuit breakers are installed on all of the circuits wired in AC cable. | | | | | | |
| 47595 |))))) | Beacon Electric Corp. 266 Jericho Turnpike, Suite LL3 Floral Park NY 11001 | Requesting permission due to a hardship to replace, to leave as installed AC cable as the wiring method inside of a place of assembly. | 1223 Coney Island Avenue Brooklyn NY | Approved | \$350.00 |
| With the stipulation that ground fault circuit breakers are installed on all of the circuits wired in AC cable. | | | | | | |
| 47596 |))))) | Promax Electrical Contracting Corp. 112-08 101 Avenue Richmond Hill NY 11419 | Requesting permission to leave as installed AC cable as the wiring method inside of a place of assembly. | 4516 Avenue D Brooklyn NY | Approved | \$0.00 |
| With the stipulation that ground fault circuit breakers are installed on all of the circuits wired in AC cable. | | | | | | |
| 47597 |))))) | Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121 | Requesting permission to install kitchen counter receptacles 23 inches above the countertop in 449 apartments. | 360 Furman Street Brooklyn NY | Denied | \$0.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|---|---|---|----------|--------|
| 47598 |))))))))) | Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York NY 10018 | Requesting permission to replace an existing 480 volt 5000 amp service switch and distribution board like and kind with ground fault protection. | Brookfield Properties One Liberty Plaza New York NY | Denied | \$0.00 |
| One for one replacement is limited to switch interiors only. | | | | | | |
| 47599 |))))))))) | Levest Electric Corp. 325 West 37th Street New York NY 10018 | Requesting permission to install MI cable as service entrance conductors that will run approximately 35 feet without physical protection, see drawing 47533. | 275 7th Avenue New York NY | Hold | \$0.00 |
| Provide coordinated floor plan showing MI cables routing, the sketch provided does not match the room layout of this special permission. | | | | | | |
| 47600 |))))))))) | Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121 | Requesting permission to utilize 1000 amps per square inch in lieu of 800 amps per square inch for the existing service bus due to the retro fit of new interior switches. | The Plaza Hotel Fifth Avenue @ Central Park South New York NY | Approved | \$0.00 |
| With the stipulation that the service bus sizing must comply with the old New York City Electrical Code Advisory Board Rules. | | | | | | |
| 47601 |))))))))) | Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121 | Requesting permission to replace like and kind the interiors of 9 service switches. | The Plaza Hotel Fifth Avenue @ Central Park South New York NY | Approved | \$0.00 |
| With the stipulation that the bottoms of the switchboard cabinets are not open. | | | | | | |
| 47602 |))))))))) | Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121 | Requesting permission to install switchgear where a column is partially blocking the front clearance of a service switch providing a 31 inch clearance instead of 5 feet in a service room. | The Plaza Hotel Fifth Avenue @ Central Park South New York NY | Approved | \$0.00 |
| As long as the existing bus and service equipment remains as is, as per special permission, Cal.# 47600. | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|------------|--------------|---|---|--|----------|----------|
| 47603 |))))))))) | Chaim Electric 2920 Avenue J Brooklyn NY 11210 | Requesting concept approval to leave one door to a service room as per attached sketch. | 12015 Flatlands Avenue Brooklyn NY | Approved | \$0.00 |
| | | | | | | |
| 47604 |))))))))) | Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232 | Requesting permission to install manufactured wiring system in a building 22 feet off of the finished floor above the line of the roof joists. | 92-30 168th Street, 1st Floor Jamaica NY | Denied | \$0.00 |
| | | | | | | |
| 47605 |))))))))) | James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231 | Requesting permission to tap the emergency feed for a fire alarm system from the fused bus of an emergency switchboard and to leave the automatic transfer switch inside of the emergency switchboard room. | Verizon 221 East 37th Street New York NY | Denied | \$0.00 |
| | | | | | | |
| 47606 |))))))))) | M-E Engineers 417 Fifth Avenue, 5th Floor New York NY 10016 | Requesting permission due to the New York City Parks Department's non approval to install medium voltage at the job site to install a transformer to correct voltage drop on service entrance conductors that will run 1600 feet to a building. | Central Park Police Precinct @ 86th Street New York NY | Denied | \$0.00 |
| | | | | | | |
| 47607 | 06A0591 | Cooper Lighting 1121 Hwy #74 South Peachtree City GA 30215 | Requested approval for use in New York City of your Light Fixtures 2x4-2GR8 and 2GC8 Series, Recessed Lensed Troffer. | | Approved | \$200.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

December 13, 2006

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|------------|--------------|---|--|---|----------|----------|
| 47608 | 06A0592 | Elliot Energy Systems, Inc. 2901 S.E. Monroe Street Stuart Fl 34997 | Requested approval for use in New York City TA100 Microturbines. Model/Series Numbers: TA100-CHP: 910110, 910112 , 910116 and 910117 . | | Approved | \$200.00 |
| | | | | | | |
| 47609 | % | Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416 | Requesting permission to install 28 sets of concrete encased service entrance conductors in fiber glass conduit(Cal. 47581). | Battery Park Park City Site 3 70 Little West Street New York NY | Approved | \$0.00 |
| | | | | | | |