

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45219CO1	03A0548CO1	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 89-63 163rd Street Queens NY	Hold	\$0.00
Carry over from 12/15/04 meeting. Provide submission on Ideal equipment.						
45658CO	04A0184CO	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	666 3rd Avenue New York NY	Approved	\$0.00
Carry over from 5/19/04 meeting.						
46747CO	05A0538CO	Hylan Electrical Contracting, Inc. 1150 South Avenue, Corporate Park Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	NYS-DOT 28-11 Queens Plaza North Long Island City NY	Approved	\$0.00
Carry over from 11/16/05 meeting.						
46768CO	05A0559CO	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Charter Mac 625 Madison Avenue New York NY	Approved	\$0.00
Carry over from November 16, 2005 meeting.						
46811	05A0611	Skyline Electrical Contracting Corp. 1299 Richmond Avenue Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	205 West 39th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46812	05A0631	James F. Volpe Electl Contracting Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	1185 6th Avenue New York NY	Approved	\$650.00
46813	05A0632	Coastal Electrical Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	PS/IS 263 222-14 Jamaica Avenue Queens NY	Hold	\$650.00
<p>1) Main switches in HV-DP-B drawn backward. 2) Explain GFP with common neutral. 3) ATS's for 4-wire loads should be 4-pole. 4) Verify adequacy of 25A CB as primary for 30 KVA F.A. XFMR. 5) On tie switch provide signage fuses energized on backfeed. 6) Neutral bonds in HV-DP-B not permitted. 7) Reconfigure F.A. and F.P. circuits to eliminate multiple overcurrent. 8) Show clearance of live bus in service switchboard above floor.</p>						
46814	05A0634	James F. Volpe Electl Contracting Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Verizon 5030 Broadway New York NY	Approved	\$650.00
46815	05A0633	I.D.K. Electric Co., Inc. 443 Park Avenue South, Suite 1004 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	2543 Webster Avenue Bronx NY	Approved	\$650.00
46816	46816	Irwol Electric, Corp. 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	157 Hudson Street New York NY	Ok, but	\$650.00
<p>1) Confirm coordination of fuses for service SW #4. 2) Indicate rating of meter banks and show adequacy of circuit breakers.</p>						

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46817	05A0628	Irwol Electric, Corp. 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	383 Carlton Avenue Brooklyn NY	Ok, but	\$650.00
Fire pump feeder must be fire-rated equipment shall not obstruct egress path in stairwell.						
46818	05A0626	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	38-44 Warren Street New York NY	Approved	\$650.00
46819	05A0621	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	170 East End Avenue New York NY	Approved	\$650.00
46820	05A0618	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NYU-6th Floor 194 Mercer Street Elmhurst NY	Approved	\$650.00
46821	05A0616	Tarasis Electric Corp. 36-08 Ninth Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Flags High School 470 Jackson Avenue Bronx NY	Approved	\$650.00
1) Tap conductor is undersized. Change to 400 MCM.						

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46822	05A0615	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Atlas Park Building #8 71-19 80th Street Flushing NY	Approved	\$650.00
1) Provide short circuit curves between 250 and 400 amp fuses. 2) Show incoming copper to switchgear.						
46823	05A0599	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Crown Castle Media 230 East 179th Street Bronx NY	Approved	\$650.00
46824	05A0609	June Electric Corp. 2025 Continental Avenue, Suite 5E Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	15 East Clarke Place Bronx NY	Approved	\$650.00
46825	05A0608	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	871 Elton Avenue Bronx NY	Approved	\$650.00
46826	05A0607	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	One Madison Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46827	05A0606	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Rockefeller Center 620 5th Avenue New York NY	Approved	\$650.00
46828	05A0601	Alef Electric Inc. 246 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Touqueville 3 East 15th Street New York NY	Approved	\$650.00
46829	05A0597	Al-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	106 Mott Street New York NY	Hold	\$650.00
1) Verify fire pump FLA and its service equipment. 2) Service conductor and load conductors in same cabinet. 3) Provide bus sizes on 1 line diagram.						
46830	05A0596	Chase Electric Inc. 97-45 99th Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Kings Cnty Senior Residence 600 Albany Avenue Brooklyn NY	Approved	\$650.00
46831	05A0592	B & G Electrical Contractors of NY Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	25 West 51st Street New York NY	Hold	\$650.00
1) Tap for fire pump must be fire-rated if run outside service room. FP switch not shown on floor plan. 2) Show elevation of stairway and bus duct area. Clarify head room.						

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46832	05A0627	Gannett Fleming, Inc. P.O. Box 560 Hammonton NJ 08037	Requested approval for the electric service equipment proposed to be installed	Visy Paper Staten Island Facility Staten Island NY	Hold	\$650.00
1) Provide manufacturer's drawings. 2) Provide SFQ of operation. 3) Phasing sequence.						
46833	05A0612	High-Tech Electrical Services Corp. 36-33 23rd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	GM Building 767 Fifth Avenue New York NY	Approved	\$650.00
Verify if the panel is within 25' of the transformer.						
46834	05A0610	Hugh O Kane Electric Co., Inc. 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	90 John Street New York NY	Hold	\$650.00
1) Provide sequence of operation of interlock system. 2) Is emergency Board feeding life safety in service room? 3) Are AT's 3 or 4 pole type?						
46835	05A0635	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Bronx Public Library 296/310 East Kingsbridge Road Bronx NY	Approved	\$650.00
1) Bond neutral at generator. 2) Show vertical bus sizes on drawing.						
46836	05A0625	Gilston Electrical Contracting Corp. 336 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	NYCHA-Polo Grnds Twr-Bldg.1 2931 Frederick Douglas Boulevard New York NY	Approved	\$650.00
1) Bond neutral in transformer only. 2) Move ground and supply to transformer not disc 4000 am switches.						

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46837	05A0624	Gilston Electrical Contracting Corp. 336 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	NYCHA-Polo Grnds Twr Bldg.2 2971 Frederick Douglas Boulevard New York NY	Approved	\$650.00
1) Bond neutral at transformer only. 2) Move ground and supply from 4000 disconnect switch to transformer.						
46838	05A0623	Gilston Electrical Contracting Corp. 336 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	NYCHA-Polo Grnds Twr Bldg 3 2949 Frederick Douglas Boulevard New York NY	Approved	\$650.00
1) Bond neutral at transformer only. 2) Move ground and supply from 4000 disconnect switch to transformer.						
46839	05A0622	Gilston Electrical Contracting Corp. 336 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	NYCHA-Polo Grnds Twr Bldg 4 2991 Frederick Douglas Boulevard New York NY	Approved	\$650.00
1) Bond neutral at transformer only. 2) Move ground and supply from 4000 disconnect switch to transformer.						
46840	05A0591	Galaxy Tri-State Electric, Inc. P.O. Box 280787 Queens Village NY 11428	Requested approval for the electric service equipment proposed to be installed	350 Central Park West New York NY	Approved	\$650.00
Provide short circuit calculators.						
46841	05A0595	Judd Electric, Inc. 327 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	79 Madison Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46842	05A0620	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	45 East 89th Street New York NY	Hold	\$650.00
1) Verify feeders to existing service equipment undersized. 2) Provide FLA of fire pump.						
46843	05A0619	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	200 Chambers Street New York NY	Approved	\$650.00
1) Verify # of conduits to fire pump. 2) Verify neutral disconnect link for 1200 amp service switch.						
46844	05A0617	James F. Volpe Electl Contrg Corp. 81Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	P.S./I.S. 260 40-20 100th Street Elmhurst NY	Approved	\$650.00
46845	05A0614	Nelson & Tom Maintenance Inc. 33 Henry Street. West Store New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Prince Tower 133-53 37th Avenue Flushing NY	Approved	\$650.00
1) Increase bus size in EDP panel. 2) Provide ground and supplemental ground.						
46846	05A0605	York Electrical Contractors Inc. 163-10 Crocheron Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	Eagle Building 24th Avenue & 21st Street Astoria NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46847	05A0604	V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	200 Schemerhorn Street Brooklyn NY	Approved	\$650.00
46848	05A0603	Maximum Electric Corp. 34-17 Broadway Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	47-50 30th Street Long Island City NY	Approved	\$650.00
46849	05A0600	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	155 Canal Street New York NY	Approved	\$650.00
46850	05A0613	Coffey Electrical Co. Inc. 65-35 Grand Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	53 East 66th Street New York NY	Approved	\$650.00
46851	05A0602	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	304 Park Avenue South New York NY	Approved	\$650.00
No supplemental ground provided.						

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46852	05A0598	J.H. Electric of New York, Inc. 59-01 Grand Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Time-Life Building 1271 6th Avenue, 3rd Floor New York NY	Approved	\$650.00
46853	05A0593	United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	7 Bushwick Place New York NY	Approved	\$650.00
46854	05A0594	Dola Electrical Co., Inc. 3044 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	1601 Bronxdale Avenue Bronx NY	Approved	\$650.00
46855	05A0630	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	IKEA Home Furnishings 1 Beard Street Brooklyn NY	Approved	\$650.00
1) Provide service and supplemental grounds. 2) 3000 amp service switches are reversed on drawing.						
46856	*	I.S.M. Electric, Inc. 512 73rd Street Brooklyn NY 11209	Requesting permission not to file Advisory Board drawings on a 1000 KVA service where three 100 amp second fusing disconnect switches were removed and replaced with a 200 amp disconnect switch that were fed by a 400 amp service switch.	681 8th Avenue	Approved	\$350.00

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46857	----	Queens Electrical Contractors, Inc. 34-05 34th Street Astoria NY 11106	Requesting permission to leave as installed 5 commercial meters and service switches located inside a structure outside of the building.	150-33 14th Avenue Queens NY	Approved	\$0.00
with stipulation that the metal structure containing the service equipment is grounded by means of bonding jumper to the grounding electrode conductor.						
46858	----	Motroneo & Marinos United Elect. Co., Inc 58-15 Fresh Pond Rd. Maspeth NY 11378	Requesting permission to install Schedule 80 non metallic conduit standpipes on 2, two family buildings located in an highly corrosive area, Far Rockaway Queens.	171 and 173 Beach 26th Street Far Rockaway NY	Approved	\$0.00
46859	-----	AEC Electrical Co., Inc. 6005 Ft. Hamilton Parkway Brooklyn NY 11219	Requesting permission not to group together service equipment in an commercial building that will be split into two separate businesses, signage will be provided at each service indicating where the other service is located.	832-838 62nd Street Brooklyn NY	Approved	\$0.00
46860	----	GB Electrical Corp. 1874 Clove Road Staten Island NY 10304	Requesting permission on a 1 family building with an indoor service switch to add an additional service on the outside of the building that will power a sewer ejection pump.	96 Brandis Avenue Staten Island NY	Approved	\$0.00
46861	----	M. Chetrit 56 West 45th Street New York NY 10036	Requesting permission on an existing 265/460 volt 1000 KVA service, to replace one for one 3 defective service switches rated over 1000 amps without ground fault protection.	555 Madison Avenue New York NY	Hold	\$0.00
More information needed.						

ADVISORY BOARD CALENDAR

December 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46862	-----	Laredo Electric, Inc. 2477 Arthur Kill Road Staten Island NY 10309	Requesting permission due to a lack of space inside the existing service room to leave as installed a new service switch for commercial space on the outside of the building.	2477 Arthur Kill Road Staten Island NY	Approved	\$0.00