

ADVISORY BOARD CALENDAR

December 14, 2011

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		J & R Rey Electrical Contrs Inc. 3471 Steenwick Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	Whole Foods Market 250 East 57th Street New York NY	Hold	\$650.00
1) Verify that service rooms are ventilated. 2) 4 sets of 500 MCM are over fused. 3) Decrease fusing or increase conductors to new 1600A disconnect switches. 4) Verify 500KVA transformer does not require front and rear access. 5) Provide size of pull box in transformer room and height of transformer. 6) Will pull box be accessible?						
		James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	1775 Broadway New York NY	Approved	\$650.00
51010		Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	481 Washington Street New York NY	Approved	\$650.00
Add door to service room or make an unobstructed means or egress out of the service room door(s). Job finalized 5/14/13.						
		Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	317 Avenue C New York NY	Approved	\$650.00
		P2 Electric, Inc. 416 Graham Avenue Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	240 Park Avenue South New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 14, 2011

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	The University Club One West 54th Street New York NY	Approved	\$650.00
		L.E.A. Electric Corp. 2112 Broadway, Suite 204 New York NY 10023	Requested approval for the electric service equipment proposed to be installed	195 Montague Street Brooklyn NY	Approved	\$650.00
		Bass Electrical Corp. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	355 Kingsland Avenue Brooklyn NY	Approved	\$650.00
Provide protection for equipment against vehicles. Job finalized 3/26/12.						
		Marcel Electrical Contracting Corp. 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	East Tower 505 West 37th Street New York NY	Approved	\$650.00
50912CO		Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	60 Wall Street New York NY	Approved	\$0.00
Carry over from October 19, 2011 meeting. 1) One door must be changed. . 2) Change fuses to 800A. Job finalized 8/1/12.						

ADVISORY BOARD CALENDAR

December 14, 2011

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Fairfield Inn & Suites 325 West 33rd Street New York NY	Approved	\$650.00
		Eastern Electrical Construction Inc. 149-07 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	247 West 46th Street New York NY	Approved	\$650.00
Service entrance conductors to 800A service switch are undersized. Job finalized 12/28/11.						
		Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	40 Worth Street New York NY	Approved	\$650.00
		James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Urban Health Plan 1054 Simpson Street Bronx NY	Approved	\$650.00
		Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Coney Island Commons-YMCA 2960 West 29th Street Brooklyn NY	Approved	\$650.00
Service switch #1 does not shown 2nd fusing. Job finalized 12/28/11.						

ADVISORY BOARD CALENDAR

December 14, 2011

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		Scott Electrical Service, LLC 40 Macon Street Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	80 Wythe Avenue Brooklyn NY	Hold	\$650.00
Provide drawings that do not smear.						
		Triborough Electric Inc. 36-20 164th Street Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	Coler Hospital 900 Main Street Roosevelt Island NY	Approved	\$650.00
		Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	NY Police Academy (East Bldg) 130-30 28th Avenue Queens NY	Ok, but	\$650.00
1) Room layout not provided. 2) Show conductors inside of the panelboards.						
		CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Rivington House 45 Rivington Street New York NY	Approved	\$650.00
		Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	156 5th Avenue New York NY	Approved	\$650.00
1) General notes not shown. 2) Show side clearances of new switchboard. 3) Is it possible to install the new switchboard in a different location? Job finalized 3/8/12.						

ADVISORY BOARD CALENDAR

December 14, 2011

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Newmark Knight Frank 440 Lafayette Street New York NY	Approved	\$650.00
		Ramdeens Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	1368 Fulton Street Brooklyn NY	Approved	\$650.00
		Seong Jin Electric Inc. 37-12 58th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Gertz Plaza 162-10 Jamaica Avenue Queens NY	Approved	\$650.00
		Al-Letric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Spring Hill Suites 112-15 Northern Blvd. Corona NY	Approved	\$0.00
Carry over from November 9, 2011 meeting.						
50957CO		A.T.J. Electrical Inc. 33-61 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Bronx Community College Bronx NY	Approved	\$0.00
Carry over from November 9, 2011 meeting. 10/21/13 Drawing cannot be swapped. 1) Service switch room doors not open in direction of egress. 2) No grounded conductor provided at 2500A service switch. 3) GFP not provided at 2-2500 amps s.s. 10/29/13 Swapped Rev 3.						

ADVISORY BOARD CALENDAR

December 14, 2011

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		Sterling Electric Inc. 863 Sterling Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Trey Whitefield School 17 Hinsdale Street Brooklyn NY	Approved	\$0.00
Carry over from November 9, 2011 meeting. Code: 230.42(A)(2).						
		American Fittings Corp. 17-10 Willow Street Fair Lawn NJ 07410	Requested approval for equipment for use in New York City of your Electrical Metallic Tubing raintight compression style fittings. Model/Series Numbers: EC750USRT thru EC755USRT(with or w/o "BUSRT" suffix) EC760USRT thru EC765USRT. Electrical rigid/MC conduit compression style fittings. Model/Series Numbers: NT2750 thru NT2759 (with or w/o "B" suffix), NT2760 thru NT2769. Electrical rigid conduit set screw style fittings. Model/Series Numbers: SNT1750 thru SNT1755 (with or w/o "B" suffix), SNT1760 thru SNT1765. Electrical Metallic Tubing compression style fittings. Model/Series Numbers: EC750US thru EC759US (with or w/o "BUS" suffix), EC760US thru EC769US. Electrical Metallic Tubing set screw style fittings. Model/Series Numbers: SS50US thru SS59US (with or w/o "BUS" suffix) SS60US thru SS69US.		Approved	\$200.00
		Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	1717 Broadway New York NY	Hold	\$0.00
Carry over from August 17, 2011 meeting. 1) Based on the documentation received concerning 250.122(F)(2), the submitter must provide documentation that the ground fault system is listed to protect undersized equipment grounding conductors. 2) Coordination study must be submitted. 3) Ground fault protection shall not be installed on the feeders for the life safety system. 4) Trip settings for the ground fault circuit breakers shall be tamper proof. 5) Provide letter from hotel owner stating who the qualified licensed electrician will be the maintain the ground fault feeder system. 6) Equipment grounding conductors in MC cables are undersized. 7) Show fire alarm switch on generator room floor plan.						

ADVISORY BOARD CALENDAR

December 14, 2011

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requesting permission to leave existing feeders fused at 4000 amps with existing 2/0 equipment grounding conductors installed in steel conduit to existing pull boxes where new feeders with 500 MCM equipment grounding conductors will be installed from existing pull boxes to new equipment	Credit Suisse 11 Madison Avenue New York NY	Approved	\$0.00
With the stipulation that the 2/0 and 500 MCM equipment grounding conductors are terminated to the enclosures of the pull boxes, not together. Code: 250.122.						
		Cartel Electrical Contracting Inc. 364 Decker Avenue Staten Island NY 10302	Requesting permission to leave service equipment as installed in the cellar area of a commercial building where the owner can provide 24 hour access to tenants as per 240.24(B)(1)	78 Douglas Street Brooklyn NY	Approved	\$350.00
Code: 240.24(B)(1).						
		Contact Electric Corp. 1775 43rd Street Brooklyn NY 11219	Requesting permission to omit receptacle outlets in spaces occupied by fixed glass panels in exterior walls in a multi-family building	111-117 Kent Avenue Brooklyn NY	Denied	\$350.00
Drawings must be submitted. Code 110.52(A)(2)(2).						
		Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to replace the code wiring of an existing 480/4160 volt defective transformer where the work will be performed by Olsun Electrical Company	Brooklyn College Chiller Plant Brooklyn NY	Denied	\$0.00
Drawings must be submitted. Code: 110.2(A).						
		Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Bronx Family/Criminal Court 215 East 161st Street Bronx NY	Hold	\$650.00
1) Main and supplemental grounds are not to be terminated on load side of neutral links. 2) GFI on generator 3000 amp switch. 3) Verify that elevator is not a life safety load or connect to gen. Switchgear. 4) Verify the switchgear is hinged doors. 5) ESSB-G generator MTD board verify work clearance, verify two means of egress.						

ADVISORY BOARD CALENDAR

December 14, 2011

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		Vilanova Electrical Co. LLC 605 West 47th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	314 West 40th Street New York NY	Approved	\$650.00
		Kleinberg Electric Inc. 437 West 16th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Skanska USA 46-65 55th Avenue Maspeth NY	Approved	\$650.00
		U.S. Electric Corp. 13-07 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	60 Madison Avenue New York NY	Approved	\$650.00
Install equipment closer wall. Job finalized 4/23/12.						
		Warren Ostroff Electric, Inc. 102-15 159th Road Howard Beach NY 11414	Requested approval for the electric service equipment proposed to be installed	2 East 70th Street New York NY	Approved	\$650.00
Verify size of service entrance conductors to existing 3000 amp service switch. Job finalized 4/23/12.						
		S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Riverside South 60 Riverside Blvd, Bldg., Bldg. J1 New York NY	Ok, but	\$650.00
1) Reduced neutral calculations not provided, 2 drawing. 2) Transformer secondary conductors undersized to 1200 and 800 amp switchboard drawing.						

ADVISORY BOARD CALENDAR

December 14, 2011

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51019		H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	197 East Broadway New York NY	Approved	\$650.00
1) Verify service entrance size to fire pump service switch. 2) Generator chassis ground connection. 8/28/14 Job finalized.						
		Martin Dorkin, Licensed Electrician 547 Coney Island Avenue Brooklyn NY 11218	Requesting permission to install underground concrete encased service lateral conductors in Schedule 40 non metallic conduit.	551 Smith Street Brooklyn NY	Approved	\$0.00
With the stipulation that the stub ups are rigid galvanized steel.						
		Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	365 Bridge Street Brooklyn NY	Approved	\$650.00
		Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Hearst Corporation 300 West 57th Street New York NY	Approved	\$650.00
		J & R Rey Electric Co. Inc. 3471 Steenwick Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	Vaughn College 86-01 23rd Avenue Flushing NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

December 14, 2011

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51025		GRX Euro Electric Corp. 18-02 26th Road Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	Wyckoff Hospital 374 Stockholm Street Brooklyn NY	Approved	\$650.00
swap dwg 1 & 2 Rev -2						
	11A0206CO	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Hamilton Marine Transfer Station 500 Hamilton Avenue Brooklyn NY	Denied	\$0.00
Carry over from May 25, 2011 meeting. 1) Verify that emergency feeders are not running through the service room. 2) Fire alarm system to have a main service switch. 3) Provide key interlock scheme for generator feeder to service switchboard. 4) Provide overcurrent protection for ATS' . 5) AIC of fire pump controller not shown, What is the AIC at the fire pump?. 6) Neutrals bonded on non separately derived system. 7) Bonding and grounding to be terminated on line side of neutral link. 8) Provide sequence of operation of PLC scheme for main tie main switchboard. 9) Describe load shed scheme. 10) Provide coordination study. 11) 1st fire alarm ATS to have normal and emergency feeds.						