

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0424CO	Requested approval for the electric service equipment proposed to be installed	Denied	\$0.00
<p>1) Item #6 and 9 from last revision are not addressed. 2) Verify the trip size of all OCPD in paralleling switchgear. 3) Provide ampacity of 300 KCML, 5KV cable and cutsheet for this size is not common for M.V. 4) Clarify the voltage rating install equipment 5KV or 15KV.</p>				
55819	18A0539	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide tap cond length. 2) Verify if the new sprinkle booster pump is feeding the standpipe or only the sprinkler system only. 3) Provide Asbestos Abatement compliance document with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/4/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
56005	18A0540	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) EGC of "ArcserSW", "DGP-SWs", "DGP-sws", "SPARE-sw" and FP cond are undersized with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.                      2) Correct note regards incoming service voltage. 3) Bus bars connected to transformer secondary switches of "TX-R-2", "TX--R-3" and "TX-R-1" are undersized. 4) Provide coordination between 1200A breaker and downstream fuses in "GDP" panel signed and sealed by P.E. 5) Provide F.P. controller AIC rating and available s.c. current. 6) EAB scope of work is not included within provided Asbestos Abatement compliance document. 7) Verify 100A-N-F switch. 8) Cond feeds transformer secondary switch of "TX-R-1" is undersized. 9) Verify size of existing busbar feeds 4000A switch (1600A fuse) in 'DS-1N'. 10) Verify ventilation to 3rd floor electric room. 7/8/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/8/2021 Amended dwgs# 1 &amp; 2 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/8/2021 Amended dwgs# 1 Rev 2. 4/23/2021 Amended dwg# 1 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55804	18A0606	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify if emergency generator is required for fire pump. 2/20/19 1) Confirm that the building is not greater than 125 feet high as per BC 403.4.8.2 2) Provide coordinatoin between 800A A4BQ &amp; upstream 1200A A4BQ. 3/26/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/7/19 - Fire pump conductor is undersized. 7/25/19 Swap Dwg # D-1808-30530-B Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
56006	18A0616	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Vertical bus in "DP-Garage" panel is undersized with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Tap cond. Feeds 600A disc sw is undersized-dwg 2 of 3. 3) Conductor from 300 KVA transformer OCPD "600A disc sw and feeds "DP-2-elev" is undersized-dwg 2 of 3. 4) Fire pump OCPD-Normal side-is undersized 5) Fire pump cond.emergency side and F,P. transformer secondary cond. (normal side) are undersized. 6) Buis bars connected to 1600A breaker are undersized-n 'ESS-3-1" Dwg#3 of 3. 7) Vertical buses in 'ESS-3-1" Section #3 are undersized-dwg #3 of 3. 8 Provide coordination and short circuit study signed and sealed by P.E. 9) Physical doesn't match one line in 'DS-2-1' and "DS-2-2". 10) Show F.A. 100A disc switch in emergency dist. room 5/10/19 1) Item #4 is not addressed - FIA of table 430.250 shall be used. 2) Provide vertical bus bar size in "ESS-3-1" section #3. 7/10/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/7/2021 Amended Dwgs# AB20- 01 Rev 3, AB20-02 Rev 2, AB20-03 Rev 3, FP01-01 Rev 2,F P90-01 Rev 2, SB60-01 Rev 4, SB60-02 Rev 6, SB61-01 Rev 8, MS60-01 Rev 3, PB90-01 Rev 5, PB90-02 Rev 5, PB90-08 Rev 6 and PB90-34 Rev 5. 4/27/2021 AB20- 01 Rev 4, AB20-02 Rev 3, AB20-03 no change, FP01-01 no change, F P90-01 no change, SB60-01 no change, SB60-02 no change, SB61-01 no change, SB61-02 no change, SB62-01 Rev 5, SB62-02 no change, MS60-01 no change, PB90-01 Rev 6, PB90-02 Rev 6, PB90-03 no change, PB90-04 Rev 5, PB90-07 no change, PB90-08 no change, PB90-09 no change and PB90-34 no change. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55862	18A0620	Requested approval for the electric service equipment proposed to be installed	Approved	\$65.00
<p>1) One line diagram not matching type and number of conductors in MSWB-C and MSWB-B and MSWB-A . 3/4/19 1) Provide location of property line box in regards to service room and verify that customer incoming service cables are concrete encased. 4/25/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55904	18A0625	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide selective coordination for OCPD. 2) Size of conductors for FP ss#3 are not matching in one line diagram and physical. 1/28/19 1) Incoming service conductors are undersized. 2) Sectional bus in Mains. Swbd section #4 and Dist. Board "RDB" section #2 are undersized. 3) Comply with 230.6. 4/25/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55603	18A0662	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/8/19 - Swap dwg A rev 1 7/8/2021 Amended Plans# A Rev 2. .Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/27/2021 Amended Plan# 1 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55604	18A0686	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/27/2021 Amended Plans# 1 of 1 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/15/2021 Amended plan# 1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0695	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>12/19/2018- 1) Provide bonding to FP \$ F.A S.SWs-normal side. 2) Verify if Gen SDS or not SDS- neutral is bonded &amp; grounded in SDS. 3)Verify Delta-Y configuration of 1500 kva xfmr. 4) Provide ventelation to room. 5)Fire pump OCPDs is undersized-695.4 (B)(1)&amp; (2)-normal &amp; emergency side. 6) Cond. Feed load bank from 400Asw is undersized and verify # of sets feeding 400A sw from generator. 7) Comply with 760.4 (A)- F.A tap to be ahead of N.D.L for F.-CML- sw " &amp; "FA-R2-sw-1" dwg # 2 of 5 (service B) . 8) Service busbar feeds ss# 1,2 &amp;3 is undersized. 9) Provide details of " BIDG.27- D.DT" switchboard- OCPDs values &amp; types. 10) Provide coordination &amp; short circuit study signed &amp; sealed ny P.E. 11) Fix typo in "FA-R2-sw-2"- SW amperage rating. 12)Show S.E.Bs in service elec. Room as per notes on EAB dwg. 13) Verify compliance with 760.41 (D)(4)- VERIFY 10' tap to F.A secondary transformer OCPD-( Emergency side). With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
55774	18A0698	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>F.P conductor undersized. 1/31/19 - 1. Fire pump GEC and EGC are undersized. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/8/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/12/19 Swap Dwg 1 rev 3.</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55745	18A0706	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/19/2018- 1) Provide 2 sets of documents for each attachment submitted. 2) Provide selective coordination. 3) Provide Electrician license number. 2/21/19 1) Confirm 5' clearance in front of solar service switch. 2) Confirm that primary OCPD to transformer in rush current and provide 1200A switchboard cut sheet.. 2/27/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/17/19 Swap Dwg #2 8/8/19 Swap Dwg #E-205.00 2 of 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
	18A0732	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>12/11/18- 1) Show bonding &amp; grounding to F.A S.SW #8 on the one line dwg. 2) Comply with 700.10 (E)(2) &amp; 760.41 (D)(4) for fire alarm emergency side. 3) Comply with 215.10 &amp; Provide GFP-10 2000A sw in "DT-T-B1". 4) Verify that "HDP-2-1" is 3rd level device &amp; provide OCPD valves feeds "EDP-2-2a" &amp; EDP-2-2B" normal side. 5) Verify AIC rating of "DS-T-B1". 6) Provide cover letter with license #. 7) Provide full size dwg to coordination one-line and provide summary &amp; recommended settings &amp; conclusions &amp; clearly indentify if equipment pass short circuit study or not within the cordination. 8) Verify that 1000kva Xfmr is NRTL listed. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
56192	18A0734	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination study signed &amp; sealed by P.E. 2) Sectional bus(Horizontal Partition) in "MSB" is section #1 is undersized. 3) Provide series rating document. 4) Provide how you access and support the copper detail trough. 5) Provide 5' clearance to MB in floor plan and verify labels with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/25/19 - 1. Item #2 is not addressed. 2. Item #2 is partially addressed. Coordination between SS#2 &amp; downstream br. And 800A CB of downstream OCPDS in EMDP-1. 8/7/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/27/2020 Amended dwg# A &amp; B Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	18A0735CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
<p>Carry over from October 23, 2018 meeting. 1) Item 1 is not addressed. 2) Comply with 110.34(A) for "SWGRL" rear access and verify which condition used provide room construction material or enclosure.</p>				
55918	18A0738	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify location of 30 KVA and 225KVA transformers (in electric service room). 2) Verify transformer 150 KVA located in electric service (room and where is it in one line diagram. 3) Remove ATS-0SB from service electric room-verify not for life safety. 4) Verify FP-SW-EMG is located in electric service room. 5) Provide selective coordination. 6) Fix number of set of 410 AWG to ATS-SB 2. 7) Fix number of set of 410 AWG to ATS-2hr 1. 8) Verify location of FA sw in electric service room. 2/28/19 1)FA &amp; FP transformers secondary neutrals to be bonded as SDS only in one location at the transformer or the secondary switch. 2) Fire alarm ATS shall be 4 pole with switched neutral &amp; also confirm that generator is SDS as the neutral is bonded &amp; grounded. 3) Comply with 450.3(B) 5/21/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/9/2020 Amended Plan # 1 of 3, 2 of 3 and 3 of 3 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/9/2021 Amended Plan # 1,2 &amp; 3 Rev-4.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
56200	18A0741	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide calculations short circuit a meterbanks MB-1,2,3 and 4. 2) Provide second door and move meterbank 4. 12/20/19 1) Item # 1 is not addressed - provide available s.c at MB-1, 2, 3 &amp; 4. 2) Verify that incoming service conductors are CON-ED cables or customer cables. 1/8/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/20/2021 Amended dwgs # 1, 2, &amp; 3 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 2/4/2021 Amended dwgs# 1, 2 &amp; 3 Rev 5 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55605	18A0744	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
	18A0757	Requesting a SP to replace keep newly service equipment as installed	Denied	\$0.00
<p>No hardship was provided on why the layout was changed from the approved EAB plans, and why a special permission was not requested before the installation was completed. Additionally, no safe alternative was proposed.</p>				
	18A0761	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>12/13/18- 1) Busbar connected to 4000A fuse in "ADS-6", "DS-B" &amp; "ADS-36" switch boards are undersized- sec 408.60 (E)(3). 2) Provide Ground fault protection and not ground fault indication or sensor to all OCPD above 1000A in 480V system. 3) Provide Cond. Size feed fire pump from fire pump controller to all F.P.s. 4) Coordination study needs to be updated per comment on page 15 on the coordination study (senario R). Update coordination study based on equipment selection for ex. "E-DS-D". 5) Show 'S ST-B' Transformer on one line dwg. 6) Comply with T110.26 (A) for rear access of DS-B &amp; SS-B. 7) Verify vestibule is leading into legal egress. 8) Verify Access to middle SEB. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55614	18a0772	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55695	18A0776	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide bonding and grounding to new 1200A service switch. 2) Provided TCCs to be signed and sealed by P.E. 3) Provide AIC rating of new 1200A switch verify 200KA rating. 2/4/2019 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/12/2020 Swap drawings # E-6.0AB Rev2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/7/2020 1) Provide the coordination between the 1200A SSW and downstream breakers sign and sealed by P.E. 2) Provide 5 feet clearance in front of 1200A SSW. 10/13/20 Amended plan # E- 1.0 AB Rev -2, # E- 6.1 AB Rev -4, and # E- 6.0 AB Rev -3.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 11/17/2020 Amended dwgs # E-6.0 AB Rev 4, E-1.0 AB Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/17/2020 Amended dwg# E-6.0AB Rev 5.				
55880	18A0784	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide 5' clearance to new F.A. service switch. 2) Provide available s.c. current at substation transformers. 3) Verify the F.A. switch voltage rating. 2/21/19 1) Item #1 from last revision is not addressed--comply with 230.64(B) provide 5' clearance to F.A. service switch, distance shall be measured from enclosure or opening if the live part parts are enclosed. 2) Provide AIC rating of all new equipment. 5/1/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0796	Requesting a SP to replace a substation in-kind that lacks required clearances.	Pending	\$0.00
Additional information is required to document the existing condition, clarify the hardship, and relocate the proposed substation's connection to a front accessible only.				
55657	18A0797	Equipment	Approved	\$200.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				



# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0799	Requesting a special permission to serve the fire pump from emergency feeders that ser the associated buildings.	Pending	\$0.00
The special permission to be resubmitted with additional details to clarify the number of fire pumps, transformers, and location in buildings.				
	18A0801	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
OR 1) New incoming service cond. were undersized.-provide max load demand				
55709	18A0803	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify that electrical room is included within the scope of work of the Asbestos Assessment report provided within the submission				
55684	18A0804	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify number of sets feeding 800A service switch #2. 2) Fire pump OCPD is overfused. 3) F.A. conductor is undersized. 4) Comply with 250.102(c )-bonding jumper size shall be 12.5% of the area of service entrance busbar. 5)Coordination study doesn't match EAB-one line.. 1/30/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/12/2021 Amended plans# 1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 9/9/2021 Amended plan# 1 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
	18A0805	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Provide documentation to show that new modification to existing ASCO switchboard will not void its listing. 2) Provide physical drawing.				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55779	18A0807	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement Compliance doc. 3/19/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0808	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) The drawings are not per Advisory Board format or size additionally drawings are faint. 2) Show bonding and grounding to 1200A service switch show grounding of Co.generation system. 3) Show fuses type in 'PDP-HP' panel. 4) Provide coordination and short circuit study signed sealed by P.E. 5) Provide Asbestos Abatement compliance documents.				
55821	18A0809	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Provide Asbestos Abatement compliance doc, 2) Provide coordination between new fuse and upstream fuse. 3) Provide tap cond length. 4) EGC to new 400A switch is undersized T250.122. 4/4/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55796	18A0810	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide existing F.A. cond size. 2) Verify that electric room is included within the provided Asbestos Abatement Compliance doc. 3/21/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0811	Requested approval for use in New York City of your DualLife FPLR-C1	Denied	\$200.00
Cable is not marked with prefix "FPLR-CF".				
55704	18A0812	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Provide bonding to SS#5. 2) Verify that service elec room is included within the scope of work of provided Asbestos Abatement compliance document. 2/7/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
56126	18A0814	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide master electrician license number. 2) Provide TCC with P.E Stamp and signature. 3/6/19 - 1. Bus bars feed distribution loads from ATC contractor and undersized. 2. Provide vertical bus size feed FDR-1 & FDR-2. 3. Show chain link fence grounding. 4. Doors to open outward with panic bars - 110.26(C)(3). 5. Comply with 408.46 for "LP-A" panel - provide main OCPD 11/22/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55864	18A0815	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement compliance required document. 4/25/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55613	18A0817	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55714	18A0820	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Distribution panelboard of 'DP-7' and 'DP-7-EM' doesn't match one line or coordination study verify # of 800A breakers. 2) Follow recommended settings and comments of coordination study- page 43 of 143 in coordination study. 3) Verify that EAB scope of work is included within the provided Asbestos Compliance document.. 2/13/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56201	18A0821	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide existing cond size feeds new 800A fuse. 2) Provide tap cond length. 3) Tap cond. Length. 3) Tap cond is undersized-the provisions of 240.4(B) shall not be permitted for tap cond.. 2/4/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/24/2021 Amended plan # AB01 1 of 2 Rev- 3, 2 of 2 Rev-0 and FP01 1 of 1 Rev- 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55895	18A0822	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) EGC of fire pump emergency side is undersized-T250.122 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>. 2) Provide cond size connected to 350 c.b and feed load bank and provide conds feed 350 and 400A breakers from generator. 3) GEC of ss#4 and 3 are undersized.-T250.66 and GEC of ss#3 on one line doesn't match the grounding detail. 4) Comply with 250.102(c)-main bonding jumper in 400A service switchboard is undersized. 5) Fix typo for front view of individual service switches. 6) Provide available s.c. current at point "A", "B" and "C" and at 'ERP-GEN'. 7) Provide Asbestos Abatement compliance document and cover letter with license number.. 3/6/19 1) Item #6 is partially addressed provide available s.c. current at points "A", "B" &amp; "C". 2) Provide coordination between 800A OCPD and downstream breakers in retail "A". 5/9/19 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/15/2020 Swap drawings # 1 &amp; 2 Rev2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55778	18A0823	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide transformer secondary cond. Length. 3/18/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/4/19 Swap Dwg P-3607-D-1 Rev 1 and P-3607-D-2 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55829	18A0825	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide available short circuit current at dist "DB-1". 2) Clarify which control number includes the service room within the scope of work for Asbestos Abatement compliance document. 3) Provide coordination between 2000A A4BQ and downstream 400A JXO6 breaker. 4/11/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/21/19 Swap Dwg #A &amp; B Rev-6. 9/10/19 Swap Dwg #D-1811-30929-A Rev 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55606	18A0828	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55607	18A0829	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55705	18A0832	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement compliance document. 2) Provide bonding and grounding to new 800A service switch. 3) Coordination study shows curves overlap between 800A fuse and 600A breaker, please clarify and fix recommended settings. 4) Provide "DPH-Tesla" cut sheet (inspector). 2/7/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55622	18A0833	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> <p>9/30/2020 Amended Plan# A.1 &amp; B.1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/28/2020 Amended Dwgs# A &amp; B Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 3/8/2021 Amended dwgs# A &amp; B Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55831	18A0834	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply with 760.41(A)(1)-F.A. tap to be ahead of N.D.L. 2) Provide the vertical busbar site feeds ss# 2, 3 and 5. 3) EGC to 100A disconnect switch is undersized. 4) Provided TCCs to be signed and sealed by P.E. 5) EGC to jockey pump is undersized-T250.122 6) Provide Jockey Pump tap cond. Length. 7) Provide AIC rating of MB1 and MB2. 4/19/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55750	18A0835	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show generators grounding method on one line DWG. 2) Show bonding and grounding to all existing service switches. 3) Verify of sets of ECG to existing "BDP-4" panel-DWG #E-6..3AB-Fix typo. 4) EGC of "BDP-1" and "BDP-s"-Normal side are undersized. 5) Verify that AIC rating of all AST are adequate to the available short circuit current with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/1/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55878	18A0838	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide 5' clearance in front of F.P. service switch. 2) Verify available calculated s.c current at F.P. controller. 5/1/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/24/2021 Amended dwgs# 1, 2 &amp; 3 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 4/21.2021 Amended dwgs# 1, 2 &amp; 3 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55703	18A0839	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify the address-the submission address is different than drawing and Asbestos document. 2) Provide tap cond length feeds existing "MDS" and comply with 240.21(B). 3) Provide coordination between 4000A A4BQ and downstream FRNR fuses. 2/7/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/18/19 Swap Dwg # 16361-1 Rev 1 and 16361-2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/6/2020 Swap drawings # 1 &amp; 2 Rev # 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/13/2020 Amended Dwg # 1 Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/25/2020 Amended Dwg # 1 &amp; 2 Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	18A0840	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Comply with 695.6(H)- ground fault protection of equipment shall not be permitted for fire pump with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Verify F.A. transformer size-transformer OCPDs are overfused. 3) Physical doesn't match one line-verify bus sizes in physical dwg. 4) Provide cover letter with license number.</p>				
55636	18A0841	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Coordination between 1600A c.b. and downstream 800A fuse not included within the coordination study with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/2/19 Job finalized.Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
56185	18A0842	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify room mechanically ventilated. 2) Verification of HDPR-2 electric service room? Show in room layout. 3) Provide selective coordination. 4) Provide grounding detail for service B. 5) 1600A switch drawn backwards. 6) Show manufacture for bus duct. 2/25/19 1) Copper busway from MSB #1 is undersized. 2) Provide available s.c. current at F.P. controller, "GDP" and "HDPR-2". 6/16/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 8/19/2020 Amended Dwgs # 1, 2 &amp; 3 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/28/2020 Amended Dwgs # 1, 2 &amp; 3 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 1/15/2021 Amended Dwg# 2 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 1/29/2021 Amended approved dwgs# 1, 2 &amp; 3 Rev 5 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	18A0843	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>Or 1) Provide Asbestos Compliance required documents. 2) Fix typo is number of 200A(5) or 3 with(2) 400A fuse switch</p>				
55642	18A0844	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide series rating doc. (manufacturer's cuts). 1/8/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/20/2020 Confirm the 12" separation between the FP and FA service switches in service room as per A695.(B)(3)(4). 5/20/2020 •Confirm the 12" separation between the FP and FA service switches in service room as per A695.(B)(3)(4). 10/6/2020 Amended dwg # 1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 12/10/2020 Amended dwg# A Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/23/2020 Amended Plan # A Rev- 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55616	18A0845	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				



# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55646	18A0846	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide selective coordination for OCPDS. 1/9/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/11/19 Swap Dwg rev 1 8/13/19 1) Provide signed and sealed coordination study to all fuses. 1/16/2020 1) Provide correction for undersized neutral conductor after both 1600 amp fuses (ss #2 and # 3) or signed and sealed calculation by a PE. 1/29/2020 Swap Dwg # A rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55641	18A0848	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply with 250.102(C)-main bonding jumper in 4000A switchboard is undersized. 2) Clarify reason for submitting FP controller and generator cutsheets-not included in the one line. 1/8/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55746	18A0852	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>1) Provide Jockey Pump tap cond length with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Show bonding t SS#2. 3) Clarify if generator neutral is bonded and grounded as separately driven system or not and show on the one line drawing. 4) Show AIC rating verses available s.c. current to equipment-800A MB, SS# 3,4,5 and 6. 2/27/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/20/2021 Amended Plan# Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55967	18A0853	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Verify that area of work is included within provided Asbestos Abatement document. 6/5/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/8/2019 Swap Dwg N18-09/24/18 Rev-1. 7/10/2019 Swap dwg N18-09/24/18 Rev-1. 11/21/19 Swap Dwg 1 rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

# ADVISORY BOARD CALENDAR

December 19, 2018

Approval #	Submission #	Type of Request	Status	Fee
55734	18A0854	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide cover letter with license # included. 2) Provide Asbestos Abatement compliance documents. 3) Provide series rating document. 4) GEC to SS#2 is undersized. 2/21/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55623	18A0856	Material Approval for 1000v PV equipment	Approved	\$350.00
With stipulation that the installation and inspection shall be in accordance with 2014 NEC. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55624	18A0857	Material Approval for 1000v PV equipment.	Approved	\$350.00
With stipulation that the installation and inspection shall be in accordance with 2014 NEC. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55617	18A0858	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/15/18 Swap Dwg # SNY0953629-S1-0L 1/3/-Revision 1 and 2/3 -Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
	18A0859	Requesting SP to keep the Service Eq. elevator as installed	Denied	\$0.00
Feeders shall have ampacity of 4000 amp. Fire Pump circuit wiring shall be protected. Open wiring is not acceptable. APPROVED Due to the temporary nature of the installation, the Department will accept the Ferraz letter for coordination. Due to the temporary nature of the installation, the Department will permit the Fire Pump to be located in the temp service switch.				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
56038	18A0860	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide cond size feeds 'CHDB', loadbank with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Comply with 230.71-number of service disconnecting means shall be not more than 6 switches. 3) The max # of 6 service switches shall be grouped in one service room. 4) Horizontal buses feeds ss#4,5, and 6 in 4000A main service switchboard and "in EMDP". Panel are undersized. 5) Provide coordination between 1200A KRPC and downstream fuses in 'CHDB' and between ss#4 (in 4000A main service switch bound) and downstream 600A FRN fuse signed and sealed by P.E. 6/5/19 1) All service switches shall be grouped in one location. 2) Incoming service cables feeds 4000A main service switchboard is undersized and doesn't match data on floor plan. 3) Horizontal bus bar in "EMDP" still undersized. 7/26/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55775	18A0861	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Conds feed chiller A &amp; B from double throw Bolt Switch are undersized. 2) Provide cutsheets showing listing of equipment. 3) Provide Asbestos Abatement compliance document. 2/7/19 1) Item #1 is not addressed. 3/18/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55812	18A0862	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) 800A A4BQ doesn't coordinate with upstream breaker and also provide coordination between 400A TR and upstream breaker. 2) Verify that service electric rooms are included within the scope of work of provided Asbestos Abatement document. 2/7/19 1) Item #1 is partially addressed - provide coordination between 400A TR &amp; upstream Br. 2) Item #2 not addressed 3) Service cond. Fuels new 1200A S. Sw#5 is undersized - Dwg#C 4/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/5/2021 Amended Dwg# A Rev. 1 and B&amp;C Rev.2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/25/2021 Amended Dwg# A Rev. 1, B, Rev. 3 and C Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55896	18A0863	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify 2 hr fire rated conductor-emergency side-for 50HP fire pump with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>2) EGCs feed 200A switches tapped from 1200A MC. C.B are undersized-T250.122. 3) Provide coordination between 1200A CB and downstream fuses in "DPR" panelboard and provide short circuit study to all equipment. 4) Correct project address on fire pump and ATs cuts 5/9/19 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/9/2021 Amended Plans# 1 of 2 Rev 2 and 2 of 2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55747	18A0864	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 1) Provide Asbestos Abatement compliance document. 2/27/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/2/19 - Swap dwg rev-2.</p>				
55608	18A0865	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55618	18A0866	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/17/2020 Swap dwgs 1, 2 & 3-Revision 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/17/2020 Amended Plan # 1,2 & 3 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 10/15/2020 Amended Dwgs# 1,2,& 3 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55898	18A0867	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide series rating and for calculations for meterbank and garage panel 2/27/19 1) Confirm 2 HR fire rated fire pump conductor out of the service room. 2) Confirm 2 HR fire rated service room. 5/9/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/2/2020 Amended Plan#1 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/28/2020 Amended Dwg # 1 Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55609	18A0868	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/15/2021 Amended dwgs# 1 & 2 Rev 1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55619	18A0869	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55620	18A0870	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> <li>1. A P.E. or R.A. must file a PWI as an AIT 3.</li> <li>2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.</li> <li>3. The fire proofing must be performed by a certified fire proofing installer.</li> </ol> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55610	18A0871	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55612	18A0872	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/23/19 Swap dwg #ACS-D-13433-1-Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

# ADVISORY BOARD CALENDAR

**December 19, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55621	18A0873	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/6/19 Swap Dwg # 1 rev.1 and # 2 rev.1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.. 5/20/2021 Amended Plan# 1 &amp; 2 Rev-2.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 7/22/2021 Amended plans# 1 &amp; 2 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55625	18A0874	Requesting SP to keep the installed MC cable in exam rooms.	Approved	\$0.00
<p>With stipulation that the MC cable shall be bonded to all device boxes and receptacles outlets</p>				