

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49957CO2	10A0058CO2	Global Electrical Contg of Wechester, Inc. 400 Boston Post Road Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	Harlem Hospital 506 Lenox Avenue New York NY	Hold	\$0.00
Carry over from June 16, 2010 meeting. 1000 KVA secondary breaker 1200 amp to 3000 amp breaker emergency side.						
50207CO2	10A0249CO2	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Lowes of Staten Island 661 Veterans Road Staten Island NY	Approved	\$0.00
Carry over from September 15, 2010 meeting						
50222CO2	10A0264CO2	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	River Place II 600 West 42nd Street New York NY	Approved	\$0.00
Carry over from October 13, 2010 meeting						
50360CO	10A0381CO	Star Delta Electric, LLC 17 Battery Place, Suite 203 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	40 Wall Street New York NY	Hold	\$0.00
1) Elevator draing required for serice entrance conductor routing. 2) Service entrance conductors to be ran in metallic conduits on troughs and provide detailed drawing of same. 3) Provide detailed drawing o						
50370	10A0388	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	160 Broadway New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50371	10A0389	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 276M 55 Battery Place New York NY	Approved	\$650.00
1) Service room doors to open outward. 2) Verify fire pump branch circuit feeder and EGC sizes. Need gnd electrode cond. 3) Bus sizes not shown for service switch #3. 4) Feeders to panel "EDBR" overfused. Job finalized 3/29/11.						
50372	10A0390	erified Electrical & Technical Services, In 27 William Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	1855 Broadway New York NY	Ok, but	\$650.00
Relocate new equipment or add second door.						
50373	10A0391	Apollo Electric, Inc. 390 Manhattan Avenue New York NY 10026	Requested approval for the electric service equipment proposed to be installed	Veselka Bowery 9 East 1st Street New York NY	Hold	\$650.00
Drawings not submitted in Advisory Board format.						
50374	10A0392	Campbell and Dawes Ltd. Electl Contrs. 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	St. Francis College 180 Remsen Street Brooklyn Heights NY	Approved	\$650.00
50375	10A0393	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	PS 59 and HS of Art & Design 250 East 57th Street New York NY	Approved	\$650.00
1) Fire pump branch circuit conductors undersized. 2) Generator neutral not to be bonded to building steel.. 3) FA service switch to be bonded and grounded. 4) Secondary of FA transformer to be bonded and grounded. 5) FA need means of disconnect on emergency side. 6) Provide coordination curves for 'EDP11' circuit. Job finalized 3/28/11.						

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50376	10A0394	A.T.J. Electrical Inc. 122-13 15th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	NYC City Hall 1 City Hall Park New York NY	Hold	\$650.00
1) EGC reversed on FA emergency switch feeders. 2) Life safety ATS switches to be relocated out of the emergency distribution room. 3) FA disconnect switch to City Hall building to be removed. 4) Life safety loads to be independently ran cannot share the same enclosure. 5) Coordinate emergency system.						
50377	10A0395	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JPMorgan Chase 270 Park Avenue New York NY	Hold	\$650.00
Show MI transition in emergency board.						
50378	10A0396	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon 240 East 38th Street New York NY	Approved	\$650.00
50379	10A0397	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Pret A. Manger Service 425 Lexington Avenue New York NY	Approved	\$650.00
50380	10A0398	Lilker Associates Consulting Engs, PC 1001 Avenue of the Americas New York NY 10018	Requested approval for the electric service equipment proposed to be installed	MPC Television, 8th & 9th Fls 434 Broadway New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50381	10A0399	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Lexington House Hotel 517 Lexington Avenue New York NY	Approved	\$650.00
50382	10A0400	Jordan Daniels Electrical Contractors, Inc. 151 West 25th Street, 7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sprint 60 Hudson Street New York NY	Hold	\$650.00
1) Show correct gen sizes. 2) Show interlocking. 3) Provide sequence of operation for mobile gen use. 4) Show neutral bonding if 4W system. 5) Show available s.c. current for all services. 6) Show remote overcurrent prot./disconn for mobile gen.(no fuse fused disonnect switch, just connectin box).						
50383	10A0401	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Signature Theatre 442 West 42nd Street New York NY	Approved	\$650.00
3/25/14 Swapped A-5 and B-4. 7/15/14 Swapped A-Rev 6 and B-Rev 5. 1/30/15 Swapped A-Revision 7 and B-Revision 6. Job address changed. Letter was submitted.						
50384	10A0402	Anthony G. Ferry, Inc. 217A Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	Elliot Chelsea 401 West 25th Street New York NY	Approved	\$650.00
Reconfigure room layout move switchboard and door. Job finalized 2/4/11.						
50385	10A0403	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Madison Square Garden 4 Penn Plaza New York	Hold	\$650.00
1) Feeder sizes to FA panel not shown. 2) Correct coordination problems above 0.1 sec. This occurs with 1000A fuse and 4000A CB in series. 3) Provide coord curves for gen distr. 4) Provide GF IND on gen main cb.						

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50386	10A0404	Denmar Electric Corp. 47-40 48th Street, Suite #7 Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Bronx Lebanon Hospital 199 Mount Eden Parkway Bronx NY	Denied	\$650.00
1) Fire pump circuit conductors not shown. 2) FA cutouts to be fused swatches. 3) Show bonding and grounding of FA service switch. 4) Are ATS' 3 or 4 pole types? 5) Generator frame to be grounded. 6) Do ATS' feed life safety equipment?7/28/16 Denied 1. EGC on load side of 1600 & 3000 amps fuses undersized. Void as new submission under 15A0777 which is pending						
50387	10A0405	RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hampton Inn at JFK Airport 144-10 135th Street Jamaica NY	Approved	\$650.00
50388	10A0406	Appo Electric 34-18 Northern Blvd., 4th Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	142 West 36th Street New York NY	Approved	\$650.00
50389	10A0407	CRM Electric Corporation 461 West 261st Street Bronx NY 10471	Requested approval for the electric service equipment proposed to be installed	800 St. Anns Avenue, Bldg. D Bronx NY	Approved	\$650.00
50390	10A0408	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	J.H.S. 271 1137 Herkimer Street Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50391	10A0409	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	485 Madison Avenue New York NY	Approved	\$650.00
50392	10A0410	L.E.A. Electric Corp. 1001 Sixth Avenue, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	16 East 40th Street New York NY	Approved	\$650.00
50393	10A0411	Rigid Electric Inc. 336 37th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Hospital for Special Surgery 475 East 72nd Street New York NY	Approved	\$650.00
50394	10A0412	Lower Manhattan Electric Inc. 56 Lispenard Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	219 West 81st Street New York NY	Approved	\$650.00
50395	10A0413	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	530 Fifth Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50396	10A0414	Positive Electrical Associates Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	J.F. Kennedy H.S. Campus 65-105 Terrace View Avenue Bronx NY	Approved	\$650.00
50397	10A0415	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	The Bradford Apartments 1560 Fulton Street Brooklyn NY	Approved	\$650.00
50398	10A0416	P.L. Electrical Contracting Corp. 41 Monroe Street New York NY 10022	Requested approval for the electric service equipment proposed to be installed	Main Street aka 136-20 Roosevelt A Flushing NY	Approved	\$650.00
50399	10A0417	ID Electric Corp. 36-17 Bud Pl Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	30 3rd Avenue Brooklyn NY	Approved	\$650.00
50400	10A0418	Matros Automated Electl Constn Corp. 5-33 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	344 Third Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50401	10A0419	Accurate Electric 4319 18th Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	28 Debevoise Street Brooklyn NY	Approved	\$650.00
50402	10A0420	Scott Electrical Service, LLC 40 Macon Street Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	25 Washington Street Brooklyn NY	Approved	\$650.00
FP #6 equipment grounding conductor undersized. Job finalized 2/2/11.						
50403	10A0421	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Knickerbocker Village 40 Monroe Street, Bldg. F New York NY	Approved	\$650.00
Submit manufacturer's drawings Job finalized 2/2/11.						
50404	10A0422	Uptown Electric, Inc. 128-20 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Brooklyn Academy of Music 321 Ashland Place Brooklyn NY	Approved	\$650.00
1) Verify that Con ED is bringing service lateral conductors. 2) Show bus size feeding 1600 & 3000 amp service switches. 3) FP branch circuit to be fire rated. 4) Provide coordination curves for dist 'B' and TLD-1. Job finalized 8/30/12.						
50405	10A0423	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	20 Henry Street Brooklyn NY	Approved	\$650.00
1) Set of drawings submitted not 2 sets. 2) Service entrance bus undersized. 3) Show feeder sizes off of 400 amp service switches. 4) Show fuse size in FA service switch. 5) FP branch circuit conductor undersized. 6) Beam located in front of service equipment. 7) Submit cuts on meter banks indicate short circuit rating and available s.c. curret. 8) Provide gnd elec. conductor for FA sw. Job finalized 2/7/11.						

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50406	10A0424	KNC Electric Inc. 187-27 Linden Blvd. St. Albans NY 11412	Requested approval for the electric service equipment proposed to be installed	Metroplex on the Atlantic 120 Beach 26th Street Far Rockaway NY	Approved	\$650.00
50407	10A0425	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	18 Richmond Terrace Staten Island NY	Hold	\$650.00
1) Service entrance conductors undersized. 2) Clarify size of bus in " MDB-SC". 3) Verify that no emergency feeder are run through the service room. 4) Verify if 3 or 4 pole ATS' are being installed. 5) Cut sheet of generator distribution not submitted. 6) FA to be fed from switches. 7) FA cutout not to be used as service switch. 8) FA on emergency side to be a switch fed ahead of generator main. 9) No coordination between 3000A and 1200A cb's curve plotted wrong for 3000A CB. 10) Gen coord curves plotted wrong 1000A CB.						
50408	10A0426	R3 Electrical Inc. 541 Port Richmond Avenue Staten Island NY 10302	Requested approval for the electric service equipment proposed to be installed	Queens County Court House 88-11 Sutphin Blvd. Jamaica NY	Approved	\$650.00
50409	10A0427	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	PS13 Clement C Moore School 55-01 94th Street Elmhurst NY	Approved	\$650.00
50410	10A0428	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Newtown Creek WPCP 359 Greenpoint Avenue Brooklyn NY	Approved	\$650.00
1) Verify that rear accessible switchgear doors are hinged. 2) Switchgear room doors to swing out. Job finalized 2/3/11.						

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50411	10A0429	Ace Electrical Construction Expert Corp. 40-04 73rd Street, FL2 Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	30-50 21st Street Astoria NY	Approved	\$650.00
50412	10A0430	New Phase Electrical Contractors, Inc. 725 East 136th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	101Central Park West New York NY	Approved	\$650.00
50413	10A0431	AKF 330 West 42nd Street, 14th Floor New York NY 10036	Requested Concept Approval:	St. Johns University 8000 Utopia Blvd. Queens NY	Approved	\$0.00
50414	10A0432	Department of Environmental Protection 96-05 Horace Harding Expressway Corona NY 11368	Requested Concept Approval:	Oakwood Beach WPCP 751Mill Road Staten Island NY	Approved	\$0.00
With the stipulation						
50415	10A0433	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mt Sinai Ctr for Science and Med 1470 Madison Avenue New York NY	Hold	\$650.00
1) Bus undersized in MS-4. 2) Verify that emergency feeders are not running through the service room and if they are, they must be fire rated. 3) Show grounded and bonding in network switchgear. 4) Provide justification for 5000A bus in network switchgear. 5) Submit special permission letter for UL heat rise testing on network switchgear.						

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50416	10A0434	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	London Terrace 410 West 24th Street New York NY	Approved	\$650.00
New Feeders undersized. Job finalized 3/1/11.						
50417	10A0435	Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1060 Fifth Avenue New York NY	Approved	\$650.00
50418	10A0436	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Community Health Academy est 158th Street & Amsterdam Avenue New York NY	Approved	\$650.00
1) Generator neutral to be bonded and grounded. 2) FA FCO to be deleted after the ATS, 3) Neutral "links" to be provided in service switches. 3/19/13-Item #2 not addressed. Job finalized 5/13/13.						
50419	10A0437	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Madison Square Garden 4 Penn Plaza New York NY	Approved	\$650.00
MS2-T-SEC panel does not comply with 25' tap rule. Job finalized 2/4/11.						
50420	10A0438	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Goldman Sachs 77 Water Street New York NY	Approved	\$650.00
1) Existing 60 amp FCO to be removed. 2) Existing fire alarm service switch to be bonded and grounded. Job finalized 9/19/11.						

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50421	10A0439	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Credit Suisse 1 Madsion Avenue New York NY	Ok, but	\$650.00
Blades of 2000 & 4000 amp switches reversed						
50422	10A0440	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Jones Lang LaSalle 1285 6th Avenue New York NY	Approved	\$650.00
50423	10A0441	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 215 West 17th Street New York NY	Approved	\$650.00
50424	10A0442	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Genesis Neighborhood 350 Snediker Avenue Brooklyn NY	Approved	\$650.00
50425	10A0443	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Chartis 180 Maiden Lane, Floors 25 & 27 New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50426	10A0444	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Long Island Jewish Hospital 270-27 76th Avenue Queens NY	Approved	\$650.00
50427	10A0445	Demand Electric, Inc. 48-02 25th Avenue, Suite 305 Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	Navy Green-Pacc Sh. Bldg. 40 Vanderbilt Avenue Brooklyn NY	Approved	\$650.00
50428	10A0446	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	U.P.S. Manhattan South 325 Spring Street New York NY	Approved	\$650.00
50429	10A0447	Circle D Electrical Contracting Inc. 3916 Dyre Avenue Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	410 Park Avenue New York NY	Approved	\$650.00
Can service room door open outwards? Job finalized 2/23/11						
50431	10A0449	RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	110-60 Dunkirk Street St. Albans NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50432	10A0450	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	1090 Amsterdam Avenue New York NY	Approved	\$650.00
50433	10A0451	E.D. Electrical Inc. 5402 7th Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	7 Main St. aka 136-20 Roosevelt Av Flushing NY	Approved	\$650.00
50434	10A0452	CRM Electric Corporation 461 West 261st Street Bronx NY 10471	Requested approval for the electric service equipment proposed to be installed	4469 Broadway New York NY	Approved	\$650.00
50435	10A0453	OM Electric Inc. 262 West 38th Street, Suite #603 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	21 9th Avenue New York NY	Approved	\$650.00
50436	10A0454	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Trinity Real Estate 435 Hudson Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50437	10A0455	Denmar Electric Corp. 47-40 48th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	33 West End Avenue New York NY	Denied	\$650.00
1) Title block information incorrect. 2) 2 sets of drawing are required. 3) All new work to be identified by bubbling it. 4)The lengths of the tapped conductors are not shown. 5) Tap detail not shown. 6) Where is new work located?						
50438	10A0456	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Octagon 888 Main Street Roosevelt Island NY	Hold	\$650.00
1) Verify that Beck equipment is listed. 2) Provide sequence of fuel cell operation. 3) Provide Con Ed's approval letter.						
50439	10A0457	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1610 Sedgewick Avenue Bronx NY	Approved	\$650.00
50440	10A0458	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	311 West 39th Street New York NY	Approved	\$650.00
50441	10A0459	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	220 Water Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50442	10A0460	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	Windsor Court 151 East 31st Street New York NY	Approved	\$650.00
50443	10A0461	Frank Pugliese Electrical 141-18 Holly Avenue Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	115 Central Park West New York NY	Approved	\$650.00
50444	10A0462	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	79 Madison Avenue New York NY	Approved	\$650.00
50445	10A0463	Accurate Electric 4319 18th Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	88 Leonard Street New York NY	Approved	\$650.00
50446	10A0464	Detore Electrical Construction Co., Inc. P.O. Box 645 New York NY 10150	Requested approval for the electric service equipment proposed to be installed	333 East 23rd Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50447	10A0465	Alef Electric Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	260 West 39th Street New York NY	Approved	\$650.00
50448	10A0466	Alef Electric Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	15 Little West 12th Street New York NY	Approved	\$650.00
50449	10A0467	Quest Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	205 Water Street Brooklyn NY	Approved	\$650.00
Provide Lengths of taps to 800 amp switches. Job finalized 10/22/12.						
50450	10A0468	APS Electric Inc. 83-32 Parsons Blvd. Jamaica NY 11432	Requested approval for the electric service equipment proposed to be installed	1384 Broadway New York NY	Approved	\$650.00
50451	10A0469	Quest Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	1468 Hoe Avenue Bronx NY	Approved	\$650.00
Job finalized 9/21/11.						

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50452	10A0470	Market Electric Inc. 2526 50th Street, Suite 201A Woodside NY 1177	Requested approval for the electric service equipment proposed to be installed	Hampshire Building 2329 Nostrand Avenue Brooklyn NY	Hold	\$650.00
1) FP branch circuit to be fire rated. 2) 3-sets of 500 MCM fused at 1200 amps. 3) Coordinate 1200 amp fuses cannot be selective above 600 amps.						
50453	10A0471	Accurate Electrical Contractors Corp. 88 New Dorp Plaza, Suite 300 Staten Island NY 10305	Requested approval for the electric service equipment proposed to be installed	210 East 86th Street New York NY	Approved	\$650.00
Is new panel 150 or 100 amps? Job finalized 2/3/11.						
50454	10A0472	Gallant Electrical Construction, Inc. 260 Beach 116th Street, Suite 1 Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	976 Third Avenue Brooklyn NY	Approved	\$650.00
50455	10A0473	D & D Electric Contracting Corp. 13 East 37th Street, Suite #701 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	51 Audubon Avenue New York NY	Approved	\$650.00
1) FP service switch undersized. 2) FP emergency side fusing to be min 150%. 3) What type material will be used to encase service entrance conductors? Job finalized 3/29/11.						
50456	10A0474	T & T Electrical Corp. 24-30 47th Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	920 Westchester Avenue Bronx NY	Approved	\$650.00
1) Service entrance conductors feeding 2000 amp service switch undersized. 2) Verify 2- 1/4" x 16" service bus. 3) FP conductors undersized. 4) SS#2 and panel PPA not selectivity. Job finalized 2/3/11.						

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50457	10A0475	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	New York NY	Approved	\$650.00
50458	10A0476	Polo Electric Corp. 497 Canal Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	555 West 57th Street New York NY	Approved	\$650.00
50459		Safeway Construction Inc. 25 Crescent Street Brooklyn NY 11208	Requesting permission to install overhead service entrance conductors in nonmetallic rigid conduit in a corrosive area, Far Rockaway, Queens	575 Cedar Hill Road Far Rockaway NY	Approved	\$0.00
50460		Nicoletta Electrical Contracting Inc. 10 Seeley Lane Staten Island NY 10308	Requesting permission to install an additional separate service on an existing 2 family building that will provide power for site lighting.	47 Imperial Court Staten Island NY	Approved	\$0.00
With the stipulation						
50461		B & R Electrical Contracting Inc. 35 Maiden Loop, Suite D Staten Island NY 10309	Requesting permission to install service equipment outdoors that will provide power to outdoor site lighting and sewer ejector pumps.	102 Turner Street Staten Island NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50462		Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requesting permission due to lack of space inside of the existing service room to install new service equipment in the adjacent room.	771 West End Avenue New York NY	Approved	\$0.00
With the stipulation that signage is provided at each service indicating where the other service is located.						
50463		Rigid Electric Inc. 336 37th Street Brooklyn NY 11232	Requesting permission to install a seventh service switch where one of the existing service switches powers a fire pump.	475 East 72nd Street New York NY	Approved	\$0.00
50464		Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requesting permission to omit the laundry area receptacle outlet due to the stackable washer/dryer occupying the 36"x36" laundry area	46-15 Center Boulevard Queens NY	Denied	\$0.00
50465		Tarasis Electric Corp. 45-48 51st Street Woodside NY 11377	Requesting permission to install a new circuit breaker interior in an existing back box that will contain more than 42 circuits.	Lehman High School 3000 East Tremont Avenue Bronx NY	Denied	\$0.00
50466		New York City Housing Authority 90 Church Street New York NY 10007	Requesting permission to install replacement elevator feeder conductors inside of the elevator shaftway where the feeder will not contain any splices.	Astoria Houses 3-02 Astoria Boulevard Queens NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50467		Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requesting permission to leave as installed one door to a 1000 KVA service room	PS29Q 125-10 23rd Avenue College Point NY	Denied	\$0.00
50468		ME Engineers 417 Fifth Avenue, Suite 501 New York NY 10016	Requesting permission for the coordination between the 4000A service fuses and the downstream 3000A circuit breakers to selectively coordinate in the time of .1 seconds and longer, as per the proposed amendment to the 2008 NEC	Madison Square Garden 4 Penn Plaza New York NY	Denied	\$0.00
50469		Cross Hudson Electrical Inc. 240-21 Braddock Avenue Bellerose NY 11426	Requesting permission due to lack of space inside of the building to leave as installed outdoor service equipment for a cell site that will not be grouped together with existing service equipment	T-Mobile 288 Sand Lane Staten Island NY	Approved	\$350.00
50470		Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requesting permission to install one double door instead of 2 separate doors for an electrical service room.	75 Clinton Street Brooklyn NY	Approved	\$0.00
With the stipulation that an opening on the middle wall is installed to allow for egress.						
50471		Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Request special permission to modify an existing 4160V metal clad switchgear to accept connection of anew rental generator.		Denied	\$0.00

# ADVISORY BOARD CALENDAR

**December 22, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50472	10A0477	Light Corporation 14800 172nd Avenue Grand Haven MI 49417	Requesting approval for use in New York City of you Portable Under Cabinet Lamp. Model/Series Numbers: Reed LED, SRD-6, SRD-19, SRD-37.		Approved	\$200.00
50473	10A0478	Universal Electric Corporation 168 Georgetown Road Canonsburg PA 15317	Requesting approval for use in New York City of you Starline Track Busway and Starline Plug-in Raceway Model/Series Numbers: B400, B400N, B400G, B400NG and Accessories & SB20, SB20G, SB40, SB40G, SB60, SB60G and Accessories.		Hold	\$200.00
Specify what accessories are being submitted.						
54030	10A0448	Shorr Electrical Contracting, Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Macy's Herald Square 151 West 34th Street New York NY	Approved	\$650.00
1) Service C2 bus feeding 2500 amp disconnect switch undersized. 2) Verify that free standing switchgear has hinged rear doors-or tamper resistant bolts. 8/1/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						