



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 123-06-E

Manufacturer: Mitsubishi Electric, HVAC, 3400 Lawrenceville-Suwanee Road, Suwanee, Georgia 30024

Trade Name(s): Mitsubishi Electric

Product: Split-system air conditioner units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995)

Laboratory: Intertek Testing Services

Test Report(s): Report No#: JP050097 dated December 22, 2005
 Report No#: JN050098 dated December 26, 2005
 Report No#: JN050099 dated December 22, 2005
 Report No#: JN050100 dated December 22, 2005

Description: Split-type air conditioning system. Units consist of an indoor unit and a matching outdoor unit which are connected electrically and by refrigerant lines when installed. This product is intended to be permanently connected to the power source

Model Number for OUTDOOR Unit	Model Number for INDOOR Unit	Manufacturer's Specified Nominal Cooling Capacity (Tons)
MU-A09WA	MS-A09WA	0.75
MU-A12WA	MS-A12WA	1.0
MUY-A15NA	MSY-A15NA	1.25
MUY-A17NA	MSY-A17NA	1.4
MUY-A24NA	MSY-A24NA	2.0
PUY-A12NHA (-BS)	PLA-A12AA	1.0
PUY-A18NHA (-BS)	PLA-A18AA	1.5
PUY-A24NHA (-BS)	PLA-A24AA	2.0
PUY-A30NHA (-BS)	PLA-A30AA	2.5

Model Number for OUTDOOR Unit	Model Number for INDOOR Unit	Manufacturer's Specified Nominal Cooling Capacity (Tons)
PUY-A36NHA (-BS)	PLA-A36AA	3.0
PUY-A42NHA (-BS)	PLA-A42AA	3.5
PUY-A12NHA (-BS)	PKA-A12GA (L)	1.0
PUY-A18NHA (-BS)	PKA-A18GA (L)	1.5
PUY-A24NHA (-BS)	PKA-A24FA (L)	2.0
PUY-A30NHA (-BS)	PKA-A30FA (L)	2.5
PUY-A36NHA (-BS)	PKA-A36FA (L)	3.0
PUY-A24NHA (-BS)	PCA-A24GA	2.0
PUY-A30NHA (-BS)	PCA-A30GA	2.5
PUY-A36NHA (-BS)	PCA-A36GA	3.0
PUY-A42NHA (-BS)	PCA-A42GA	3.5

Terms and Conditions: The above-described split-system air conditioning units are accepted under the following conditions:

1. Units shall use only Refrigerant R-410A.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the New York City Building Code.
3. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 3/30/07

Examined By Shya m. [Signature]