



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 129-96-M Vol. 2

Manufacturer: Specified Technologies Inc., 200 Evans Way, Somerville, N.J. 08876

Trade Name(s): Specseal Series LC Sealant

Product: Fill, void or cavity material for fire protection

Pertinent Code Section(s): 27-345

Prescribed Test(s): RS 5-19 (ASTM E814)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File 14288, dated July 8, 1994 through August, 2007, and UL Design numbers

Description: Fill void or cavity material for through penetrations and joints in fire-rated assemblies, as indicated below. The sealant is a water-based high-solids fire-stopping compound installed within the opening or gap and shall be applied in accordance with Underwriters Laboratories, Inc. system numbers, listed below, in achieving the required fire-resistance ratings.

Laboratory	System No.	F Rating	UL Report
UL	C-AJ-0047	2	07NK10760
UL	C-AJ-1208	3	07NK10760
UL	C-AJ-1209	3	07NK10760
UL	C-AJ-1210	2	07NK10760
UL	C-AJ-1213	3, 4	94NK11697
UL	C-AJ-1214	2, 3	96NK14224
UL	C-AJ-1215	3, 4	94NK11697
UL	C-AJ-1232	2	96NK3961
UL	C-AJ-1240	2	96NK36561

Laboratory	System No.	F Rating	UL Report
UL	C-AJ-1315	3	98NK38316
UL	C-AJ-1316	3	98NK38316
UL	C-AJ-3085	3	94NK11697
UL	C-AJ-5313	2	07NK20818
UL	C-AJ-7026	2	07NK10760
UL	HW-D-0482	2	07NK12864
UL	HW-D-0483	1, 2	07NK12864
UL	HW-D-0484	1, 2	07NK12864
UL	HW-D-0485	1, 2	07NK12864
UL	HW-D-0486	1, 2	07NK12864
UL	HW-D-0487	2	07NK12864
UL	W-J-1030	2	96NK14787
UL	W-J-1033	2	95NK34623
UL	W-J-1054	2	96NK14787
UL	W-J-1100	2	07NK10760
UL	W-J-1121	3	01NK4941/07NK10760
UL	W-J-3035	2	96NK14787
UL	W-J-3043	2	98NK38316/07NK10760
UL	W-J-3099	2	02NK6583/07NK10760
UL	W-J-3131	2	04NK3824/07NK10760
UL	W-J-5139	2	07NK12904
UL	W-J-7020	2	07NK10760
UL	W-J-7077	2	05NK11155/07NK12906
UL	W-J-7086	2	06NK03826
UL	W-L-1078	1, 2	94NK17325
UL	W-L-1088	1, 2	95NK16408
UL	W-L-1090	1, 2	96NK14787
UL	W-L-1093	1, 2	95NK34623
UL	W-L-1127	1, 2	96NK14787
UL	W-L-1168	1, 2	98NK38316
UL	W-L-1283	1, 2, 3	98NK38316/05NK11155
UL	W-L-3100	1, 2	96NK14787
UL	W-L-3132	1, 2	98NK38316/07NK10760
UL	W-L-3219	1, 2	02NK6583/07NK10760
UL	W-L-3256	1, 2	04NK3824/07NK10760
UL	W-L-5273	1, 2	07NK12904
UL	W-L-7009	1, 2	07NK10760
UL	W-L-7136	1, 2	05NK11155/07NK12906
UL	W-L-7145	1, 2	06NK03826

Terms and Conditions: The above-described fill void or cavity material, used by itself or in conjunction with other MEA-approved fire-stop material to fill the remaining voids in wall or floor/ceiling assemblies with the above described fire protection rating, where there may or may not be electrical trays, cables, mechanical piping or ductwork pass through the assembly, is accepted for use in such assemblies when installed in accordance with the manufacturer's application instructions.

1. All shipments and deliveries of such material shall be provided with a label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety

Final Acceptance September 24, 2007

Examined By Simon Derk Hudson