



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 13-92-E Vol.28

Manufacturer: GE Security Inc., 8985 Town Center Parkway, Bradenton, FL 34202

Trade Name(s): EST

Product: Fiber optics modules for EST3

Pertinent Code Section(s): §27-133, Subchapter 17 and Reference Standards RS17-3, RS 17-3A, RS 17-3B & RS 17-3C

Prescribed Test(s): §27-969 (UL 864)

Laboratory: Underwriters Laboratories, Inc

Test Report(s):

1. UL File S3000, Vol. 10, Section 1, issued April 5, 1996 and revised November 5, 2004.
2. UL File S3000, Projects 01NK05159/01NK40698, issued August 22, 2001 and revised March 3, 2006.

Description: Fiber optics interface modules for EST3 system.

Products Covered

EST Cat. No.	Description
3-FIBMB	Fiber optics interface module for data and audio
MMXVR	Multimode fiber transceiver module
SMXHI	Single-mode fiber transceiver module
SMXLO	Single-mode fiber transceiver module
MINI-MUX	Multiplex network card
FCOM-FIB	Fiber optics module for FireWorks

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated September 4, 2007, F.P. Index #0708032.

Terms and Conditions: The above units are accepted on condition that:

1. The use and application of above-referenced fiber optics interface modules shall be limited to building-to-building or campus-wide net communications.
2. The above-referenced modules shall not be used for fire alarm system installation within buildings. Fire alarm system installation in each protected building shall be in accordance with the requirements of the New York City Building Code and Subchapter 17.
3. All uses, configurations, arrangements and functions, application and installations shall be in accordance with the applicable provisions of NYC Electrical Code, and other NYC codes, rules and regulations.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance

September 21, 2007

Examined By

Donald [Signature]