

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner  
MEA 130-00-E

Report of Material and Equipment Acceptance Division

Manufacturer - Systems Sensor, A Division of Pittway, 3820 Stern Avenue,  
St. Charles, IL. 60174

Trade Name(s) - Johnson Controls, Notifier, Pittway Co.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268, UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S3705, Volume 7, Section 1, issued May 5, 1999, ML File S1570  
issued March 7, 1989 and revised December 1, 1999.

Description - Multiple listing for System Sensor's smoke detector as follows:

Johnson Controls Model Number	Description	Basically listed for Notifier, Pittway Co. Model Number
M300MJ	Monitor Modules	FMM-1
M301MJ	Monitor Modules	FMM-101
M300SMJ	Monitor Modules	FSM-101
M302MJ	Monitor Modules	FZM-1
M300CJ	Control Module	FCM-1
M300RJ	Control Module	FRM-1

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objections letter dated March 23, 2000 F.P. Index No. 9912073A for equivalent model numbers under MEA 457-99-E, approved April 17, 2000.

Recommendation - That the above units be accepted on conditions that all uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, the UL listing and UL Standard. Periodic sensitivity tests where required for the smoke detectors shall be conducted in accordance with the regulations of Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance  
Examined By

*October 24, 2000*  
*Mark Jucly*