

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 130-03-E

Report of Material and Equipment Acceptance Division

Manufacturer – Antar-Com, Inc., 155 Lafayette Avenue, White Plains, New York 10603.

Trade Name(s) – UIB 848.

Product – Access control unit accessory, Universal Interface Board.

Pertinent Code Section(s) – 27-968 thru 27-877, Subchapters 6 and 17, Referenced Standard RS 17-3 through RS 17-5.

Prescribed Test – UL 294 (Fifth Edition).

Laboratory – Underwriters Laboratories, Inc.

Test Report(s) – UL File #BP9310, Project #01ME03472 issued February 12, 2002.

Description – The UIB-848 is an access control unit accessory. This non CPU interface board is provided to simplify wiring and installation of access control systems. It is designed to route power to a variety of access control devices such as electrical strikes, maglocks, Trex motion detectors/ switches. The unit can accept up to 8 inputs from access control panels or devices to energize or de-energize 12 VDC or 24VDC maglocks or electric door strikes (base on input power supplied to UIB).

Pursuant to “Promulgation of the Rules relating to Material and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention has no objection letter dated May 27, 2003, F.P. Index No. 0304030A.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17 and with Reference Standards RS 17-3, manufacturer’s recommendations, NFPA 72 and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

June 16, 2003

Examined by

