

City of New York  
Department of Buildings

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 131-03-M  
Report of Material and Equipment Acceptance Division

Manufacturer – Ductmate Industries, Inc., 1502 Industrial Drive, E. Monongahela, Pennsylvania 15063.

Trade Name(s) – Ultimate II.

Product - Grease Duct access door.

Pertinent Code Section(s) – RS-13-3

Prescribed Test(s) – UL 1978.

Laboratory – Underwriters Laboratories.

Test Report(s) - UL File MH27722, dated March 15, 2001.

Description – The Ductmate Ultimate II grease duct access doors are intended to provide access into grease exhaust ducts for the purposes of cleaning or inspection. The ULtimate II door is a frame style door, which has its frame permanently welded to the duct. The Ultimate II is also available with a hinge to keep the door permanently attached to the duct, but still provide easy access. Doors are UL listed and meet all the requirements of UL 1978. The doors are constructed of 11 gauge stainless or carbon steel and utilize a 2300°F ceramic gasket to prevent leakage of air or grease.

Pursuant to “Promulgation of the Rules relating to Material and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated August 21, 2003, F.P. Index No. 0306053B.

Recommendation – That the above described material be accepted, when installed following manufacturer's instructions and Listing laboratory recommendations, for a 2-hour fire resistance enclosure, and on further condition that:

1. Installation, maintenance cleaning procedures and use shall comply with RS 13-3 of the Building Code and all applicable New York City Codes, Rules, Regulation and maintenance requirements.
2. Underwriter's Laboratories, Inc.'s listing requirements and limitations shall be complied with.
3. Manufacturer's installation, maintenance procedures and limitations shall be complied with.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance March/25/04

Examined By S Dorflinger