



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 133-07-E

**Manufacturer:** NorthWind, Inc., 1291 Brummel Avenue  
Elk Grove Village, IL 60007

**Trade Name(s):** Tundra

**Product:** Portable special-purpose air conditioner units

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-11B (ANSI B9.1), RS 13-12 (UL 484)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File SA32369 dated January 8, 2007.

**Description:** Portable special-purpose air conditioner units, designed for indoor installation. R-22 is the refrigerant used for the system. Unit is comprised of rotary compressor, air-cooled condenser, evaporator coil, blower and controls. Units, with model numbers and cooling capacities, are listed below:

Model No.	Mfr's. Specified Cooling Capacity (Btu/hr)
MAC1211	12,000
MAC1811	17,200

**Terms and Conditions:** The above-described air conditioning units are accepted under the following conditions:

1. Units shall use only Refrigerant R-22.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance November 23, 2007

Examined By Saim Deshpande