

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 137-03-M
Report of Material and Equipment Acceptance Division

Manufacturer – Stafford Textiles, Limited, 2200 Lakeshore Boulevard West, #308, Toronto, Ontario Canada M8V 1A4.

Trade Name(s) – Grandform 5371.

Product - PVC coated fabric for flexsign.

Pertinent Code Section(s) - 27-499, 27-501, 27-507, and TPPN #11/99.

Prescribed Test(s) - RS 7-3 [NFPA 701 (Test Method 2)].

Laboratory – The Govmark Organization, Inc.

Test Report(s) – Report No. 2-38749-0 dated January 11, 2002.

Description – Flexsign material 5371 Mesh, is 100% woven polyester fabric with PVC coating on both sides. It comprises 70% PVC and 30% polyester, bonding pre-coat polyester substrate with adhesion then knit coat PVC. The material has a nominal weight of 375 gram/meter square.

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance Oct/29/03

Examined By S Deshpande