



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 137-08-M

Manufacturer: Cooley Incorporated
50 Esten Avenue
Pawtucket, Rhode Island 02860

Trade Name(s): CoolFlex Rigid

Product: Rigid, PVC sheet for Tri-face signs
MEA Index #30 – Flex Signs

Pertinent Code Section(s): 27-499, 27-506, 27-507 and TPPN #11-99

Prescribed Test(s): RS 7-3 (NFPA 701, Method 2)

Laboratory: Magill Laboratories

Test Report(s): Report #080137 dated February 11, 2008.

Description: CoolFlex® Rigid are rigid PVC sheets engineered for use with channeled panels on multi-image billboard systems.

Products Covered:

TF1548KI
TF1552KI
TF1560KI

Terms and Conditions: The above-described materials are accepted with the following conditions:

1. The acceptance of these materials is limited to flame resistance.

2. Structures and other requirements shall be in accordance with pertinent New York City Building Code provisions and Technical Policy and Procedure Notice, #11/99.
3. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Sections 27-499 and 27-501, and the Zoning Resolution.
4. All shipments and deliveries of such materials shall be provided with a label, suitably placed, certifying that the materials shipped or delivered are equivalent to those tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 20, 2008

Examined By Srin Derbladen