

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner

**MEA 140-04-M
Report of Material and Equipment Acceptance Division**

Manufacturer – Watts Regulator Company, 100 Watts Road, Spindale, North Carolina 21860.

Trade Name(s) – Watts.

Product - Anti-siphon atmospheric vacuum breakers.

Pertinent Code Section(s) – P107.18 of Reference Standard RS 16.

Prescribed Test(s) – ASSE No. 1001.

Laboratory – Stevens Institute of Technology.

Test Report(s) – Report No. WTT120303R dated February 19, 2004 and March 5, 2004.

Description - Vacuum breaker assembly, Series 288A-Z38 sizes $\frac{3}{4}$ inches of brass body construction. Unit is provided with disc float which prevents back siphonage.

Recommendation - That the above described anti-siphon atmospheric vacuum breakers, Series 288A-Z38, be accepted when installed in accordance with manufacturer's recommended instructions. These vacuum breakers shall not be used where continuous pressure exists. All shipments and deliveries of such material shall be provided with a metal tag certifying that the material shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance June 12/04

Examined By S. Deshpande