



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 140-05-E

Manufacturer: System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, Illinois 60174.

Trade Name(s): System Sensor.

Product: Fire Alarm Equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR).

Prescribed Test(s): UL 521

Laboratory: Underwriters Laboratories Inc.

Test Report(s): UL File No. S2101, Project 03CA30197, Vol. 10, Sec. 1 issued November 20, 2003 revised March 28, 2005.

Description - Fire Alarm Equipment

Model Number	Description
5601P	Heat Detector (135°F)

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated May 11, 2005, F.P. Index No. 0505018.

Terms and Conditions: That the above units be accepted on condition that all uses, configurations, arrangements, and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard. These products shall be used only with compatible, listed and approved control panels and accessories.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 5, 2006
 Examined by Donald [Signature]