

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 141-02-E
Report of Material and Equipment Acceptance Division

Manufacturer– Vulcain Alarm, Inc. 3 Industrielle St., Delson, Qc J0L 1G0.

Trade Name – Vulcain Alarm Inc.

Product – Annunciator Panel.

Pertinent Code Sections – 27-456, 27-968 thru 27-977.

Tests – UL 1244 (Electrical shock and electrical fire hazard only). CSA Standard C22.2 No. 205-M1983 (R1999)

Laboratory – ETL Testing Laboratory.

Test Reports – 3013397 dated January 31, 2002.

Description - Model VA-SQN-A annunciator panel provides an interface between the gas analyzers/transmitters and external alarming. It provides visual indicators, multiple alarm levels and fault alarm within a location.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections Letter dated July 24, 2002, F.P. Index 0205005A.

Recommendation - That the above panel be accepted on conditions that all uses, configurations, arrangements, functions, applications, and installations shall comply with the provisions of New York City Building Code, specifically Reference Standard RS 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation and NFPA Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

August 27, 2002

Examined by

Mark J. Schiavone