

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 153-00-M

Report of Material and Equipment Acceptance Division

Manufacturer - Nur Media Solution, Rue du Bosquet 8, Louvain-la-neuve, Belgium
1348.

Trade Name - NURTEX Flag FR 21032-21050.

Product - Translucent polyester fabric for flex sign.

Pertinent Code Section(s) -27-499, 27-501, 27-506, 27-507, and TPPN #11/99.

Prescribed Test(s) - RS 7-3 [NFPA 701(Test Method 2)].

Laboratory - Omega Point Laboratories.

Test Report(s) - Report #16047-106522, dated April 4, 2000.

Description - Translucent polyester fabric, NURTEX Flag FR 21032-21050, intended to be used company flag and banners, country and region flag, indoor promotional flags and translucent indoor signage. The nominal weight of the material is 2.4 ounces per square yard.

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance MAY 25 2000

Examined By S. Derkshidan