



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 153-05-E

Manufacturer: Hearth & Home Technologies Inc, 20802 Kensington Blvd., Lakeville, MN 55044.

Trade Name(s): Hearth & Home Technologies.

Product: Gas fired vented decorative fireplace appliances.

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223.1).

Prescribed Test(s): RS 14-6 (ANSI Z21.50-1988).

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File MH28669, dated January 10, 2005.

Description – Gas fired decorative log appliance designed to provide supplemental heating and to enhance the aesthetics of a room.

Product Covered:

	Model No.	Max. Rating (BTU/hr) NG only)	Description
V156	CB4236R	30,000	B-Vent Gas Appliance
V156	CB4842IR	33,000	B-Vent Gas Appliance
V156	CB4236ILR	29,500	B-Vent Gas Appliance
V156	CB4842ILR	32,500	B-Vent Gas Appliance
V155	CD4236R, IR	30,000	Direct Vent Gas Appliance
V155	CD4236ILR	29,500	Direct Vent Gas Appliance
V155	CD4842R, IR	33,000	Direct Vent Gas Appliance
V155	CD4842ILR	32,500	Direct Vent Gas Appliance
V231	GDST5244I	48,000	See-through Direct Vent Gas Appliance
V251	GDST5244IL	43,000	See-through Direct Vent Gas Appliance
V153	ICON60 Series	48,000	Direct Vent Gas Fireplace Heater
V153	ICON100 Series	59,000	Direct Vent Gas Fireplace Heater
V154	SOULSTICE	17,000	Decorative Vented Gas Burning Fireplace
V154	TWILIGHT-II	38,000	Decorative Vented Gas Burning Fireplace

	EL Series	N/A	Wood Burning Fireplace
	RH Series	N/A	Wood Burning Fireplace

Terms and Conditions - The above described gas fired vented appliances are accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from Department before installation. All shipments and deliveries of such equipment shall be provided with a metal tag permanently affixed to the units and suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 12/8/05

Examined by Stephen J. Fernald