

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or materials has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, Acting Commissioner  
MEA 157-00-M

Report of Material and Equipment Acceptance Division

Manufacture – Ali-Porte Inc., 4950 Hickmore – St. Laurent – Quebec, Canada H4T 1K6.  
Trade Name – Ali-Porte.

Product - Swinging fire door assembly.

Pertinent Code Section - 27-329, 27-342.

Prescribed Test - RS 5 - 6 (ASTM E152).

Laboratory – Underwriters Laboratories, Inc.

Test Report - UL File R18162 and R18163 and letter dated April 17, 2000.

Description – Swinging hollow metal type fire doors with foam: polystyrene core or honeycomb core rated for 3, 1-1/2 and ¾ hr. locations. Maximum door sizes are: single swing – 4' 0" wide by 8' 0" high, pairs – 8' 0" wide by 8' 0" high. Series 300 or 400 stainless steel wit honeycomb core rated for 3, 1-1/2 and ¾ hr location. Maximum door sizes: single swing – 3' 5" wide by 7' 0" high.

Door frames for use with transom panels and/or lights and side panels and/or lights; ¾ h frame not to exceed 13'6" wide by 12'0" high when installed in a masonry opening and 11'4" wide by 10'0" when installed in a nonmasonry opening; 1 hr frame not to exceed 10'2" wide by 10'1" high when installed in either a drywall or masonry opening.

Fire door frames for a pair of double egress doors not to exceed 8'0" wide by 10'0" high and multiple frame openings not to exceed 12'0" wide by 8'0" high.

Recommendation - That the above described doors, which shall be operated by an approved fusible link or other New York City approved automatic closing mechanism, be accepted as providing 3/4, 1-1/2 and 3 hours fire protection rating when installed in accordance with Reference Standard RS 5-8 (NFPA 80) for Class A openings, on condition that the certificates or labels all shipments shall be provided by the testing service which shall be regularly engaged by the manufacturer to make periodic inspections and/or tests of the doors in the course of their manufacture. All shipments and deliveries of such materials shall, in addition, be accompanied by a metal tag, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance AUG 18/01

Examined by S Derkhdam