



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 159-07-M

**Manufacturer:** Maharam, 45 Rasons Court, Hauppauge, NY 11788

**Trade Name(s):** 100% Polyolefin Wallcovering, Panel, Upholstered Wall (Textile)

**Product:** Wallcovering, panel, upholstered wall fabric

**Pertinent Code Section(s):** 27-348

**Prescribed Test(s):** RS 5-5 (ASTM E 84), UPITT Toxicity

**Laboratory:** Commercial Testing – ASTM E 84  
Anderson Laboratories – UPITT Toxicity

**Test Report(s):** UPITT: Test # 658, dated March 18, 2007  
ASTM E 84: Test # 05-02021, dated September 17, 2004

**Description:** Wallcovering, panel, upholstered wall textile, which contains 100% polyolefin. Material has stain resistant finish with acrylic backing. Material is manufactured 54" wide and 17.4 oz. per linear yard.

Flame Spread Rating – 25  
Smoke Developed Rating – 25

**Terms and Conditions:** The above-described wall-covering material is accepted with the following conditions.

1. Material is suitable for interior-finish with Class 'A' flame spread rating, as indicated above.
2. Material with smoke density greater than 25 shall not be used in exits or corridors.
3. Material with smoke density greater than 50 shall not be used in occupancy group H-1 and H-2.
4. All shipments and deliveries of such materials shall be provided with a metal tag, suitably placed, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 22, 2007  
Examined By Sivan Derphidan