

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner  
MEA 160-00-E

**Report of Material and Equipment Acceptance Division**

Manufacturer – York International Corp., P.O. Box 1592, Pennsylvania 17405-1592.

Trade Name(s) – York.

Product – Packaged terminal air conditioning units with electric heat.

Pertinent Code Section(s) – 27-770, 27-777.

Prescribed Test(s) -RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995).

Laboratory – Intertek Testing Services.

Test Report(s) – No. J98019536-001 dated August 10, 1998.

Description – Packaged terminal air conditioning units; Model MFT designed for thru-the -wall installation. R-22 is the refrigerant used for the system. Unit consists of hermetic sealed compressor, air cooled condenser with fan, evaporator coil and controls. Units are provided with heating coil for electric heaters for the range of 2.4 kw to 9.5 kw. Units with model number and cooling capacities, are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity BTU	Mfr.'s Specified Nominal Heating Capacity BTU
MFT-A, 150	1953 - 3581	326-6836
MFT-B, 300		651-13,671
MFT-C, 600		1302-27,342

Recommendation - That the above described packaged terminal air conditioning be accepted when utilizing Refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be provisions with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 8/22/2000

Examined By S.M. Prasad