



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 166-07-M

Manufacturer: Intermat Inc., 2045 Placentia Avenue, Costa Mesa, CA 92627

Trade Name(s): Sure-Board®, MagBoard

Product: 22-gauge steel sheet laminated to any form of interior finish

Pertinent Code Section(s): 27-348

Prescribed Test(s): RS 5-5 (ASTM E84), Toxicity

Laboratory: Hardwood/Plywood & Veneer Association Laboratory and Testing Service (HPVA); Anderson Labs, Inc.

Test Report(s): HPVA T-12170 dated February 6, 2007
Anderson Labs, Inc. #659 dated March 19, 2007
E84 flame spread: 5, smoke developed: 5
Toxicity: LC₅₀=>100.0 grams

Description: Sure-Board® panel is a 22-gauge steel sheet laminated to any form of interior-type gypsum, concrete board, glassmat, fiber-reinforced gypsum or magnesium board. These sheets may be used on steel- or wood-framed structures. Sheet panels used to resist wind and seismic lateral loads on steel- and wood-framed buildings. It may also be used to prevent penetration from airborne debris, as well as impact and security protection for prison walls, banks, government buildings and schools.

Flame Spread Rating – 5
Smoke Developed Rating – 5

Terms and Conditions: The above-described panel is accepted with the following conditions:

1. Material is for interior-finish with Class 'A' flame spread rating, as indicated on prior page.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 25, 2007

Examined By Seius Derkudam