



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 168-92-E Vol. 13

**Manufacturer:** Altronix Corporation, 140 58<sup>th</sup> Street, Brooklyn, N.Y. 11220

**Trade Name(s):** Altronix Corp.

**Product:** Power supplies for fire alarm signaling and access control

**Pertinent Code Section(s):** 27-968 through 27-981, Reference Standard RS 17

**Prescribed Test(s):** UL1481, UL294

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File S4707, Projects 00ME14147, 03ME`5511, 04ME11097 and 05ME04470, issued March 9, 2001, revised March 31, 2005.  
UL letter dated September 29, 2006

**Description:** Models, AL300ULS, AL300ULEX are field selectable 12V or 24V multi-purpose power supplies used with fire protective signaling systems and access control systems.

The Model AL300ULEX is identical to the Model AL300ULS power supply except for the use of a larger enclosure.

The units are designed to charge sealed lead acid type re-chargeable batteries and are designed to provide power with a max-resistive load of 2.5A at 12 or 24VDC.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated October 16, 2006, R.P. Index #0610006.

**Terms and Conditions:** The above units are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and with Reference Standards RS 17-3 and RS 17-5.
2. Installation shall be in accordance with the manufacturer's recommendations and UL standards.
3. Underwriters Laboratories Inc.'s listing requirements and limitations shall be complied with.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance October 31, 2006

Examined By Donald A. [Signature]