



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 172-08-E

**Manufacturer:** Lennox Hearth Products  
1110 W. Taft Avenue  
Orange, CA 92865

**Trade Name(s):** Lennox

**Product:** Direct-Vent Gas Fireplace Heaters  
MEA Index #300-20 – Gas-Fired Fireplace

**Pertinent Code Section(s):** Subchapter 14

**Prescribed Test(s):** RS 14-6 (ANSI Z21.88-2005, Z21.88a-2007)

**Laboratory:** OMNI-Test Laboratories, Inc.

**Test Report(s):** O-TL Report #116-F-48-5, issued 06.18.20

**Description:** Direct-vent gas fireplace heaters.

Model Nos.	Input Rating (Btu/hr.) Natural Gas	Low Rate (Btu/hr.)
ADAGIO-MN, ADAGIO-EN, ADAGIO-MP	13,000	10,000

**Width of Units:** 22" Nominal

**Terms and Conditions:** The above described direct-vent fireplace heaters are accepted for operation under the following conditions:

1. Units are for through-the-wall installation only.

2. Units shall use natural gas only.
3. Units shall be installed by a licensed plumber only, who shall insure that installations provided with required unobstructed vent-opening and that all Gas Company requirements for this type of installation are strictly enforced.
4. If steel flue tube passes through a combustible wall, it must pass through a double metal thimble that is two inches larger than the flue.
5. Units shall not be installed behind doors, in an alcove or at locations where curtains or drapes can come into contact with them.
6. Gas pressure regulator shall be installed and gas inlet pressure shall be adjusted by the installer to give inlet pressure at the burner orifice recommended by the manufacturer.
7. A tag must be permanently affixed to the equipment stating that if installed in New York City within 10 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
8. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
9. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
10. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance July 3, 2008  
Examined by Donald 

