



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 174-04-E

Manufacturer: Rheem Manufacturing Co., for RUUD, P.O. Box 17010, Fort Smith, AR 72917-7010.

Trade Name(s): Rheem.

Product: Outdoor air cooled condensers and compressor units.

Pertinent Code Section(s): 27-770, 27-777.

Prescribed Test(s): RS 13-6 (ANSI B9.1), RS 13-11 (CSA C22.2No. 236; UL 1995).

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): No. SA7930 dated January 30, 2004.

Description – Outdoor air cooled condensing and compressor unit used for refrigeration and air conditioning systems. This is a component comprising condenser coil, fan motor and appropriate controls. Units, with cooling capacities are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity Tons
RALC018*	1.5
RALC024*	2.0
RALC030*	2.5
RALC036*	3.0
RALC042*	3.5
RALC048*	4.0
RALC060*	5.0

Note - * Model designation may be suffixed.

Terms and Conditions: That the above outdoor air-cooled condensers be accepted, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 9/15/05
Examined By Stephen. Brown